

## EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 12-Jun-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCPP Unit-1	PDB	1*260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1*210	190	190	4347000		
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	260	6484745	Condenser problem	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	92	2226818	Engine problem	
7	Harpur GTPP	SBU, PDB	2*32	20	0	0	Under maint.	
8	Harpur 412 MW CCPP	EGCB	1*273+1*139	412	398	9684560	Machine problem	
9	Harpur 350MW CCPP(HPL)	IPP	1*235+1*125	360	322	7762000	Machine problem	
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	225	5063000	GT-2 SID, Gas shortage	
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	89	2123520	Engine problem	
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	2246807	Gas shortage & FGMO	
13	Madanganj 102 PP(Summit)	ORPP	6*17	102	0	0		
14	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	50	1190934	Engine problem	
15	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired	
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	473940		
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.	
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	96	566000	GT-2 U/M & Gas shortage	
19	Siddhirganj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	91	2020541	Engine problem	
20	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage	
21	Sagariganj 102 MW PP (Digital Po	IPP	1*28.924	102	93	1968480	Engine problem	
22	Katohli 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1289160		
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2869920		
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1331762		
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1318575		
27	Bosila 108MW RPCL	IPP	12*9.15+1*3.0	0	0	0		
28	Summit Power (Madhabadi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	49	1177800	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	649080		
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	24	576300	Engine problem	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	47	1032480	#REF!	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	290	6822216	Engine problem	
34	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	302	3603361		
35	Bramhangonj 100 MW PP (Aggr)	IPP	114*0.959	100	100	1629594		
36	Aurahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	98	1510619		
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	132	3209470	Engine problem	
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2346000		
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	88	2202240	Engine problem	
40	Manikganj 162MW MPGL	IPP	9*18	162	162	3689280		
41	Spectra Solar Plant Ltd.	IPP	35	35	0	0		
42	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1341360		
<b>Dhaka area Total</b>				<b>5898</b>	<b>3717</b>	<b>82747552</b>		
43	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem	
44	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
45	Razon 25 MW PP	RPCL	2*8.9	25	25	413983		
46	Talsol 20MW PP (Solartech/Teknaf	Solar/Energy	20	20	0	129735		
47	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	34	834720	Engine problem	
48	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	32	758880	Low water level	
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.	
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.	
51	Sikalbaha 105 MW PP (Baraka S	IPP	6*17.5	105	105	2531861		
52	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	34	251744		
53	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	317229	Fuel shortage	
54	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	90	1851600	Engine problem	
55	Juddah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	2047680	Engine problem	
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	520416		
57	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	13	331680		
58	Chattogram 108 MW PP (ECPV)	IPP	18*7.9	108	71	1255560	Engine problem	
59	Kapla 7 MW Solar PP	PDB	7	7	0	30000		
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	265	5587745	Engine problem	
61	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1355059		
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2589380		
63	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	2362560		
64	Anilma Energy Ltd.	IPP	6*21.2	116	108	2373600		
<b>Chattogram area Total</b>				<b>2382</b>	<b>1304</b>	<b>27552392</b>		
65	Ashuganj TPP Unit-3	APSCCL	1*150	129	0	0	Contract Expired	
66	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	Contract Expired	
67	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage	
68	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	208	4513000	#REF!	
69	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	0	0	FGMO	
70	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	260	7159000	Gas shortage	
71	Ashuganj 50 MW CCPP (Baraka)	APSCCL	14*3.968	45	35	820880	Engine problem	
72	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	40	1173120	Gas shortage	
73	Ashuganj 195MW PP (APSCCL-UR	IPP	20*9.73+1*16	195	8	217454	Gas shortage	
74	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1140003		
75	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	133	3029309	Engine problem	
76	Titas 50 MW Peaking PP	PDB	6*8.92	52	47	832552		
77	Chandpur 150 MW Peaking PP	PDB	1*106+1*57	163	0	0	Machine problem	
78	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	2892960		
79	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	444384		
80	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	193860	Engine problem	
81	Impoport (Tripura)	Imported power	0	160	128	2820480		
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	708100		
83	Jangalia 52 MW PP (Midnew)	IPP	8*8.92	52	0	0	Fuel shortage	
84	Jumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*8.97	25	20	464880	Engine problem	
85	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	50	1154880	Fuel shortage	
86	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	278160	Fuel shortage	
87	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	9	220920	Fuel shortage	
88	Bhairab 54.5 MW	IPP	3*18.2	54	35	867960	33 kV feeder problem.	
89	Chandpur 113(Doreen)	IPP	4*18.5+2*22.5	113	98	2241800	Engine problem	
<b>Comilla Area Total</b>				<b>3074</b>	<b>1401</b>	<b>3172592</b>		
90	RPCL 210MW CCPP	IPP	4*35+1*70	202	108	2859600	Gas shortage	
91	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	418608		
92	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.	
93	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	7950		
94	Mymensingh 200 MW PP (Unitec	IPP	9*78*21	200	185	4252800	Engine problem	
95	Jamalpur 115 MW PP (Unitec)	IPP	9*78*21	115	106	1768800	Engine problem	
96	Suitkhal 50 MW Solar PP	IPP	50	50	0	1537560		
97	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	22	523200		
<b>Mymensingh Area Total</b>				<b>622</b>	<b>441</b>	<b>10013708</b>		
98	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1022000	Machine problem	
99	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	919992	Machine problem	
100	Kushhara 163 MW CCPP (KP)	IPP	1*108+1*54	163	110	2679709	ST Under maint.	
101	Shahjibazar 330 MW PP (Baraka)	PDB	3*110	330	0	0	Under maint.	
102	Fenchugonj 51 MW DP (Baraka)	RPP	19*2.90	51	53	1252800		
103	Fenchugonj 44MW (Energyprima	RPP	12*3.35+5*2	50	50	1190304		
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000		
105	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	55	1437504		
106	Shahjibazar 96MW PP (Shahjibaz	RPP	32*2.90	86	81	1856640		
107	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.	
108	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	0	0	Gas shortage	
109	Sylhet 20 MW GTTP	PDB	1*20	20	18	433000		
110	Sylhet 50MW PP (EPL)	RPP	27*2	50	41	935360	Engine problem	
111	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	563976		
112	Bibliana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	310	7304500	FGMO	
113	Bibliana-III 400 MW CCPP	PDB	400 MW	400	402	9556000		
114	Sylhet 108MW PP (EPL)	RPP	8*13.95	108	10	254880		
115	Bibliana South 400 MW	PDB	400 MW	383	260	6243000	ST Under maint.	
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1509</b>	<b>35913665</b>		
116	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.	
117	Bheramara (HVDC)	Imported power	2*500	1000	923	22312000		
118	Khulna 115 MW (KPCL-2)	ORPP	7*17	115	106	2116800	Engine problem	
119	Farpur 50 MW Peaking PP	PDB	8*8.9	54	38	297600	Engine problem	
120	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	210	3598417		
121	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	75	626768	Engine problem	
122	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	195	4663584	Gas shortage	
123	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	40	40	732000		
124	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	40	388800	Line O/L	
125	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	2345760		
126	Madhumati 100 MW PP	NWPGCL	1*141	105	105	2637328		
127	Mongla Orion 100 MW Solar PP	IPP	100	100	0	527200		
<b>Khulna Area Total</b>				<b>2384</b>	<b>1837</b>	<b>35869777</b>		
128	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	48	947136	Line O/L	
129	Bhola 33 MW PP (Venture)	RPP	1*34.50	40	33	621136	Engine problem	
130	Bhola 225 MW CCPP	PDB	2*63+1*68	194	66	1553000	Gas shortage	
131	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	0	0	0	Contract Expired	
132	Payra 1320 MW PP	BPCL	2*622	1244	1070	24184800	Line O/L	
133	Bhola Nutan Bidut BD LTD	IPP	220	220	216	4990582		
134	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	1			