

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation	Energy Generated	Remarks
				MW	KWH			
Unit No. X Capacity								
1	Ghoratal Repowered CCPP Unit-3 (ST)	PDB	1'260	260	0	0	Under maint.	
2	Ghoratal Repowered CCPP Unit-4	PDB	1'260	180	0	0	Under maint.	
3	Ghoratal 365 MW CCPP Unit-7	PDB	1'210	160	180	4347000		
4	Ghoratal 78.5 MW PPMAX	QRPP	2'40	0	0	0	Contract Expired	
5	Ghoratal 108MW PP (Regent)	IPP	34'3.35	108	94	2130636		Engine problem
6	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.	
7	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	396	9658370		Machine problem
8	Haripur 30MW CCPP (HPL)	IPP	1'250+1'125	360	320	7895630		Machine problem
9	Meghnaghat 450 MW CCPP (MPL)	IPP	2'150+1'100	450	225	4622150		GT-1 S.D. Gas shortage
10	Meghnaghat 100 MW (EEL)	QRPP	12'9.9	100	80	1974720		Engine problem
11	Meghnaghat CCPP (Summit)	IPP	2'110+1'110	335	0	0	Under maint.	
12	Madangan 102 PP (Summit)	QRPP	6'17	102	0	0	Under maint.	
13	Madangan 55 MW PP (Summit)	(IPP)	3'17.08+1'11.3	55	55	1247845		
14	Madangan 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired	
15	Madangan 23 MW PP (Dorson)	SIPP, REB	8'2.90	22	22	317772		
16	Madangan 210 MW Sidhargarh TPP	PDB	1'210	115	0	0	Under maint.	
17	Sidhargarh 210 MW GTTP	EGCB	2'105	210	94	2330000		GT-2 U/M
18	Sidhargarh 100 PP (Dutch Bangla)	QRPP	12'9.9	100	91	1865000		Engine problem
19	Sidhargarh 335 MW CCPP	EGCB	1'217+1'18	335	0	0	Gas shortage	
20	Gagragar 102 MW PP (Digital Power)	IPP	12'6.924	102	94	2067696		Engine problem
21	Katani 52 MW PP (Summit)	IPP	7'17.9	51	0	0	Under maint.	
22	Karnahat 54 MW PP (Banco Energy)	IPP	3'16	54	35	1045080		Engine problem
23	Koda 150MW PP	BPOB-RPCL	9'17.08	149	150	2870880		
24	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1126630		
25	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	1291186		
26	Boala 108MW PP (CLC)	IPP	12'9.775+1'9.5	0	0	0		
27	Sumit Power (Madhat-Kashala)	SIPP, REB	3'3.67+4'7.3	80	48	1160000		Engine problem
28	Macra 33 MW PP (Summit)	SIPP, REB	4'8.73	33	33	762640		
29	Rugan 33 MW PP (Summit)	SIPP, REB	4'8.73	33	0	271600		Engine problem
30	Gaspur 52 MW PP	RPCL	6'8.9	52	47	1003680		(REF)
31	Tong 80 MW GTTP	PDB	1'105	105	0	0	Under maint.	
32	Koda 300 MW PP Unit-2 (Summit)	IPP	8'17.076	300	276	6613961		Engine problem
33	Kariganj 30 MW PP (HPL)	IPP	2'6.14	30	30	291633		
34	Branaganj 100 MW PP (Aggreko)	IPP	114'9.959	100	95	1142392		Engine problem
35	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	96	1178921		Engine problem
36	Koda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	114	2850192		Engine problem
37	Gaspur 100 MW PP	RPCL	6'17.5	105	105	2403600		
38	Meghnaghat 104 MW PP (DPL)	IPP	18.5'6	104	104	2316480		
39	Manikganj 102MW PP (MPL)	IPP	9'16	102	162	3739200		
40	Spectra Solar Plant Ltd	IPP	35	0	35	0		
41	Kapichan Purbachal Power Generation Ltd	IPP	18.4'3	55	55	1311840		
<b>Dhaka area Total</b>								
41	Chatogram TPP-1	PDB	1'210	180	100	2300000		Machine problem
42	Chatogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
43	Razzan 25 MW PP	RPCL	3'9.9	25	0	424955		
44	Khajuri 20MW PP (Summit)	National Solar Energy Lt	2'6.20	20	0	107720		
45	Khajuri 50MW PP (Baraka)	IPP	8'6.88	50	43	918720		Engine problem
46	Kapila Hydro Unit-1,2,3,4,5	PDB	2'40+3'50	230	32	766080		Lowwater level
47	Sikabaha 220MW	PDB	1'150+1'175	225	0	0	HGR for 30 days.	
48	Sikabaha Peaking GT	PDB	1'150	150	0	0	Under maint.	
49	Sikabaha 105 MW PP (Baraka Sikabaha)	IPP	8'17.5	105	87	2468109		Engine problem
50	Hafiznagar 100 MW peaking PP	PDB	11'9.9	96	34	305280		Engine problem
51	Dokan Katabh 100 MW Peaking	PDB	6'17	102	51	201587		Fuel shortage
52	Jukah 100 MW Unit-1 (Acom)	QRPP	8'13.45	100	90	2121480		Engine problem
53	Jukah 100 MW Unit-3 (Acom)	IPP	8'13.5	100	90	2053040		Engine problem
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	472656		
55	Malancha, Cig, EPZ (United)	IPP	5'8.73+3'9.34	0	17	364800		
56	Chatogram 108 MW PP (ECPV)	IPP	16'7	108	74	1262200		Engine problem
57	Kajali 1 MW Solar PP	IPP	7.4'96	7	0	2626		
58	Amena 300 MW PP (United)	IPP	17'1+24	300	282	505040		Engine problem
59	Jodac Power	IPP	3'18.55+1'3.6	54	54	1307595		
60	Karnaphuli Power Ltd	IPP	18.419'6+6.5	110	92	2283263		Engine problem
61	Jukah unit-2 (Acom)	IPP	8'13.6	100	100	2405760		Engine problem
62	Anlma Energy Ltd	IPP	6'21.2	116	108	2099455		Engine problem
<b>Chatogram area Total</b>								
61	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired	
62	Ashuganj TPP Unit-4	APSCL	1'150	129	0	0	Contract Expired	
63	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage	
64	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	193	4623000		(REF)
65	Ashuganj 450 MW CCPP (North)	APSCL	1'360	360	0	0	Gas shortage	
66	Ashuganj 450 MW CCPP (South)	APSCL	1'360	305	305	7514000		Gas shortage
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	38	829772		Engine problem
68	Ashuganj 55 MW PP (Pheasant)	IPP	10'4	55	55	1315616		Engine problem
69	Ashuganj 150MW PP (APSCL-United)	IPP	20'9.73+1'16	195	8	200727		Gas shortage
70	Ashuganj 51 MW PP (Midand)	IPP	6'9.34	51	38	884541		Engine problem
71	Ashuganj 150MW PP (Midand)	IPP	23'7.015	150	134	3116290		Engine problem
72	Titas 50 MW Peaking PP	PDB	6'8.92	52	47	1160112		Engine problem
73	Chandpur 150 MW CCPP	PDB	1'106+1'157	163	0	0	Machine problem	
74	Chandpur 200MW (Dorson)	IPP	12'18.4	200	200	2968000		
75	Feni 22MW PP (Dorson)	SIPP, PDB	8'2.90	22	21	477540		
76	Feni 11 MW PP (Dorson)	SIPP, REB	4'2.90	11	0	169300		Engine problem
77	Import (Tripura)	Imported power	0	160	114	283080		
78	Jangila 33MW PP (Summit)	SIPP, PDB	4'8.73	33	19	234700		Engine problem
79	Jangila 52 MW PP (Ladawan)	IPP	6'9.92	52	0	0	Gas shortage	
80	Kumila 25 MW PP (Summit)	SIPP, PDB	3'3.89+2'9.97	25	20	516870		Engine problem
81	Darshana 200 MW PP (B. Trac)	IPP	154'1.4	200	205	691584		Fuel shortage
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	427900		Fuel shortage
83	Chowmohani 113 MW	IPP	12'9.78+2'3.1	113	9	240240		Fuel shortage
84	Bharat 54.5 MW	IPP	3'18.2	54	35	859680		33 kV feeder problem.
85	Chandpur 115(Dorson)	IPP	4'18.5+2'22.5	115	99	2097600		Engine problem
<b>Cumilla Area Total</b>								
83	RPCL 210MW CCPP	IPP	4'30+1'70	202	114	2611500		Gas shortage
84	Tangail 22 MW PP (Dorson)	SIPP, PDB	8'2.90	22	20	432048		
85	Jamapur 95 MW PP (Powerpac)	IPP	12'6.924	8	0	0	Under maint.	
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	7350		
87	Mymensingh 200 MW PP (United)	IPP	9'78.21	200	180	4168800		Engine problem
88	Jamapur 115 MW PP (United)	IPP	9'78.12	115	96	2098800		Engine problem
89	Sabhalai 50 MW Solar PP	IPP	50	50	0	84380		
90	Tangail Fall Power Gen-22 MW	IPP	4'6.7	22	22	530560		
<b>Mymensingh Area Total</b>								
91	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	43	1036000		Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	80	41	963824		Machine problem
93	Kuthara 163 MW CCPP (KIP)	IPP	1'109+1'54	163	110	2724872		ST Under maint.
94	Shahbaz 330 MW CCPP	PDB	3'110	330	0	0	Under maint.	
95	Fenchuganj 51 MW PP (Barakatalah)	IPP	1'97.90	51	53	1269300		
96	Fenchuganj 44MW (Energies)	IPP	12'3.3+2'72	50	50	1205784		
97	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	230040		
98	Shahbaz GTTP Unit-8 & 9	PDB	2'35	66	65	1476552		
99	Shahbaz 80MW PP (Shahbaz)	RPP	32'2.90	86	81	1866240		
100	Shahbaz 100 MW GTTP	PDB	1'100	100	0	0	Under maint.	
101	Sylhet 225 MW CCPP	PDB	1'143+1'189	231	0	0	Under maint.	
102	Sylhet 20 MW GTTP	PDB	1'20	20	18	438000		
103	Sylhet 60MW PP (EPL)	RPP	2'72	60	41	999300		Engine problem
104	Shahabnuda 25 MW PP	SIPP, REB	3'9.34	25	24	435408		
105	Boiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	260	7200500		FGMO
106	Boiana-III 400 MW CCPP	PDB	400 MW	400	399	9521000		
107	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	237780		
108	Boiana South 400 MW	PDB	400 MW	383	260	5433300		ST Under maint.
<b>Sylhet Area Total</b>								
107	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.	
**	Bheramara (HVDC)	Imported power	2'500	1000	922	22311272		
108	Khulna 115 MW (KPCCL-2)	QRPP	7'17	115	75	2043840		Engine problem
109	Fairpur 50 MW Peaking PP	PDB	8'6.89	54	42	233440		Engine problem
110	Khulna 225 MW CCPP	NWPGL	1'180+1'175	230	217	4037760		Machine problem
111	Chaugajal 100 MW Peaking PP	PDB	16'8.98	108	68	625054		Engine problem
112	Bheramara 410 MW CCPP	NWPGL	1'278+1'132	410	240	5330332		Gas shortage
113	Noapara 40 MW PP (Kharjahan Al)	QRPP	5'8.5	40	40	683625		
114	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	10	127680		Low Demand
115	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	105	2132640		
116	Machumoni 100 MW PP	NWPGL	6'18	105	89	2256948		Engine problem
117	Machumoni 100 MW Solar PP	IPP	100	100	0	454240		
<b>Khulna Area Total</b>								
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	48	1925184		Line O/L
118	Bhola 33 MW PP (Venture)	RPP	1'34.50	40	32	636517		Engine problem
119	Bhola 225 MW CCPP	PDB	2'63+1'68	184	52	1343000		Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	95'1.10	0	0			