

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel. 9564667, 9551095

Month June, 2022										Day : Saturday		Date : 18.06.22				
Probable Maximum Demand : 12300 MW				Probable Maximum Generation : 14919 MW						Rule Curve = 80.49 ft.						
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 74.89 ft		Today = 75.62 ft				
Sl. No.	Name of Power Station	Nos. of Unit	X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.22 (Yesterday)		18.06.22 (Today)		17.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
						Day Evening		Day Evening		Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
(A) Plants in operation:																
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas	(PDB)	1 x 260	260	260	0	0	0	0	260	Under project work				
2	a) Ghorasal Repowered CAPP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.				
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CAPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	260	220	280	280						
4	Ghorasal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	94	97	97	97						
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.				
6	Hairpur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0		Contract Expired				
7	Hairpur 360MW CAPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	262	0	0	0						
8	Meghnaghat 450 MW CAPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	225	360	360	360	90	Gas Shortage				
9	210 MW Siddhirganj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling				
10	Hairpur 412 MW CAPP	Gas	(EGCB)	1x273+1x139	412	412	398	43	405	412						
11	Siddhirganj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	0	0	0	0	105	105				
12	Siddhirganj 335 MW CAPP	Gas	(EGCB)	1 x 217+1x118	335	335	250	46	335	335						
13	Meghnaghat CAPP(Summit)	GAS	(IPP)	2x110+1x110	335	335	130	300	280	300						
14	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	15	55	55	55						
15	Gagragar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	16	0	94	94						
16	Narshingi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	0	0	22	22						
17	Summit Power, (Madhabdi+Ashulia)	Gas	(SIPP, REB)	6x3.67+6x3.73	80	80	44	41	50	50						
18	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	33	28	33	33						
19	Rugganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	25	0	25	25						
20	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	24	0	48	48						
21	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	105	0	90	90						
22	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	32	0	150	150						
23	Kamalganj 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	35	54	54	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	16	130	285	290						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	108	106	135	135						
26	Keranganj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	0	0	200	300						
27	Bramanganj 100 MW PP (Agrako)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	100	100						
28	Aurath 100MW PP (Agrako)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	98	98						
29	Nababganj 55 MW PP (Southern powe)	HFO	(IPP)	3x19.3	55	55	55	35	55	55						
30	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	17	55	55	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	17	88	88	88						
32	Manikganj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	17	35	162	162						
33	Manikganj 35MW Solar PP (Inspectra)	Solar	(IPP)	1x35	35	35	0	0	30	0						
34	Kanchan Purbachal Power Generation	HFO	(IPP)	3x19.404	55	55	34	17	55	55						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO	(NENP)	12x8.9	100	100	8	16	90	100						
36	Meghnaghat 100 MW (IEL)	HFO	(NENP)	12x8.9	100	100	32	78	79	90						
37	Madanganj 102 PP(Summit)	HFO	(NENP)	6x17	102	102	0	0	0	0						
Dhaka Zone Total				6004	5847	2432	1984	3990	4113	195	765					
38	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	66	66	66	66	164	Low water level				
39	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage				
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.				
40	Kaptai 7 MW Solar PP	Solar	(PDB)	7	7	1	0	5	0							
41	Raccon 25 MW PP	HFO	(RPCL)	3x8.9	25	25	0	0	25	25						
42	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	4	0	20	0						
43	Patnaf 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	45	45	45	45						
44	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO	(IPP)	6x18.415	105	105	68	105	105	105						
45	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.				
46	Sikalbaha 225 MW CAPP	Gas	(PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI				
47	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+3x8.04	300	300	15	0	265	285						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO	(IPP)	8x13.45	100	100	16	90	90	90						
49	Dohazari-Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	0	0	0	0	51					
50	Haf hazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	0	17	35						
51	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	22	22	22	22						
*	Malancha, Chg EPZ (United)	Gas	(PDB)	5x8.73+3x9.34	108	108	20	42	15	30						
52	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	0	0	78	81						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	17	54	54	54						
54	Kamaphul Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	34	92	110	110						
55	Juldah unit-2 (Acom)	HFO	(IPP)	8x13.6	100	100	60	100	100	100						
56	Juldah 100 MW Unit-1 (Acom)	HFO	(QRPP)	8x13.45	100	100	0	60	90	90						
57	Chattogram 116 MW PP (Anima Ener)	HFO	(IPP)	6x21.06	116	116	68	90	90	90						
Chattogram Zone Total				2442	2382	536	866	1297	1379	244	555					
58	a) Ashuganj TPP Unit- 4	Gas	(APSCCL)	1 x 150	150	0	0	0	0	0		Contract Expired				
	b) Ashuganj TPP Unit- 5	Gas	(APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage				
59	Ashuganj 50 MW PP	Gas	(APSCCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage				
60	Ashuganj 225 MW CAPP	Gas	(APSCCL)	1x142+175	221	221	148	176	180	200						
61	Ashuganj 450 MW CAPP(South)	Gas	(APSCCL)	1x360	360	360	260	280	280	300						
62	Ashuganj 450 MW CAPP(North)	Gas	(APSCCL)	1x361	360	360	260	280	280	300						
63	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage				
64	Ashuganj 195MW PP (APSCCL-United)	Gas	(IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage				
65	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	43	50	51	51						
66	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	10	149	140	150						
67	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	0	0	50	50						
68	Chandpur 150 MW CAPP	Gas	(PDB)	1X106+1x57	163	163	136	135	135	135						
69	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	17	155	150	200						
70	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	19	18	21	21						
71	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	8	8	8	8						
72	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	0	0	0	0						
74	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21						
75	Daudkandi 200 MW PP (B. Trac)	HSD	(IPP)	95x1.4+6x1.915+15x1.928	200	200	0	0	100	200						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO	(IPP)	7'18.415+1'9.78	114	114	0	0	0	0						
77	Chowmuhani 113 MW	HFO	(IPP)	12'9.79+2'13.1	113	113	9	96	96	96						
78	Bharos 54 MW PP	HFO	(IPP)	3x18.2	54	54	17	0	35	35						
79	Chandpur 115MW PP (Doreen)	HFO	(IPP)	4x18.516+2x23.428	115	115	50	101	100	100						
**	Imporrt (Tripura)	India		160	160	86	100	143	165							
Cumilla Zone Total				3059	2885	1130	1615	1836	2078	416	0					
80	RPCL 210MW CAPP	Gas	(IPP)	4x35+1x70	210	202	119	160	160	190	42	Gas Shortage				
81	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	17	20	20	20						
82	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	8	8	95	107						
83	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	8	145	180	191						
84	Sanshabani 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	0	0	1.6	0						
85	Sutakhalai 50 MW Solar PP	Solar	(IPP)	1x50	50	50	0	0	50	0						
86	Tangail 22 MW PP(PPGL)	HFO	(IPP)	4x6.7	22	22	0	22	22	22						
Mymensing Zone Total				622	614	152	355	529	530	42	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.22 (Yesterday)		18.06.22 (Today)		17.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43			GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41			GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	1x92.90	51	51	36	11	51	51					
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110			ST under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	64	62	65					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	130	0	0					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	0	0	0					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	0	0					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	265	295	280	300					
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	399	400	400					
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	280	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100 Under project work		
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	0	0	0					
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	35	10	50	50					
Sylhet Zone Total					2522	2477	1267	1614	1532	1555	0	559		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278-1 x 132	410	410	270	285	270	300			125 Gas Shortage		
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	38	38					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
109	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 159+1x75	230	230	120	105	120	220					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	93	93					
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	70	89					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	31	0	100	0					
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	20	0	99	99					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40					
**	Bheramara (HVDC)	India		1000	1000	918	918	935	935					
Khulna Zone Total					2388	2384	1359	1348	1765	1974	125	0		
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	48					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	30	20	33					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	81	85	85	85					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	260	1050	1050					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17					
121	Bhola 220MW CCPP (Nutan Bidyut BC	Gas/HSD (IPP)	2x75+1x70	220	220	160	224	220	220					
Barishal Zone Total					1958	1958	620	599	1440	1453	0	0		
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71 Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100 Gas Shortage		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	34					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	190					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0					
126	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	0	90					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	32					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	34					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40					
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0			210 Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	130	130	130	180			90 Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	140	180	180			80 Gas Shortage		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	250	414	350	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	70	95	113					
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	94	94					
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total					2129	2129	560	851	1084	1434	551	0		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Under Overhauling		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175			99 Coal Shortage		
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	15	95	95					
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
145	Majpara, Taula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	0	0	8	0					
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	108	108	108					
Rangpur Zone Total					800	720	175	298	386	403	184	85		
Sub-total: Plants in operation					21924	21396	8231.0	9530	13859	14919	1757	1964		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8034	9302	13528	14563				
(B) Plants under long term maintenance contract expired														
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired		
148	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired		
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
150	Karriganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired		
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance contract expired					424	0	0	0	0	0	0	0		
Gross Total					22348	21396	8231	9530	13859	14919	1757	1964		
(C) Actual data of 17.06.22 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)				9530	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)				9302	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)				12316	MW, at = 1:00 hrs	Dhaka	3181	3181	0	Myemsingh	652	652	0
04.	Minimum Generation (Generation end)				8231	MW, at = 9:00 hrs	Chattoagram	1151	1151	0	Sylhet	236	236	0
05.	Day-peak Generation (Generation end)				8231	MW, at = 9:00 hrs	Khulna	1156	1156	0	Barishal	337	337	0
06.	Evening-peak Generation (Generation end)				9530	MW, at = 21:00 hrs	Rajshahi	1008	1008	0	Rangpur	651	651	0
07.	Evening Peak Load-shed (Sub-station end)				0	MW, at = 21:00 hrs	Cumilla	930	930	0				
08.	Minimum Generation Forecast up to 8:00 hrs.				8424	MW, at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :													
a)	Gas limitation				1409	MW								
b)	Coal supply Limitation				184	MW								
c)	Low water level in Kaptai lake				164	MW								
d)	Plants under shut down/ maintenance				1964	MW								
10.	Total Energy (Generation + India Import)				225.50	MKWh								
	By Gas =	131.264	MKWh	By Oil =	53.566	MKWh								
	By Coal =	14.092	MKWh	By Hydro =	1.582	MKWh								
	By Solar =	0.504	MKWh											
11.	Total Gas Supplied				997.87	MMCFD								
(D) Forecast of 18.06.22 (Today) Saturday :														
01.	Maximum Demand				12300	MW (Generation end)	04.	Maximum Load-shed			0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation				14919	MW (Generation end)	05.	Total Generation			225.21	MKWh		
03.	Reserve / Shortage				2619	MW (Generation end)	06.	Probable Max. Temperature in Dhaka			34.3° C			

* Cogline Power; ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation