

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present			Remarks
				Capacity	Peak Hour Generation	Energy Generated	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	4378500	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	81	1759500	Engine problem
6	Harpur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
7	Harpur 412 MW CCPP	EGCB	1*273+1139	412	410	9971710	
8	Harpur 350MW CCPP(HPL)	IPP	1*235+1125	360	0	0	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1150	450	400	9492250	Gas shortage
10	Meghnaghat 100 MW(EL)	NENP	12*8.9	100	88	1957440	Engine problem
11	Meghnaghat CCPP(Summit)	IPP	2*110+1110	335	300	6773207	FGMO
12	Madangan 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madangan-55 MW PP(Summit)	EGCB	3*17.08+1111.3	55	55	1272654	
14	Karanaganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
15	Narsingi 22 MW PP (Doreen)	SIPP, REB	8*2.80	22	22	326808	
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2120 MW GTTP	EGCB	2*105	210	0	0	GT-2 U/M and gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	70	1491840	Engine problem
19	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	337	7948803	
20	Saganaganj 102 MW PP (Digital Po)	IPP	12*8.924	102	94	1469240	Engine problem
21	Katohli 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1306800	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1459200	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1162014	
25	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	35	973771	Engine problem
26	Boisia 108MW RPCL	IPP	12*9.15+113.5	0	0	0	
27	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	45	1178700	Engine problem
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	738400	Engine problem
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	0	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	50	1006560	#REF!
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW Unit-2 (Summ)	IPP	18*17.076	300	285	5298563	Engine problem
33	Karanaganj 300 MW PP (APR)	IPP	25*11.4	300	122	121139	Low demand
34	Bramhangan 100 MW PP (Aggr)	IPP	114*0.959	100	86	277925	Low demand
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	80	193784	Low demand
36	Kodda 149 MW PP Unit-1 (Summ)	IPP	8*18.45+8.97	149	112	2970580	Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2002800	
38	Meghnaghat 104 MW PP (QPCL)	IPP	18*5.9	104	94	2188600	Engine problem
39	Manikganj 162MW MIPGL	IPP	9*18	162	162	2868600	
40	Spectra Solar Plant Ltd.	IPP	35	35	0	121508	
41	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1241280	
Dhaka area Total				5847	3552	7187706	
41	Chattogram TPP-1	PDB	1*210	180	100	2300000	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Razzan 25 MW PP	RPCL	3*8.9	25	25	327400	
44	Talsari 20MW PP (Solutech)	IPP	20	0	0	81945	
45	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	37	4438400	Engine problem
46	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	81	2626198	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka St)	IPP	6*17.5	105	105	2493199	
50	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	43	242976	Engine problem
51	Dohazari-Kalash 100 MW Peakin	PDB	6*17	102	51	289975	Fuel shortage
52	Julidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	30	882960	Engine problem
53	Julidah 100 MW Unit-3 (Acorn)	IPP	8*13.5	100	83	1732300	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	580128	
55	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	25	489120	
56	Chattogram 108 MW PP (ECPV)	IPP	18*5.92	108	62	776640	Engine problem
57	Kapla 7 MW Solar PP	PDB	7	7	0	25020	
58	Anwara 300 MW PP (United)	IPP	1*17+24	300	220	2601927	Engine problem
59	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1313003	
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2606098	
61	Julidah unit-2 (Acorn)	IPP	8*13.6	100	50	1817280	
62	Anilima Energy Ltd.	IPP	6*21.2	116	90	2152800	Engine problem
Chattogram area Total				2382	1188	31697169	
63	Ashuganj TPP Unit-3	APSCl	1*150	0	0	0	Contract Expired
64	Ashuganj TPP Unit-4	APSCl	1*150	0	0	0	Contract Expired
65	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage
66	Ashuganj 225 MW CCPP	APSCl	1*142+1*75	221	200	4639000	#REF!
67	Ashuganj 450 MW CCPP(North)	APSCl	1*360	360	355	7639500	FGMO
68	Ashuganj 450 MW CCPP(South)	APSCl	1*360	360	335	7831000	FGMO
69	Ashuganj 423 MW CCPP(East)	APSCl	284*1+138*1	0	0	1529900	On test.
70	Ashuganj 50 MW PP	APSCl	14*3.968	45	33	690480	Engine problem
71	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	51	1014720	
72	Ashuganj 195MW PP (APSCl-Ur)	IPP	20*9.73+1*16	195	150	3111272	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1017118	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	143	2835372	Engine problem
75	Titas 50 MW Peaking PP	PDB	8*8.92	52	49	518824	
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	136	3258510	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	3074880	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	461232	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	202140	
80	Import (Tripura)	Imported power	0	160	156	3264960	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	513900	
82	Jangalia 32 MW PP (Lakshmi)	IPP	6*8.92	52	0	0	Fuel shortage
83	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	476120	
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Fuel shortage
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	95	1594320	Engine problem
87	Bharoi 54.5 MW	IPP	3*18.2	54	35	890280	33 KV feeder problem.
88	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	116	2728400	
Cumilla Area Total				2885	2189	4688028	
89	RPCL 210MW CCPP	IPP	4*35+1*70	202	154	3751800	Gas shortage
90	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	378540	
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14850	
93	Mymensingh 200 MW PP (Unite)	IPP	9*7.21	200	181	4104000	Engine problem
94	Jamalpur 115 MW PP (Unite)	IPP	9*7.92	115	96	1851000	Engine problem
95	Sultakkhal 50 MW Solar PP	IPP	50	50	0	287250	
96	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	24	569760	
Mymensingh Area Total				614	475	10667280	
97	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1033000	Machine problem
98	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	581184	Machine problem
99	Kushkhara 163 MW CCPP (KP)	IPP	1*109+1*54	163	110	2694763	ST Under maint.
100	Shahbazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
101	Fenchugonj 51 MW PP (Barakat)	RPP	19*2.90	51	31	1078800	Gas shortage
102	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	30	1056528	Gas shortage
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
104	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1315680	
105	Shahbazar 56MW PP (Shahbaz)	RPP	32*2.90	66	84	1681920	
106	Shahbazar 100 MW GTTP	PDB	11*100	100	0	0	Under maint.
107	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	120	2895300	ST Under maint.
108	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
109	Sylhet 50MW PP (EPL)	NENP	27*2	50	25	574280	
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	372096	Engine problem
111	Bibianna-II 341 MW CCPP (Summ)	IPP	1*222+1*119	341	315	7014500	FGMO
112	Bibianna-III 400 MW CCPP	PDB	400 MW	400	400	9376000	
113	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	210060	
114	Bibianna South 400 MW	PDB	400 MW	383	400	9221400	
Sylhet Area Total				2477	1692	39369511	
115	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
116	Bheramara (HVDC)	Imported power	2*500	1000	923	22339636	
117	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	103	1179840	Engine problem
118	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	42	199220	Engine problem
119	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
121	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	305	7607520	Gas shortage
122	Noapara 40 MW PP (Khanjahan A)	NENP	5*8.5	40	40	409500	
123	Noapara 100 MW PP (Bangla Tre)	IPP	70*1.4	100	70	289920	Low demand
124	Rupsha 105 MW PP (Orion ruspk)	IPP	6*18.445	105	76	1254240	Engine problem
125	Madhumati 100 MW PP	NWPGCL	105	105	15	91440	Line O/L
126	Mongla Orion 100 MW Solar PP	IPP	100	100	0	583200	
Khulna Area Total				2384	1574	33954016	
127	Barisal 110 MW PP (Summit I)	IPP	7*17.076	110	16	86032	Line O/L
128	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	27	543226	Engine problem
129	Bhola 225 MW CCPP	PDB	2*63+1*88	194	83	2112962	Gas shortage
130	Bhola 95 MW PP (Aggreko)	ORPP	9*11.0	0	0	0	Contract Expired
131	Payra 1320 MW	BCPCL	2*622	1244	540	12160100	Line O/L
132	Bhola Nutan Bidut BD LTD	IPP	220	220	222	5052682	
133	Unite Payra Power Ltd.	IPP	8*18.5+1*9.5	150			