

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 956467, 9551095

Month June, 2022		Day : Saturday		Date : 25.06.22										
Probable Maximum Demand : 13500 MW		Yesterday = 88.10 ft		Today = 88.66 ft										
Water Level of Kaptai Lake at 06:00 AM		Rule Curve = 82.38 ft												
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.22 (Yesterday)		25.06.22 (Today)		24.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation			Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Under maint.			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	84	84						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0		105	Under maint.			
6	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0			Contract Expired			
7	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	450	450						
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling			
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	409	411	412						
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0		105	105			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	331	335						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	225	305	305						
14	Madanganj-55 MW PP (Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55						
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	50	55						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.07+6x7.13	80	80	33	46	51						
18	Maona 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33						
19	Rugganji 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	25			25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	16	50			50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	105			105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	96	150			150			
23	Kamaphuli 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54			54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	288	285			285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	79	115	135			135			
26	Karangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200			300			
27	Bramanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100			100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	25			100			
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55			55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55			55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	93	104			104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	42	162	162			162			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	22	0	30			0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55			55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	99	100			100			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	42	88	89			89			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0			0			
Dhaka Zone Total			6004	5847	2248	3250	3782	3946	105	1130				
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	121	126	126		104	Low water level			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100		80	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0						
41	Racganj 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25			25			
42	Teknaf 20MW PP (Sartech)	Solar (IPP)	1x20	20	20	12	0	20			0			
43	Paterga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	24	37	44			44			
44	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	71	105	105			105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0		150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0		225	Awaiting for HGPI			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	135	265			300			
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	90	90			90			
49	Dohazari - Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0			51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	48	0			51			
51	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22			22			
*	Malanha, Ctg,EPZ (Unite)	Gas	5x8.73+3x9.34			8	36	10			30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	80			92			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	34			54			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110			110			
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	35	85	100			100			
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	30	30	54			54			
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	90	82	90			90			
Chattogram Zone Total			2442	2382	668	1102	1280	1444	184	555				
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	0	0	0	0			Contract Expired			
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0		134	Gas Shortage			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	15	15	15			15			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	208	205	215			215			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	340	300			340			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	345	300			350			
	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)				292	0	0			0			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	48	50	50			50			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	150	177	177		18	Gas Shortage			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51			51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	26	123	140			150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	45			45			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	136	135			135			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	179	150			200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19			19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11			11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	33	33			33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0			0			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	20			20			
75	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	89x1.4+40x1.05+15x1.05	200	200	0	0	100			200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0			0			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	95	50			95			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35			35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	45	116	115			115			
**	Import (Tripura)	India		160	160	116	140	143			165			
Cumilla Zone Total			3059	2885	1843	2090	2059	2421	152	0				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	170	187	160		15	Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20			20			
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	8	111	110			110			
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	88	200	180			200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6			0			
85	Sutkhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50			0			
86	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	23	24	22			22			
Mymensingh Zone Total			622	614	357	542	544	522	15	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.22 (Yesterday)		25.06.22 (Today)		24.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening						
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	GT-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	1x92.90	51	51	33	34	34	34					
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST Under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	30	30	30					
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	84	84					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	120	120	120	120					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	300	310	341					
100	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	404	400	400					
101	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	396	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	25	25	25					
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	30	30	30	30					
Sylhet Zone Total					2522	2477	1642	1655	1666	1697	0	557		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	385	400	400	400					
107	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	42					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
109	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 159+1x75	230	230	0	0	0	220					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100					
111	Rupsaha 105 MW PP (Orion rupsaha)	HFO (IPP)	6x18.445	105	105	0	90	93	93					
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	70	89					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	9	0	100	0					
114	Khulna 115 MW PP (KPCL-2)	Gas (NENP)	7x17	115	115	48	110	110	110					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40					
**	Bheramara (HVDC)	India		1000	1000	924	921	940	940					
Khulna Zone Total					2388	2384	1374	1561	1753	2094	0	0		
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	28	20	25					
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x98	194	194	85	84	87	87					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	510	622	622					
120	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	35	35					
121	Bhola 220MW CAPP (Nutan Bidyut BC	Gas/HSD (IPP)	2x75+1x70	220	220	225	222	220	220					
Barishal Zone Total					1958	1958	667	877	1000	1005	0	0		
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	34					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	200					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	90					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	32					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	34					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38					
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	176	213	180	210					
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	178	210	200	210					
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	60	113	75	113					
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	94	94	94					
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total					2129	2129	899	1115	1134	1502	381	0		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage		
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	32	94	70	100					
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
145	Majpara, Taula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	3	0	8	0					
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	109	108	108					
Rangpur Zone Total					800	720	244	378	361	408	184	85		
Sub-total: Plants in operation					21924	21396	9942.0	12570	13579	15039	1021	2327		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9621	12164	13140	14553						
(B) Plants under long term maintenance contract expired														
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired		
148	Kalptoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired		
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
150	Karriganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired		
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance contract expired					424	0	0	0	0	0	0	0		
Gross Total					22348	21396	9942	12570	13579	15039	1021	2327		
(C) Actual data of 24.06.22 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)				12570	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)				12164	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)				12804	MW, at = 23:00 hrs	Dhaka	4241	4241	0	Mymensingh	1037	1037	0
04.	Minimum Generation (Generation end)				9272	MW, at = 9:00 hrs	Chattoagram	1202	1202	0	Sylhet	435	435	0
05.	Day-peak Generation (Generation end)				9942	MW, at = 12:00 hrs	Khulna	1515	1515	0	Barishal	355	355	0
06.	Evening-peak Generation (Generation end)				12570	MW, at = 21:00 hrs	Rajshahi	1368	1368	0	Rangpur	837	837	0
07.	Evening Peak Load-shed (Sub-station end)				0	MW, at = 21:00 hrs	Cumilla	1174	1174	0				
08.	Minimum Generation Forecast up to 8:00 hrs.				9902	MW, at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation				733	MW								
	d) Coal supply Limitation				184	MW								
	b) Low water level in Kaptai lake				104	MW								
	c) Plants under shut down/ maintenance				2327	MW								
10.	Total Energy (Generation + India Import)				266.10	MKWh	13.	Fuel cost : (a) Gas = 179067149 Taka (c) Coal = 127485096 Taka (b) Oil = 826255399 Taka Total = 1132817644 Taka						
	By Gas =	157.396	MKWh	By Oil =	63.352	MKWh	14.	Maximum Temperature in Dhaka was : 33.8° C						
	By Coal =	15.923	MKWh	By Hydro =	2.966	MKWh	15.	Export through East-West interconnections :						
	By Solar =	1.137	MKWh											
11.	Total Gas Supplied				1185.59	MMCFD								
(D) Forecast of 25.06.22 (Today) Saturday :														
01.	Maximum Demand				13500	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation				15039	MW (Generation end)	05.	Total Generation : 280.56 MKWh						
03.	Reserve / Shortage				1539	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.5° C						

* Cogline Power; ** Imported Power
 #Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helatur Rahman)
 Deputy Secretary, Generation