

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 30-Jun-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity Unit No. X Capacity	Present Capacity MW	Peak Hour MW	Energy Generated KWH	Remarks
1	Ghorasal Repowered CCGP-Unit-3 (GT)	PDB	1*260	260	0	0	Under maint
2	Ghorasal Repowered CCGP-Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	180	4359600	Machine problem
4	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	280	6606318	Machine problem
5	Ghorasal 76.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	3*34.35	108	71	1598500	Engine problem
7	Harijpur GTTP	SBU_PDB	2*32	20	0	0	Under maint.
8	Harijpur 412 MW CCGP	EGCB	1*273+1*139	412	312	8824830	Gas shortage
9	Harijpur 360MW CCGP(MPL)	IPP	1*235+1*125	360	236	8832000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	225	5095850	Gas shortage due to dirty fuel
11	Meghnaghat 100 MW (IEL)	NENP	12*8.9	100	75	1743360	Engine problem
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	335	130	3181527	FGMO & GT-1 S/D due to gas shortage.
13	Madangan 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
14	Madangan-55 MW PP(Summit)	IPP	3*17.06+1*11.3	55	55	1311347	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narshingdi 22 MW PP (Doreen)	SIPP_REB	8*2.90	22	22	440424	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	GT-2 U/M and gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*9.9	100	100	2011104	
20	Siddhirgonj 335 MW CCGP	EGCB	1*217+1*118	335	0	35545	
21	Gaganaar 102 MW PP (Digital Power)	IPP	12*8.924	102	94	2058480	Engine problem
22	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalajhat 54 MW PP(Banco Energy)	IPP	3*18	54	35	929520	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	2623200	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1291130	
26	Nataganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	373274	Engine problem
27	Bosila 108MW PP(CLC)	IPP	12*9.75+1*3.5	0	0	0	
28	Summit Power,(Madhabdi+Ashulia)	SIPP_REB	3*3.67+4*8.73	80	51	1185180	Engine problem
29	Maona 33 MW PP(Summit)	SIPP_REB	4*8.73	33	33	801300	
30	Rupganj 33 MW PP(Summit)	SIPP_REB	4*8.73	33	15	414000	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	50	981120	#REF!
32	Tongi 80 MW GTTP	PDB	1*105	0	105	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	275	5655489	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	203	2716427	
35	Bramhangonj 100 MW PP (Aggreko)	IPP	114*0.959	100	85	758261	Engine problem
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	81	1233720	Engine problem
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	133	2313940	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2345076	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.976	104	94	2093760	Engine problem
40	Manikganj 162MW PP(MPGL)	IPP	8*18	162	162	1935360	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	84014	
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	55	1314000	
Dhaka area Total				5847	3399	73347656	
43	Chattoagram TPP-1	PDB	1*210	180	100	2400000	Machine problem
44	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage
45	Razzar 25 MW PP	RPCL	3*9.9	25	25	534254	
46	Teknaf 20MW PP (Solartech)	IPP	20	20	0	66015	
47	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	44	832320	Engine problem
48	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	125	2949502	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	2542534	
52	Hathazari 100 MW peaking PP	PDB	11*8.9	98	52	304272	Engine problem
53	Dohazari-Kalaish 100 MW Peaking	PDB	6*17	102	51	282028	Fuel shortage
54	Julda 100 MW Unit-1 (Accom)	NENP	8*13.45	100	20	510960	Engine problem
55	Julda 100 MW PP Unit-3 (Accom)	IPP	8*13.5	100	76	1810560	Engine problem
56	Barakkunda 22 MW PP (Regent)	SIPP_PDB	8*2.90	22	21	448560	
57	Matanaha CCGP (United)	IPP	5*8.73+9.34	50	28	553480	
58	Chattoagram 108 MW PP (ECVP)	IPP	16*7	108	92	1744320	Engine problem
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	24961	
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	288	5000618	
61	Jodiach Power	IPP	3*18.55+1*3.6	54	54	1368550	
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	108	2361054	
63	Julda unit-2 (Accom)	IPP	8*13.6	100	77	1349760	Engine problem
64	Anima Energy Ltd.	IPP	6*21.2	116	90	2169109	Engine problem
Chattoagram area Total				2382	1356	27251657	
65	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	209	4669000	#REF!
69	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	270	7009800	Gas shortage
70	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	300	4777000	Gas shortage
71	Ashuganj 420 MW CCGP(East)	APSCCL	284*1+136*1	0	0	1722700	On test.
72	Ashuganj 50 MW PP	APSCCL	14*3.968	45	33	478872	Gas shortage
73	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	50	296640	Gas shortage
74	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	8	150545	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1132374	
76	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	147	3245090	
77	Titas 50 MW Peaking PP	PDB	6*8.92	52	49	825880	Engine problem
78	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	123	2831270	Machine problem
79	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	2902560	
80	Feni 22MW PP (Doreen)	SIPP_PDB	8*2.90	22	22	500940	
81	Feni 11 MW PP (Doreen)	SIPP_REB	4*2.90	11	11	227520	
82	Impgrt (Tripura)	Imported power		0	146	3082880	
83	Jangalia 33MW PP (Summit)	SIPP_PDB	4*8.73	33	33	640600	
84	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	0	0	Fuel shortage
85	Cumilla 25 MW PP (Summit)	SIPP_REB	3*3.67+2*6.97	25	20	502240	Engine problem
86	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	150	1946304	low demand
87	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Fuel shortage
88	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	68	1535320	Engine problem
89	Bharati 54.5 MW	IPP	3*18.2	54	35	889620	33 kV feeder problem.
90	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	116	2644000	
Cumilla Area Total				2885	2069	42038055	
91	RPCL 210MW CCGP	IPP	4*35+1*70	202	105	2064000	Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP_PDB	8*2.90	22	22	490392	
93	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8900	
95	Mymensingh 200 MW PP (United)	IPP	9*78*12	200	177	3024000	Engine problem
96	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	98	1519200	Engine problem
97	Sutiakhali 50 MW Solar PP	IPP	50	50	0	109250	
98	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	520800	
Mymensingh Area Total				614	424	7736542	
99	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	44	1033000	Machine problem
100	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	970726	Machine problem
101	Kushkhara 183 MW CCGP (KP)	IPP	1*109+1*54	163	110	2664654	ST Under maint.
102	Shajibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
103	Fenchugonj 51 MW PP (Barakatalah)	RPP	19*2.90	51	22	661800	Gas shortage
104	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	35	816408	Gas shortage
105	Hobiganj 11MW PP (Confidence-E)	SIPP_REB	4*2.90	11	11	219920	
106	Shajibazar GTTP Unit-8 & 9	PDB	2*35	66	63	1385184	
107	Shajibazar 80MW PP (Shajibazar)	RPP	3*2*9.0	84	84	1901760	
108	Shajibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
109	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	120	2892500	ST Under maint.
110	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
111	Sylhet 50MW PP (EPL)	NENP	27*2	50	6	423520	Engine problem
112	Shajhanuli 25 MW PP	SIPP_REB	9*3.4	25	24	527520	
113	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	290	7076500	FGMO
114	Bibiana-III 400 MW CCGP	PDB	400 MW	400	403	9395000	
115	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	244080	
116	Bibiana South 400 MW	PDB	400 MW	383	400	9515700	
Sylhet Area Total				2477	1664	39728274	
117	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
118	Bheramara (HVDC)	Imported power	2*500	1000	860	21334545	
119	Khulna 115 MW (NCPCL-2)	NENP	7*17	115	49	534720	Gas shortage
120	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	34	375360	Engine problem
121	Khulna 225 MW CCGP	NWPGL	1*150+1*75	230	222	9502940	
122	Gopalganj 100 MW Peaking PP	PDB	16*9.98	109	0	9088	Line O/L
123	Bheramara 410 MW CCGP	NWPGL	1*278+1*132	410	160	4233312	Gas shortage
124	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	40	357750	
125	Noapara 100 MW PP (Bangla Trac)	IPP	8*12.4	100	50	491520	
126	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	93	2040960	Engine problem
127	Madhumati 100 MW PP	NWPGL	6*18	105	105	961920	
128	Mongla Orion 100 MW Solar PP	IPP	100	100	0	276480	
129	Khulna 330 MW CCGP (O/L)	BPDB	1*220+1*110	0	0	0	On test.
Khulna Area Total				2384	1612	125645095	
130	Barsail 110 MW PP (Summit)	IPP	7*17.076	110	48	1345056	Line O/L
131	Bhola 33 MW PP (NCPCL)	NENP	1*34.50	40	29	540543	Engine problem
132	Bhola 225 MW CCGP	PDB	2*63+1*68	194	84	2039617	Gas shortage
133	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired