

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation		Energy Generated	Remarks
					MW	MWH		
			Unit No. X Capac	MW	MW	KWH		
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	260				Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0		Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4334400		
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	300	7143118		Machine problem
5	Ghorasal 78.5 MW PP (MAX)	QRPP	240	0	0	0		Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	89	2071045		Engine problem
7	Haripur 615 MW CAPP	SBU_PDB	2152	0	0	0		Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	0	0		Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	282	5108000		Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2160+1150	450	225	4499550		Gas shortage
11	Meghnaghat 100 MW (IEL)	NENP	128.9	100	31	746880		Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	0	0		Gas shortage
13	Madangan-100 MW CAPP (Summit)	NENP	6117	102	0	0		Under maint.
14	Madangan-55 MW PP(Summit)	IPP	317.08+111.3	55	55	1326932		
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0		Contract Expired
16	Narshingdi 22 MW PP (Doreen)	SIPP_REB	82.90	22	22	484812		
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0		Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0		Gas shortage
19	Siddhirgonj 100 MW (Dutch Bangla)	NENP	1218.9	100	8	541085		Engine problem
20	Siddhirgonj 335 MW CAPP	EGCB	1217+118	335	317	5614930		Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	94	1504512		Engine problem
22	Kalpott 52 MW PP (Sinha)	IPP	77.9	0	0	0		Fuel shortage
23	Kamalaghat 54 MW PP (Banco Energy)	IPP	318	54	54	1262160		
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	132	2882880		Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	1314543		
26	Nabatganj 55 MW PP (Southern power)	IPP	319.3	55	55	1312017		
27	Bosila 108MW PP (CLC)	IPP	128.775+113.5	0	0	0		
28	Summit Power (Madhabdi+Ashulia)	SIPP_REB	313.67+48.73	80	52	1211820		Engine problem
29	Maona 33 MW PP (Summit)	SIPP_REB	48.73	33	33	761100		
30	Rupganj 33 MW PP (Summit)	SIPP_REB	48.73	33	30	686100		
31	Gazipur 52 MW PP	RPCL	618.9	52	49	1024320		#REF!
32	Tongi 80 MW GTTP	PDB	11105	105	0	0		Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	248	5718216		Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	2561.4	300	302	3635233		
35	Bramhangonj 100 MW PP (Aggreko)	IPP	1140.959	100	100	1101724		
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	96	279888		
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	139	2943360		Engine problem
38	Gazpur 100 MW PP (Summit)	RPCL	617.5	105	90	2196000		Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.576	104	104	2416320		
40	Manikganj 162MW PP (MPGL)	IPP	918	162	162	3860640		
41	Spectra Solar Plant Ltd.	IPP	35	35	0	260031		
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.43	55	55	1117080		
Dhaka area Total				5847	3359	6708906		
43	Chattoagram TPP-1	PDB	1210	180	100	2300000		Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0		Gas shortage
45	Razzan 25 MW PP	RPCL	319.25	25	25	545320		
46	Teknaf 20MW PP (Solutech)	IPP	20	20	0	88965		
47	Patenga 50MW PP (Baraka)	IPP	818.98	50	44	957600		Engine problem
48	Kaptai Hydro Unit-1,2,3,4,5	PDB	2140+350.5	230	118	2783580		Low water level
49	Sikalbaha 225MW	PDB	11150+1175	225	0	0		HGPI for 30 days.
50	Sikalbaha Peaking GT	PDB	1150	150	0	0		Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	105	2294982		
52	Hathazari 100 MW peaking PP	PDB	1118.9	98	50	1430972		Engine problem
53	Dohazari-Kalaish 100 MW Peaking	PDB	617	102	49	842586		Fuel shortage
54	Judah 100 MW Unit-1 (Acorn)	NENP	813.45	100	55	1302480		Fuel shortage
55	Judah 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	90	2060160		Engine problem
56	Barakunda 22 MW PP (Regent)	SIPP_PDB	92.90	22	21	456624		
57	Madarancha 52 (United)	IPP	578.73+9.34	0	36	593760		
58	Chattoagram 108 MW PP (ECPV)	IPP	167	108	85	1961280		Engine problem
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29160		
60	Anwara 300 MW PP (United)	IPP	1717+24	300	261	4739673		Engine problem
61	Jodiac Power	IPP	318.55+13.6	54	54	1342962		
62	Karnaphuli Power Ltd.	IPP	18.415+6.5	110	110	2006427		
63	Judah unit-2 (Acorn)	IPP	813.6	100	90	2269480		
64	Antima Energy Ltd.	IPP	821.2	116	108	2520382		Engine problem
Chattoagram area Total				2382	1401	3052393		
65	Ashuganj TPP Unit-3	APSCL	11150	0	0	0		Contract Expired
66	Ashuganj TPP Unit-4	APSCL	11150	0	0	0		Contract Expired
67	Ashuganj TPP Unit-5	APSCL	11150	134	0	0		Gas shortage
68	Ashuganj 225 MW CAPP	APSCL	11142+1175	221	205	5003000		#REF!
69	Ashuganj 450 MW CAPP(North)	APSCL	11360	360	345	8160400		Gas shortage
70	Ashuganj 450 MW CAPP(South)	APSCL	11360	360	340	7802000		Gas shortage
71	Ashuganj 420 MW CAPP(East)	APSCL	2841+1361.1	0	0	0		On test.
72	Ashuganj 50 MW PP	APSCL	143.968	45	35	829800		Engine problem
73	Ashuganj 55 MW PP (Precision)	QRPP	154	55	48	1201440		Engine problem
74	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+1116	195	92	1859727		Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	119.34	51	51	1193680		
76	Ashuganj 150MW PP (Midland)	IPP	237.015	150	142	3154763		
77	Tilas 50 MW Peaking PP	PDB	618.92	52	47	785408		
78	Chandpur 150 MW CAPP	PDB	11106+1157	163	84	2001590		Machine problem
79	Chandpur 200MW (Desh energy)	IPP	1218.4	200	200	3207360		
80	Feni 22MW PP (Doreen)	SIPP_PDB	82.90	22	22	445608		
81	Feni 11 MW PP (Doreen)	SIPP_REB	42.90	11	9	239400		Engine problem
82	Import (Tribuna)	Imported power	0	160	164	3437270		
83	Jangalia 33MW PP (Summit)	SIPP_PDB	48.73	33	30	363800		
84	Jangalia 52 MW PP (Lakdhanav)	IPP	618.92	52	34	219941		Fuel shortage
85	Cumilla 25 MW PP (Summit)	SIPP_REB	313.67+218.97	25	20	481990		Engine problem
86	Daudkandi 200 MW PP (B.Trac)	IPP	1541.4	200	195	2659968		
87	Feni Lanka Power	IPP	718.415+19.78	114	114	1048800		
88	Chowmuhani 115 MW PP	IPP	1219.78+23.11	113	113	223440		Fuel shortage
89	Bhairab 54.5 MW	IPP	318.2	54	35	797760		33 KV feeder problem.
90	Chandpur 115(Doreen)	IPP	418.5+222.5	115	95	2390400		Engine problem
Cumilla Area Total				2885	2315	4751795		
91	RPCL 210MW CAPP	IPP	4135+1170	202	102	2208960		Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP_PDB	82.90	22	20	428544		
93	Jamalpur 95 MW PP (Powerpac)	IPP	128.924	0	0	0		Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	113	3	0	15180		
95	Myensingh 200 MW PP (United)	IPP	978+21	200	175	3033600		Engine problem
96	Jamalpur 115 MW PP (United)	IPP	978+12	115	115	1678800		
97	Sutiakhali 50 MW Solar PP	IPP	50	50	0	289770		
98	Tangail Pali Power Gen 22 MW	IPP	476.7	22	7	453360		
Myensingh Area Total				614	419	8108214		
99	Fenchuganj CAPP Phase-1	PDB	2132+1133	70	33	695000		Machine problem
100	Fenchuganj CAPP Phase-2	PDB	2136+1135	90	42	985375		Machine problem
101	Kushira 163 MW CAPP (KP)	IPP	11109+1154	163	75	1827245		ST Under maint.
102	Shajibazar 330 MW CAPP	PDB	3110	330	0	0		Under maint.
103	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90	51	0	0		Gas shortage
104	Fenchuganj 44MW (Energyprima)	NENP	123.3+572	50	0	0		Gas shortage
105	Hobiganj 11MW PP Confidence-E	SIPP_REB	42.90	11	11	241090		
106	Shajibazar 330 MW PP (S & S)	PDB	2135	66	50	1142400		Engine problem
107	Shajibazar 98MW PP (Shajibazar)	RPP	322.90	98	86	1493760		
108	Shajibazar 100 MW GTTP	PDB	11100	100	0	0		Under maint.
109	Sylhet 225 MW CAPP	PDB	11142+1189	231	140	3389930		ST Under maint.
110	Sylhet 20 MW GTTP	PDB	120	20	0	0		Gas shortage
111	Sylhet 50MW PP (EPL)	NENP	272	50	0	0		Gas shortage
112	Shajibazar 22 MW PP	SIPP_REB	319.34	25	0	422040		Under maint.
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	290	7039000		FGMO
114	Bibiana-III 400 MW CAPP	PDB	400 MW	400	404	9457000		
115	Sylhet 10MW PP (Desh)	RPP	61.95	10	0	227340		Engine problem
116	Bibiana South 400 MW	PDB	400 MW	383	394	9384900		
Sylhet Area Total				2477	1525	3650801		
117	Bheramara GTTP Unit-3	PDB	120	16				Reserve.
118	Bheramara GTTP Phase-2	Imported power	2500	1000	483	18282181		
119	Khuila 115 MW (RPCL-2)	NENP	717	115	48	528960		Fuel shortage
120	Fardpur 50 MW Peaking PP	PDB	818.99	54	35	366100		Engine problem
121	Khuila 225 MW CAPP	NWPGCL	11150+1175	230	203	4764017		Engine problem
122	Gopalganj 100 MW Peaking PP	PDB	1618.98	109	66	568880		Engine problem
123	Bheramara 410 MW CAPP	NWPGCL	11278+1132	410	280	6922656		Gas shortage
124	Nospara 40 MW PP (Kharajahan Ali)	NENP	518.5	40	8	183375		Engine problem
125	Nospara 100 MW PP (Bangla Trac)	IPP	701.4	100	92	1368080		
126	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	75	1787040		Engine problem
127	Madhumati 100 MW PP	NWPGCL	618	105	89	2398320		Engine problem
128	Mongla Orion 100 MW Solar PP	IPP	100	100	0	729360		