

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Jul-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP-Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TFP Unit-5	PDB	1*210	190	180	4331250	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	310	741109	Machine problem
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	JPP	3*43.35	108	92	2054318	Engine problem
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1*273+1*139	412	347	1972220	
9	Haripur 360MW CCGP(HPL)	JPP	1*235+1*125	360	323	7789000	Machine problem
10	Meghnaghat 450 MW CCGP(MPL)	JPP	2*150+1*50	450	225	5037000	Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12*8.9	100	82	1925600	Engine problem
12	Meghnaghat CCGP(Summit)	JPP	2*110+1*110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
14	Madanganj-55 MW PP(Summit)	JPP	3*17.08+1*11.3	55	0	486821	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	343584	
17	210 MW Sakibhaganj T1 (Azom)	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	96	1588000	GT-2 under maint
19	Siddhirganj 100 PP(Dutch Bangla)	NENP	12*8.9	100	96	1352640	Engine problem
20	Siddhirganj 335 MW CCGP	EGCB	1*217+1*118	335	332	6767021	
21	Gagnagar 102 MW PP (Digital Pow)	JPP	12*8.924	102	48	1053648	Low demand
22	Kalpoti 52 MW PP (Sinha)	JPP	7*7.9	0	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco Enk)	JPP	3*18	54	17	330480	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	507360	Reserve.
25	Manikganj 55 MW PP (Northern)	JPP	3*19.3	55	35	611496	Fuel shortage
26	Nababganj 55 MW PP (Southern)	JPP	3*19.3	55	35	513257	Engine problem
27	Bosila 108MW PP(IEI)	JPP	12*9.775+1*3.5	0	0	0	
28	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	37	898260	Engine problem
29	Miana 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	782500	
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	24	585500	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	24	418080	#REF!
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	JPP	18*17.076	300	225	3806290	Low demand
34	Keraniganj 300 MW PP (APR)	JPP	256*1.4	300	0	288105	Reserve.
35	Bramhanagar 100 MW PP (Aggre)	JPP	11*40.959	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	JPP	0.85*23+0.95*91	100	0	81723	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	JPP	8*18.45+8*9.7	149	56	1292112	Low demand
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1584000	
39	Meghnaghat 104 MW PP (OPCL)	JPP	18.5*6	104	61	1211520	Low demand
40	Manikganj 162MW PP(MPGL)	JPP	9*18	162	72	776160	Fuel shortage
41	Spectra Solar Plant Ltd.	JPP	35	35	0	238990	
42	Kanchan Purbahal Power Genera	JPP	18.4*3	55	55	1020240	
43	Dhaka area Total			5847	2932	57107854	
44	Chattoagram TFP-1	PDB	1*210	180	100	2300000	Machine problem
45	Chattoagram TFP-2	PDB	1*210	180	0	0	Gas shortage
46	Raozan 25 MW PP	RPCL	3*8.9	25	16	331227	Engine problem
47	Teknaf 20MW PP (SolarTech)	JPP	20	20	0	119070	
48	Patenga 50MW PP (Baraka)	JPP	6*8.58	50	44	1052160	Engine problem
49	Kodda 220 MW PP (1,2,3,4,5)	PDB	2*140+3*50	230	125	2949764	Low water level
50	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
51	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
52	Sikalbaha 105 MW PP (Baraka Sik)	JPP	6*17.5	105	0	520218	Low demand
53	Hathazari 100 MW peaking PP	PDB	1*18.9	98	0	116544	Reserve.
54	Dohazari-Kalash 100 MW Peakin	PDB	6*17	102	51	334395	Fuel shortage
55	Judha 100 MW PP (Azom)	NENP	8*13.45	100	10	469440	Low demand
56	Judha 100 MW PP Unit-3 (Azom)	JPP	8*13.5	100	50	949440	Low demand
57	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	510336	
58	Malancha, Ctg. EPZ (United)	JPP	5*8.73+3*9.34	0	42	1052640	
59	Chattoagram 108 MW PP (ECPV)	JPP	16*7	108	0	352320	Reserve.
60	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35039	
61	Anwara 300 MW PP (United)	JPP	1*171+2*24	300	0	850592	Low demand
62	Jodica Power Ltd.	JPP	3*18.55+1*3.6	54	54	1111527	
63	Karnaphuli Power Ltd.	JPP	18.45*6+6.5	110	110	1845846	
64	Judha unit-2 (Acorn)	JPP	8*13.6	100	90	1935360	Low demand
65	Anlima Energy Ltd.	JPP	6*21.2	116	108	2133982	Engine problem
66	Chattoagram area Total			2382	821	18957890	
67	Ashuganj TFP Unit- 3	APSCL	1*150	0	0	0	Contract Expired
68	Ashuganj TFP Unit- 4	APSCL	1*150	0	0	0	Contract Expired
69	Ashuganj TFP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
70	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	203	4966000	#REF!
71	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	280	7617400	Machine problem
72	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	270	7410000	FGMO
73	Ashuganj 420 MW CCGP(East)	APSCL	284*1+1*36*1	0	0	1859200	On test.
74	Ashuganj 50 MW PP	APSCL	14*3.968	45	31	735984	Engine problem
75	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	48	1187040	Engine problem
76	Ashuganj 195MW PP (APSCL-Una)	JPP	20*9.73+1*16	195	55	669090	Gas shortage
77	Ashuganj 51 MW PP (Midland)	JPP	6*9.34	51	51	1184753	
78	Ashuganj 150MW PP (Midland)	JPP	23*7.015	150	123	2005600	Engine problem
79	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	123640	Engine problem
80	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	136	2471490	Machine problem
81	Chandpur 200MW (Desh energy)	JPP	12*18.4	200	200	3889400	
82	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	411660	
83	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	239580	
84	Impopr (Tripura)	Imported power	0	160	144	3166080	
85	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	773600	
86	Jangalia 52 MW PP (Lakdanav)	JPP	6*8.92	52	34	390182	Engine problem
87	Cumilla 35 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	500000	Engine problem
88	Daudkandi 200 MW PP (B.Trac)	JPP	154*1.4	200	0	56064	Reserve.
89	Feni Lanka Power	JPP	7*18.415+1*9.78	114	114	902880	
90	Chowmuhani 113 MW	JPP	12*9.78+2*3.1	113	75	1228080	Fuel shortage
91	Bhairab 54.5 MW	JPP	3*18.2	54	17	659160	33 kV feeder problem
92	Chandpur 115(Doreen)	JPP	4*18.5+2*22.5	115	72	1095360	Fuel shortage
93	Cumilla Area Total			2885	1937	43542283	
94	RPCCL 198MW CCGP	JPP	4*35+1*70	202	201	4455300	
95	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	475128	
96	Jamalpur 95 MW PP(Powerpac)	JPP	12*8.924	0	0	0	Under maint.
97	Sarishabari 3 MW Solar Plant	JPP	1*3	3	0	15000	
98	Mymensingh 200 MW PP (United)	JPP	9.78*21	200	169	2733600	Engine problem
99	Jamalpur 115 MW PP (United)	JPP	9.78*12	115	115	165800	
100	Sultankhal 50 MW Solar PP	JPP	50	50	0	390970	
101	Tangail Pali Power Gen 22 MW	JPP	4*8.7	22	24	350880	
102	Mymensingh Area Total			614	531	8586738	
103	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	33	772000	Machine problem
104	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	989152	Machine problem
105	Kushlira 163 MW CCGP (KP)	JPP	1*109+1*54	163	110	2615727	ST Under maint.
106	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
107	Fenchugonj 51 MW PP (Barakatu)	RPP	19*2.90	51	0	0	Gas shortage
108	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	0	0	Gas shortage
109	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	204912	
110	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	60	1257312	Engine problem
111	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	84	1175040	
112	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.
113	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	140	3371830	ST Under maint.
114	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
115	Sylhet 50MW PP (EPL)	NENP	2*7.2	50	0	0	Gas shortage
116	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	192560	Gas shortage
117	Bibiana-II 341 MW CCGP (Summit)	JPP	1*222+1*119	341	285	6913500	FGMO
118	Bibiana-III 400 MW CCGP	PDB	400 MW	400	403	9314000	
119	Sylhet 100MW PP (Desh)	RPP	6*1.95	10	8	193980	
120	Bibiana South 400 MW	PDB	400 MW	383	396	8188990	
121	Sylhet Area Total			2477	1580	38188613	
122	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
123	Bheramara (HVDC)	Imported power	2*500	1000	493	11893090	
124	KPhulla 115 PP MW (KPCL-2)	NENP	7*17	115	48	525120	Fuel shortage
125	Faridpur 50 MW Peaking PP	PDB	6*8.89	54	30	260160	Engine problem
126	Bhola 225 MW CCGP	NWPGCL	1*150+1*75	230	0	1763520	Reserve.
127	Gopalganj 100 MW Peaking PP	NENP	10*8.9	100	20	248916	Low demand
128	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	400	9023904	
129	Noapara 40 MW PP (Khanjahan A)	NENP	5*8.5	40	8	82875	Fuel shortage
130	Noapara 100 MW PP (Bangla Tra	JPP	70*1.4	100	12	307200	Engine problem
131	Rupsha 105 MW PP (Orion rupsha	JPP	6*18.445	105	70	1070880	Low demand
132	Madhumati 100 MW PP	NWPGCL	6*18	105	105	1860048	
133	Mona Chon 100 MW Solar PP	JPP	100	0	0	719280	
134	KPhulla 330 MW CCGP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
135	KPhulla Area Total			2384	1186	27752093	
136	Barisal 110 MW PP (Summit)	JPP	7*17.076	110	32	361820	Line O/L
137	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	32	632043	Engine problem
138	Bhola 225 MW CCGP	PDB	2*63+1*68	194	85	2098217	Gas shortage
139	Bhola 95 MW PP (Aggreko)	QRPP	96*1.0	0	0	0	Contract Expired
140	Payra 200 MW PP (Summit)	BPCL	2*622	1244	520	12497000	Line O/L
141	Bhola Nutan Biddui BD LTD	JPP	220	220	224	5091573	
142	United Payra Power Ltd.	JPP	8*18.5+1*9.5	150	0	26400	Line O/L
143	Barisal Area Total			1958	893	20697053	
144	Baghabari 71 MW GTTP	PDB	1*71	71	0	120000	Gas shortage
145	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
146	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	136376	Reserve.
147	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	851439	
148	Amnura 50 MW PP(Sinha)	QRPP	7*7.9	0	0	0	Contract Expired
149	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	8	165904	Low demand
150	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	118678	Reserve.
151	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	210	5188127	
152	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	209	4165519	
153	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	208	5098455	
154	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	410	9131418	FGMO
155	Santahar 50 MW Peaking PP	PDB	6*8.7	50	29	297554	Engine problem
156	Bogra 22 MW PP (GBB)	RPP	6*4	22	20	470880	