

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	160	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	260	0	0	Under maint.
3	Ghorasal TFP Unit-1	PDB	1210	160	188	4340790	
3	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	300	6935745	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	343.35	108	93	2067909	Engine problem
5	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1273+1139	412	415	9791490	
6	Haripur 365MW CCGP(HPL)	IPP	1235+1125	360	332	7470000	Machine problem
6	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	280	6425800	Gas shortage
9	Meghnaghat 100 MW(IEL)	NENP	128.9	100	79	1855690	Engine problem
10	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
11	Madanganj 102 PPI(Summit)	NENP	617	102	0	0	Under maint.
12	Madanganj-55 MW PPI(Summit)	IPP	317.08+111.3	55	40	618756	Engine problem
13	Karaniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired
14	Narsingdi 22 MW (Doreen)	SIPP, REB	872.96	22	15	341244	Engine problem
15	210 MW Siddhirganj TFP	PDB	1210	115	0	0	Under maint.
16	Siddhirganj 210 MW GTTP	EGCB	2105	210	185	3921000	FGMO
17	Siddhirganj 100 PPI(Dutch Bangla)	NENP	128.9	100	72	1349760	Engine problem
18	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	335	7438203	
19	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	74	1393920	Low demand
20	Katpodi 52 MW PP (Sinha)	IPP	171.9	0	0	0	Fuel shortage
21	Karnalghat 54 MW PP(Banco Energy)	IPP	318	54	0	132840	Reserve.
22	Kodda 150MW PP	BPDB-RPCL	917.06	149	32	742560	Transformer O/L
23	Manikganj 55 MW PP (Northern)	IPP	319.3	55	35	607773	Fuel shortage
24	Nababganj 55 MW PP (Southern power)	IPP	319.3	55	35	515807	Engine problem
25	Bosila 108MW PPI(CLC)	IPP	128.975+113.5	0	0	0	
26	Summit Power Mahabadi-Ashulia	SIPP, REB	33.67+418.73	60	36	825180	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP, REB	48.73	33	25	587916	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	48.73	33	24	627400	Engine problem
29	Gazipur 52 MW PP	RPCL	68.9	52	50	828480	#REF!
30	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	275	4134980	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	2581.4	300	0	0	Reserve.
33	Brambarangan 100 MW PP (Aggreko)	IPP	1140.959	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	147	2001600	
36	Gazipur 100 MW PP	RPCL	617.5	105	105	2194800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	104	1752000	
38	Manikganj 162MW PPI(MPL)	IPP	918	162	54	578680	Low demand
39	Spectra Solar Plant Ltd.	IPP	35	35	35	168601	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.43	55	55	1134720	
<b>Dhaka area Total</b>			<b>5847</b>	<b>3377</b>	<b>70783744</b>		
41	Chattogram TFP-1	PDB	1210	180	100	2300000	Machine problem
42	Chattogram TFP-2	PDB	1210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	38.9	25	20	377569	
43	Teknaf 20MW PP (Solarteck)	IPP	20	20	0	129465	
44	Palenga 50MW PP (Bakatel)	IPP	918.98	50	44	987360	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	240+350	230	119	2869722	Low water level
46	Sikalbaha 225MW	PDB	1150+1175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	0	249235	Reserve.
49	Hathazari 100 MW peaking PP	PDB	1118.9	98	60	361840	Fuel shortage
50	Dahazari 100 MW Peaking	PDB	817	102	34	207521	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	813.45	100	10	559680	Low demand
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	90	1194240	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	21	508800	
54	Malancha, Ctg. EPZ (United)	IPP	578.73+39.34	0	42	1024800	
54	Chattogram 108 MW PP (ECPV)	IPP	167	108	0	103680	Reserve.
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	33240	
56	Anwasa 300 MW PP (United)	IPP	1717.24	300	0	60218	Reserve.
57	Jodiac Power	IPP	318.55+13.6	54	54	1091258	
58	Karnaphuli Power Ltd.	IPP	18.415+6+6.5	110	110	2357709	
59	Juidah unit-2 (Acorn)	IPP	813.6	100	77	2045760	
60	Anilma Energy Ltd.	IPP	621.2	116	108	2223055	Engine problem
<b>Chattogram area Total</b>			<b>2382</b>	<b>894</b>	<b>18685152</b>		
61	Ashuganj TFP Unit-3	APSCL	1150	0	0	0	Contract Expired
61	Ashuganj TFP Unit-4	APSCL	1150	0	0	0	Contract Expired
61	Ashuganj TFP Unit-5	APSCL	1150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCGP	APSCL	1142+1175	221	210	4569000	#REF!
63	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	280	7601100	Gas shortage
64	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	265	6625000	FGMO
64	Ashuganj 420 MW CCGP(East)	APSCL	2841+136*1	0	0	1423400	On test.
65	Ashuganj 50 MW CCGP	APSCL	143.968	45	32	752332	Engine problem
66	Ashuganj 55 MW PP (Precision)	QRPP	154	55	49	1166400	Machine problem
67	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+116	195	8	719272	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	1149815	
69	Ashuganj 150MW PP (Midland)	IPP	237.015	150	130	2731563	Engine problem
70	Titas 50 MW Peaking PP	PDB	68.92	52	49	111952	
71	Chandpur 100 MW CCGP	PDB	1110+1157	163	136	3230540	Machine problem
72	Chandpur 200MW Dash energy)	IPP	1218.4	200	200	2988480	
73	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	501768	
74	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	10	235980	
**	Imoport (Tripura)	Imported power	0	160	76	2622720	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	802000	
76	Jangalia 52 MW PP (Lakshmana)	IPP	618.92	52	43	426696	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	313.67+26.97	25	20	515060	Engine problem
78	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	0	Reserve.
79	Feni Lanka Power	IPP	718.415+19.78	114	70	705660	High Voltage
80	Chowmuhani 113 MW	IPP	129.78+23.1	113	113	955920	
81	Bhairab 54.5 MW	IPP	318.2	54	17	432720	33 KV feeder proble
82	Chandpur 115(Doreen)	IPP	418.5+22.5	115	53	1061760	Fuel shortage
<b>Cumilla Area Total</b>			<b>2885</b>	<b>1667</b>	<b>43228611</b>		
83	RPCL 210MW CCGP	IPP	4135+170	202	141	4428560	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	22	463500	
85	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	13	3	0	13600	
87	Mymensingh 200 MW PP (United)	IPP	978.21	200	168	3081600	Engine problem
88	Jamalpur 115 MW PP (United)	IPP	978.21	115	106	1695600	Engine problem
89	Sultkhali 50 MW Solar PP	IPP	50	50	0	343730	
90	Tangail Pali Power Gen 22 MW	IPP	46.7	22	24	446640	
<b>Mymensingh Area Total</b>			<b>614</b>	<b>461</b>	<b>10471230</b>		
91	Fenchuganj CCGP Phase-1	PDB	2132+133	70	33	775000	Machine problem
92	Fenchuganj CCGP Phase-2	PDB	2135+135	90	42	983368	Machine problem
93	Kushnara 163 MW CCGP (KP)	IPP	11109+154	163	110	2628900	ST Under maint.
94	Shahjibazar 33 MW CCGP	PDB	3110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakattallah)	IPP	192.90	51	0	600	Gas shortage
95	Fenchuganj 44MW (Energyprima)	NENP	123.3+52	50	0	11400	Gas shortage
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	227952	
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2135	66	61	1365504	Engine problem
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	84	1982400	
99	Shahjibazar 100 MW GTTP	PDB	11160	100	0	0	Under maint.
100	Sylhet 225 MW CCGP	PDB	1142+1199	221	140	3351400	ST Under maint.
101	Sylhet 20 MW GTTP	PDB	120	20	0	0	Gas shortage
101	Sylhet 50MW PP (EPL)	NENP	272	50	0	0	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	8	192112	Gas shortage
103	Bibiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	0	795130	Gas shortage
104	Bibiana-III 400 MW CCGP	PDB	400 MW	400	401	3672000	
105	Sylhet 10MW PP (Desh)	RPP	611.95	10	10	236340	
106	Bibiyana South 400 MW	PDB	400 MW	383	220	1963900	
<b>Sylhet Area Total</b>			<b>2477</b>	<b>1120</b>	<b>18186006</b>		
**	Bheramara HVDC	Imported power	2500	1000	493	11938181	
107	Bheramara GTPP Unit-3	PDB	120	16	0	0	Reserve.
108	Khulna 115 PP MW (KPCL-2)	NENP	717	115	49	512640	Fuel shortage
109	Faidpur 50 MW Peaking PP	PDB	618.89	54	42	270720	Engine problem
110	Khulna 225 MW CCGP	NWPGL	1150+1175	230	0	0	Reserve.
111	Gopalganj 100 MW Peaking PP	PDB	166.98	109	0	90752	Reserve.
112	Bheramara 410 MW CCGP	NWPGL	1278+1132	410	355	8676288	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	58.5	40	8	37500	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Reserve.
114	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	75	688520	Engine problem
115	Madhumati 100 MW PP	NWPGL	618	105	85	1181856	Low demand
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	716400	
116	Khulna 330 MW CCGP (OIL)	BPDB	1220+1110	0	0	0	On test.
<b>Khulna Area Total</b>			<b>2384</b>	<b>1107</b>	<b>24118657</b>		
117	Barisal 110 MW PP (Summit)	IPP	717.076	110	110	1311360	
118	Bhola 33 MW PP (Venture)	NENP	134.50	40	31	634552	Engine problem
119	Bhola 225 MW CCGP	PDB	2633+168	194	0	1673250	Gas shortage
120	Bhola 95 MW PP	QRPP	967.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2622	1244	622	15039300	Line O/L
122	Bhola Nutan Biddut BD LTD	IPP	220	220	220	5166218	
123	United Payra Power Ltd.	IPP	818.5+19.5	150	134	1134000	Machine problem
<b>Barisal Area Total</b>			<b>1958</b>	<b>1117</b>	<b>24958680</b>		
124	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
124	Baghabari 100 MW GTTP	PDB	1100	100	100	889000	
125	Baghabari 50 MW Peaking PP	PDB	618.9	52	34	324944	Engine problem
126	Bera 70 MW Peaking PP	PDB	98.29	71	30	195500	Engine problem
127	Amnura 50 MW PP(Sinha)	QRPP	77.79	0	0	0	Contract Expired
128	Katakhal 50 MW PP (Northern)	QRPP	68.9	50	8	243552	High Voltage
129	Katakhal 50 MW Peaking PP	PDB	68.9	50	32	275419	Engine problem
130	Sirajganj Unit-1 225MW	NWPGL	1150+1175	210	40	3375473	Start up process
131	Sirajganj Unit-2 225MW	NWPGL	1150+1175	220	189	4261755	
132	Sirajganj Unit-3 225MW	NWPGL	1141	220	194	4668918	Gas shortage
133	Sirajganj 400 MW CCGP Unit-4	NWPGL	1282+1132	414	414	9127236	
134	Santahar 50 MW Peaking PP	PDB	68.7	50	29	307000	Engine problem
135	Bogra 22 MW PP (GBB)	RPP	64	22	22	481680	
136	Bogra 20 MW PP (Energyprima)	NENP	53.3+52	0	0	0	
137	Uliapara 11 MW PP (Summit)	SIPP, REB	42.90	11	11	240210	
138	Natore 52 MW PP (Rajkanta)	IPP	68.92	52	52	412776	
139	Chapainawabganj 100 MW Peaking PP	PDB					