

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 16-Jul-22

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | | Remarks |
|------------------------------|---|----------------|---------------------|------------------|----------------------|------------------|-----|-----------------------|
| | | | | | | MW | KWH | |
| | | | Unit No. X Capacity | MW | MW | | | |
| 1 | Ghorasal Repowered CCPP-Unit-3 (GT) | PDB | 1'260 | 260 | 0 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCPP Unit-4 | PDB | 1'210 | 180 | 0 | 0 | 0 | Under maint. |
| 3 | Ghorasal TPP Unit-1 | PDB | 1'210 | 180 | 190 | 4347000 | 0 | Machine problem |
| 3 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1'243+1'122 | 365 | 300 | 7221864 | 0 | Machine problem |
| 4 | Ghorasal 78.5 MW PP(MAX) | ORPP | 2'40 | 0 | 0 | 0 | 0 | Contract Expired |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34'3.35 | 108 | 89 | 1939318 | 0 | Engine problem |
| 5 | Haripur GTPP | SBU, PDB | 2'32 | 20 | 0 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CCPP | EGCB | 1'273+1'139 | 412 | 398 | 9897980 | 0 | Machine problem |
| 7 | Haripur 360 MW CCPP(HPL) | IPP | 1'235+1'125 | 360 | 324 | 8870000 | 0 | Machine problem |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2'150+1'150 | 450 | 450 | 9497900 | 0 | Machine problem |
| 9 | Meghnaghat 100 MW(IELE) | NENP | 1'28.9 | 100 | 80 | 1753920 | 0 | Engine problem |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2'110+1'110 | 335 | 0 | 0 | 0 | Gas shortage |
| 11 | Madanganj 102 PP(Summit) | NENP | 6'17 | 102 | 0 | 0 | 0 | Under maint. |
| 12 | Madanganj 55 MW PP(Summit) | IPP | 3'17.08+1'111.3 | 55 | 55 | 923105 | 0 | Under maint. |
| 13 | Keraniganj 100 MW PP (Powerpac) | GRPP | 8'13.45 | 0 | 0 | 0 | 0 | Contract Expired |
| 14 | Narsingh 22 MW PP (Doreen) | SIPP, REB | 8'22.30 | 22 | 0 | 0 | 0 | Engine problem |
| 15 | 210 MW Siddhirganj TTP | PDB | 1'210 | 115 | 0 | 0 | 0 | Under maint. |
| 16 | Siddhirganj 2'120 MW GTPP | EGCB | 2'105 | 210 | 0 | 0 | 0 | Gas shortage |
| 17 | Siddhirganj 100 PP(Dutch Bangla) | NENP | 12'8.9 | 100 | 98 | 1742256 | 0 | Gas shortage |
| 18 | Siddhirganj 335 MW CCPP | EGCB | 1'217+1'118 | 335 | 335 | 7569721 | 0 | Machine problem |
| 19 | Gagnagar 102 MW PP (Digital Power) | IPP | 12'8.924 | 102 | 93 | 1710720 | 0 | Engine problem |
| 20 | Katpott 52 MW PP (Sinha) | IPP | 7'17.9 | 52 | 0 | 0 | 0 | Fuel shortage |
| 21 | Karnalaghat 54 MW PP(Banco Energy) | IPP | 3'18 | 54 | 35 | 340200 | 0 | Engine problem |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9'17.06 | 149 | 132 | 1883040 | 0 | High Voltage |
| 23 | Maniganj 55 MW PP (Northern) | IPP | 3'19.3 | 55 | 55 | 298707 | 0 | Under maint. |
| 24 | Nababganj 55 MW PP (Southern power) | IPP | 3'19.3 | 55 | 55 | 513979 | 0 | Under maint. |
| 25 | Bosila 108MW PP(OLC) | IPP | 12'8.75+1'3.5 | 0 | 0 | 0 | 0 | Under maint. |
| 26 | Summit Power (Madhabadi-Ashulia) | SIPP, REB | 33.67+1'173 | 80 | 48 | 977820 | 0 | Engine problem |
| 27 | Masona 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 25 | 592600 | 0 | Engine problem |
| 28 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 33 | 746700 | 0 | Engine problem |
| 29 | Gazipur 52 MW PP | RPCL | 6'9.9 | 52 | 49 | 762720 | 0 | #REF! |
| 30 | Tongi 80 MW GTPP | PDB | 1'105 | 105 | 0 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18'17.076 | 300 | 273 | 4649344 | 0 | Engine problem |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 250'1.4 | 300 | 0 | 0 | 0 | Reserve. |
| 33 | Bramanganj 100 MW PP (Aggreko) | IPP | 1'140.959 | 100 | 0 | 0 | 0 | Reserve. |
| 34 | Aurahat 100MW PP (Aggreko) | IPP | 0.85'23+0.95'91 | 100 | 0 | 0 | 0 | Reserve. |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8'18.45+8.97 | 149 | 122 | 2667168 | 0 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 6'17.5 | 105 | 105 | 2404800 | 0 | Under maint. |
| 37 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5'6 | 104 | 104 | 1901760 | 0 | Engine problem |
| 38 | Maniganj 162MW PP(MFPL) | IPP | 9'18 | 162 | 162 | 712800 | 0 | Engine problem |
| 39 | Spectra Solar Plant Ltd | IPP | 35 | 35 | 35 | 237661 | 0 | Under maint. |
| 40 | Kanchan Purbachal Power Generation Ltd. | IPP | 18'4.3 | 55 | 55 | 1297440 | 0 | Under maint. |
| Dhaka area Total | | | | 5847 | 3653 | 76307443 | | |
| 41 | Chattogram TPP-1 | PDB | 1'210 | 180 | 100 | 2400000 | 0 | Machine problem |
| 42 | Chattogram TPP-2 | PDB | 1'210 | 180 | 0 | 0 | 0 | Gas shortage |
| 42 | Raizan 25 MW PP | RPCL | 3'8.25 | 25 | 25 | 469409 | 0 | Under maint. |
| 43 | Teknaf 250MW PP (Solartech) | IPP | 20 | 20 | 0 | 119880 | 0 | Under maint. |
| 44 | Patenga 50MW PP (Baraka) | IPP | 8'9.98 | 50 | 37 | 833880 | 0 | Engine problem |
| 45 | Kaptai Hydro Unit-1,2,3,4, 5 | PDB | 2'40+3'50 | 230 | 124 | 2728800 | 0 | Low water level |
| 46 | Sikalbaha 225MW | PDB | 1'150+1'175 | 225 | 0 | 0 | 0 | HGPI for 30 days. |
| 47 | Sikalbaha Peaking GT | PDB | 1'150 | 150 | 0 | 0 | 0 | Under maint. |
| 48 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6'17.5 | 105 | 70 | 994436 | 0 | Low demand |
| 49 | Hathazari 100 MW peaking PP | PDB | 1'18.9 | 98 | 51 | 471288 | 0 | Fuel shortage |
| 50 | Dhazari-Kalash 100 MW Peaking | PDB | 8'17 | 102 | 51 | 482245 | 0 | Fuel shortage |
| 51 | Juidah 100 MW Unit-1 (Acorn) | NENP | 8'13.45 | 100 | 55 | 760320 | 0 | Engine problem |
| 52 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 8'13.5 | 100 | 90 | 1252800 | 0 | Engine problem |
| 53 | Barakunda 22 MW PP (Regent) | SIPP, PDB | 8'2.90 | 22 | 21 | 462048 | 0 | Under maint. |
| * | Malancha, Ctg. EPZ (United) | IPP | 5'8.73+3'9.34 | 0 | 32 | 534240 | 0 | Under maint. |
| 54 | Chattogram 108 MW PP (ECPV) | IPP | 16'7 | 108 | 80 | 834240 | 0 | Engine problem |
| 55 | Kaptai 7 MW Solar PP | PDB | 7.4 | 7 | 0 | 39840 | 0 | Under maint. |
| 56 | Arwara 300 MW PP (United) | IPP | 17'17+24 | 300 | 50 | 1038764 | 0 | Low demand |
| 57 | Jodac Power | IPP | 3'18.55+1'3.6 | 54 | 54 | 1002850 | 0 | Under maint. |
| 58 | Karnaphuli Power Ltd. | IPP | 18.415+6+6.5 | 110 | 110 | 2564279 | 0 | Under maint. |
| 59 | Juidah unit-2 (Acorn) | IPP | 8'13.6 | 100 | 100 | 2233920 | 0 | Under maint. |
| 60 | Anilma Energy Ltd. | IPP | 6'21.2 | 116 | 108 | 2541709 | 0 | Engine problem |
| Chattogram area Total | | | | 2382 | 1158 | 21752948 | | |
| 61 | Ashuganj TPP Unit-3 | APSCL | 1'150 | 0 | 0 | 0 | 0 | Contract Expired |
| 61 | Ashuganj TPP Unit-4 | APSCL | 1'150 | 0 | 0 | 0 | 0 | Contract Expired |
| 61 | Ashuganj TPP Unit-5 | APSCL | 1'150 | 134 | 0 | 0 | 0 | Gas shortage |
| 62 | Ashuganj 225 MW CCPP | APSCL | 1'142+1'175 | 221 | 206 | 3745000 | 0 | #REF! |
| 63 | Ashuganj 450 MW CCPP(North) | APSCL | 1'360 | 360 | 285 | 7702800 | 0 | Gas shortage |
| 64 | Ashuganj 450 MW CCPP(South) | APSCL | 1'360 | 360 | 265 | 7224000 | 0 | FGMO |
| 65 | Ashuganj 420 MW CCPP(East) | APSCL | 284'1+36'1 | 0 | 0 | 0 | 0 | On test. |
| 65 | Ashuganj 50 MW PP | APSCL | 14'3.368 | 45 | 38 | 787104 | 0 | Engine problem |
| 66 | Ashuganj 55 MW PP (Precision) | ORPP | 15'4 | 55 | 44 | 1093920 | 0 | Engine problem |
| 67 | Ashuganj 195MW PP (APSCL-United) | IPP | 20'9.73+1'116 | 195 | 155 | 4248727 | 0 | Engine problem |
| 68 | Ashuganj 51 MW PP (Midland) | IPP | 6'9.34 | 51 | 51 | 1118251 | 0 | Under maint. |
| 69 | Ashuganj 150MW PP (Midland) | IPP | 23'7.015 | 150 | 10 | 1493745 | 0 | Low demand |
| 70 | Tras 50 MW Peaking PP | PDB | 6'8.92 | 52 | 47 | 740754 | 0 | Engine problem |
| 71 | Chandpur 150 MW CCPP | PDB | 1'108+1'157 | 163 | 84 | 2003810 | 0 | Machine problem |
| 72 | Chandpur 200MW (Dash energy) | IPP | 12'18.4 | 200 | 200 | 3474240 | 0 | Machine problem |
| 73 | Feni 22MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 22 | 503820 | 0 | Under maint. |
| 74 | Feni 11 MW PP (Doreen) | SIPP, REB | 4'2.90 | 11 | 10 | 195120 | 0 | Under maint. |
| ** | Impoprt (Tripura) | Imported power | 0 | 160 | 80 | 1695360 | 0 | Under maint. |
| 75 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4'8.73 | 33 | 33 | 810900 | 0 | Under maint. |
| 76 | Jangalia 52 MW PP (Lakshminaw) | IPP | 8'9.92 | 52 | 8 | 207336 | 0 | Engine problem |
| 77 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3'3.67+2'6.97 | 25 | 14 | 506380 | 0 | Engine problem |
| 78 | Daudkandi 200 MW PP (B.Trac) | IPP | 154'1.4 | 200 | 0 | 0 | 0 | Reserve. |
| 79 | Feni Lanka Power | IPP | 7'18.415+1'9.78 | 114 | 114 | 835620 | 0 | Under maint. |
| 80 | Chowmahani 113 MW | IPP | 12'9.78+2'3.1 | 113 | 111 | 979440 | 0 | Under maint. |
| 81 | Bhairab 54.5 MW | IPP | 3'18.2 | 54 | 35 | 879840 | 0 | 33 kV feeder problem. |
| 82 | Chandpur 115(Doreen) | IPP | 4'18.5+2'2.5 | 115 | 95 | 2225280 | 0 | Engine problem |
| Cumilla Area Total | | | | 2888 | 1908 | 42476277 | | |
| 83 | RPCL 210MW CCPP | IPP | 4'35+1'70 | 202 | 131 | 4055040 | 0 | Gas shortage |
| 84 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 19 | 327024 | 0 | Under maint. |
| 85 | Jamalpur 95 MW PP(Powerpac) | IPP | 12'8.924 | 0 | 0 | 0 | 0 | Under maint. |
| 86 | Sarishabari 3 MW Solar Plant | IPP | 1'3 | 3 | 0 | 15650 | 0 | Under maint. |
| 87 | Mymensingh 200 MW PP (United) | IPP | 9'78'21 | 200 | 167 | 3057600 | 0 | Engine problem |
| 88 | Jamalpur 152MW PP (United) | IPP | 9'78'12 | 115 | 105 | 1675400 | 0 | Engine problem |
| 89 | Sultajhat 50 MW Solar PP | IPP | 50 | 50 | 0 | 395500 | 0 | Under maint. |
| 90 | Tangail Pali Power Gen 22 MW | IPP | 4'6.7 | 22 | 15 | 522720 | 0 | Engine problem |
| Mymensingh Area Total | | | | 614 | 437 | 10047984 | | |
| 91 | Fenchugonj CCPP Phase-1 | PDB | 2'32+1'33 | 70 | 42 | 1024000 | 0 | Machine problem |
| 92 | Fenchugonj CCPP Phase-2 | PDB | 2'35+1'35 | 90 | 42 | 973096 | 0 | Machine problem |
| 93 | Kushibari 163 MW CCPP (KP) | IPP | 1'109+1'54 | 163 | 80 | 1990963 | 0 | ST Under maint. |
| 94 | Shahbazar 330 MW CCPP | PDB | 3'110 | 330 | 0 | 0 | 0 | Under maint. |
| 95 | Fenchugonj 51 MW PP (Barakatullah) | RPP | 19'2.90 | 51 | 0 | 708000 | 0 | Gas shortage |
| 96 | Fenchugonj 44MW (Energytoma) | NENP | 12'3.3+5'2 | 50 | 0 | 670752 | 0 | Gas shortage |
| 96 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4'2.90 | 11 | 5 | 196800 | 0 | Gas shortage |
| 97 | Shahbazar GTPP Unit- 8 & 9 | PDB | 2'35 | 66 | 59 | 1347072 | 0 | Engine problem |
| 98 | Shahbazar 96MW PP (Shahbazar) | RPP | 32'2.90 | 86 | 81 | 1747200 | 0 | Under maint. |
| 99 | Shahbazar 100 MW GTPP | PDB | 1'100 | 100 | 0 | 0 | 0 | Under maint. |
| 100 | Sylhet 225 MW CCPP | PDB | 1'142+1'139 | 231 | 219 | 5182010 | 0 | Gas shortage |
| 101 | Sylhet 20 MW GTPP | PDB | 1'20 | 20 | 0 | 0 | 0 | Gas shortage |
| 102 | Sylhet 50MW PP (EPL) | NENP | 27'2 | 50 | 0 | 328600 | 0 | Engine problem |
| 102 | Shahjahanulla 25 MW PP | SIPP, REB | 3'9.34 | 25 | 8 | 450662 | 0 | Gas shortage |
| 103 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1'222+1'119 | 341 | 260 | 3281220 | 0 | FGMO |
| 104 | Bibiana-III 400 MW CCPP | PDB | 400 MW | 400 | 404 | 9493000 | 0 | Under maint. |
| 105 | Sylhet 10MW PP (Desh) | RPP | 6'11.95 | 10 | 10 | 231840 | 0 | Under maint. |
| 106 | Bibiana South 400 MW | PDB | 400 MW | 383 | 398 | 9334400 | 0 | Under maint. |
| Sylhet Area Total | | | | 2477 | 1608 | 36924895 | | |
| ** | Bheramara GTPP Unit-3 | PDB | 1'20 | 16 | 0 | 0 | 0 | Reserve. |
| ** | Bheramara (HVDC) | Imported power | 2'500 | 1000 | 863 | 21502545 | 0 | Under maint. |
| 108 | Khulna 115 PP MW (KPCL-2) | NENP | 7'17 | 115 | 80 | 736320 | 0 | Engine problem |
| 109 | Fardpur 50 MW Peaking PP | PDB | 6'9.89 | 54 | 38 | 204000 | 0 | Reserve. |
| 110 | Khulna 225 MW CCPP | NWPGCL | 1'150+1'175 | 230 | 0 | 0 | 0 | Reserve. |
| 111 | Gopalganj 100 MW Peaking PP | PDB | 16'6.98 | 109 | 30 | 157568 | 0 | Line O/L |
| 112 | Bheramara 410 MW CCPP | NWPGCL | 1'278+1'132 | 410 | 355 | 8651232 | 0 | FGMO |
| | | | | | | | | |