

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	PDB	1210	190	180	4315500	
4	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Machine problem
5	Ghorasal 108MW PP (Regent)	IPP	343.35	108	89	2083590	Contract Expired
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Engine problem
7	Haripur 412 MW CAPP	EGCB	1273+1139	412	288	6815740	Gas shortage
8	Haripur 365 MW CAPP(HPL)	IPP	1235+1125	365	196	4120000	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	170	3685500	Gas shortage & GT-2 Si/D.
10	Meghnaghat 100 MW(LEL)	NENP	1218.9	100	40	956160	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6117	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	317.08+111.3	55	40	1175085	Engine problem
14	Keraniganj 100 MW PP (Powerpac)	ORPP	813.45	0	0	0	Contract Expired
15	Narsingdi 22 MW (Doreen)	SIPP, REB	82.90	22	22	348192	
16	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
17	Siddhirganj 2120 MW GTPP	EGCB	2105	210	0	0	Gas shortage
18	Siddhirganj 100 PP(Dutch Bangla)	NENP	1218.9	100	32	771283	Engine problem
19	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	0	0	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12.8.924	102	93	2211264	Engine problem
21	Katpali 52 MW PP (Sinha)	IPP	171.9	0	0	0	Fuel shortage
22	Karnalghat 54 MW PP(Banco Energy)	IPP	318	54	17	634320	Engine problem
23	Kodda 150MW PP	BPDB-RPCL	917.06	149	125	2870400	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	272699	
25	Nababganj 55 MW PP (Southern power)	IPP	319.3	55	35	325044	
26	Bosila 108MW PP(CCLC)	IPP	12.8.775+13.5	0	0	0	
27	Summit 300 MW PP (Madhatra-Ashulia)	SIPP, REB	33.67+418.73	80	50	1121480	Engine problem
28	Mazona 33 MW PP(Summit)	SIPP, REB	418.73	33	25	541500	Engine problem
29	Rugganj 33 MW PP(Summit)	SIPP, REB	418.73	33	28	709800	Engine problem
30	Gazipur 52 MW PP	RPCL	618.9	52	50	1087200	#REF!
31	Tongi 80 MW GTPP	PDB	1105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	255	6220034	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	2581.4	300	0	755974	
34	Brambaraganj 100 MW PP (Aggreko)	IPP	1140.959	100	0	542709	
35	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	259966	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	149	3561552	
37	Gazipur 100 MW PP	RPCL	617.5	105	105	2467200	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.516	104	104	2480640	
39	Manikganj 162MW PP(MPGL)	IPP	918	162	17	1956990	Engine problem
40	Spectra Solar Plant Ltd	IPP	35	35	0	152779	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.43	55	55	1341000	
Dhaka area Total				5847	2522	60789596	
41	Chattoagram TPP-1	PDB	1210	180	100	2400000	Machine problem
42	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	318.9	25	25	605914	
44	Taknai 25 MW PP (Sclartech)	IPP	20	20	0	91935	
45	Palena 50MW PP (Banco)	IPP	818.98	50	38	715200	Engine problem
46	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2140+3150	230	123	2968851	Low water level
47	Sikalbaha 225MW	PDB	1150+1175	225	0	0	HGPI for 30 days.
48	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	105	2507418	
50	Hathazari 100 MW peaking PP	PDB	1118.9	98	42	689290	Fuel shortage
51	Hathazari 100 MW Peaking	PDB	817	102	61	704488	Fuel shortage
52	Juidah 100 MW Unit-1 (Acorn)	NENP	813.45	100	33	771000	Engine problem
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	90	2035200	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	19	440448	
55	Malancha, Ctg. EPZ (United)	IPP	578.73+319.34	0	30	446400	
56	Chattoagram 108 MW PP (ECBPV)	IPP	167	108	85	1954560	Engine problem
57	Kaptai 7 MW Solar PP	PDB	7.4	7	0	29278	
58	Anwara 300 MW PP (United)	IPP	1712.24	300	285	6331164	Engine problem
59	Jodis Power	IPP	318.55+113.6	54	36	907910	Engine problem
60	Karnaphuli Power Ltd.	IPP	18.415+6+5.5	110	92	2546716	Engine problem
61	Juidah unit-2 (Acorn)	IPP	813.6	100	77	1610880	
62	Anilma Energy Ltd.	IPP	621.2	116	108	2527909	Engine problem
Chattoagram area Total				2382	1349	30481202	
61	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCL	1142+1175	221	208	3885000	#REF!
65	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	300	7323400	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	290	6701000	
67	Ashuganj 420 MW CAPP(East)	APSCL	2841+1361	0	0	0	On test.
68	Ashuganj 50 MW PP	APSCL	143.968	45	10	568872	Engine problem
69	Ashuganj 55 MW PP (Precision)	ORPP	154	55	5	324480	Engine problem
70	Ashuganj 195MW PP (APSCL-United)	IPP	2019.73+116	195	8	200727	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	619.34	51	51	1135588	
72	Ashuganj 150MW PP (Midland)	IPP	2317.015	150	130	3082836	Engine problem
73	Titas 50 MW Peaking PP	PDB	618.92	52	45	80180	
74	Chandpur 150 MW CAPP	PDB	11163	163	0	0	Machine problem
75	Chandpur 200MW (Dash energy)	IPP	1218.4	200	200	3965760	
76	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	19	448740	
77	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	10	238320	
78	Imported (Tripura)	Imported power	0	160	128	2247360	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	418.73	33	25	586400	Engine problem
80	Jangalia 51 MW PP (Lakshana)	IPP	618.92	52	8	209083	Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	313.67+216.97	25	20	530960	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	655296	
83	Feni Lanka Power	IPP	718.415+119.78	114	0	0	Fuel shortage
84	Chowmuhani 113 MW	IPP	1219.78+21.3	113	18	281400	Fuel shortage
85	Bhairab 54.5 MW	IPP	318.2	54	35	855720	33 kV feeder problem.
86	Chandpur 115(Doreen)	IPP	418.5+22.5	115	35	1549440	Fuel shortage
Cumilla Area Total				2868	1548	3552190	
87	RPCL 210MW CAPP	IPP	4135+170	202	106	2447040	Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	22	357048	
89	Jamalpur 95 MW PP(Powerpac)	IPP	1218.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1.3	3	0	15550	
91	Mymensingh 200 MW PP (United)	IPP	918.21	200	180	3012000	Engine problem
92	Jamalpur 115 MW PP (United)	IPP	918.21	115	104	1576000	Engine problem
93	Sultajhat 50 MW Solar PP	IPP	50	50	0	264800	
94	Tangail Pali Power Gen 22 MW	IPP	416.7	22	16	470400	
Mymensingh Area Total				614	428	8144838	
95	Fenchuganj CAPP Phase-1	PDB	2132+133	70	43	748000	Machine problem
96	Fenchuganj CAPP Phase-2	PDB	2135+135	90	42	958080	Machine problem
97	Kushara 163 MW CAPP (KP)	IPP	11109+1154	163	0	0	Gas shortage
98	Shahjibazar 33 MW CAPP	PDB	3110	330	0	0	Under maint.
99	Fenchuganj 51 MW PP (Barakattullah)	RPP	192.90	51	0	0	Gas shortage
100	Fenchuganj 44MW (Energyprima)	NENP	1213.3+512	50	0	0	Gas shortage
101	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	0	0	Gas shortage
102	Shahjibazar GTPP Unit- 8 & 9	PDB	2135	66	62	1411776	Engine problem
103	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	25	888960	Gas shortage
104	Shahjibazar 100 MW GTPP	PDB	1160	100	0	0	Under maint.
105	Sylhet 225 MW CAPP	PDB	1142+1199	231	220	5246730	
106	Sylhet 20 MW GTPP	PDB	1120	20	0	0	Gas shortage
107	Sylhet 50MW PP (EPL)	NENP	272	50	0	0	Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	319.34	25	8	162576	Gas shortage
109	Bibiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	310	7483000	FGMO
110	Bibiana-III 400 MW CAPP	PDB	400	400	404	946600	
111	Sylhet 10MW PP (Desh)	RPP	811.95	10	10	237060	
112	Bibiyana South 400 MW	PDB	400	383	396	9274200	
Sylhet Area Total				2477	1520	35876382	
113	Bheramara GTPP Unit-3	PDB	120	16	0	0	Reserve.
114	Bheramara (HVDC)	Imported power	2500	1000	857	21265454	
115	Khulna 115 MW PP (KP-2)	NENP	717	115	32	453120	Fuel shortage
116	Faidpur 50 MW Peaking PP	PDB	618.99	54	42	421920	Engine problem
117	Khulna 225 MW CAPP	NWPQCL	1150+1175	230	0	0	Reserve.
118	Gopalganj 100 MW Peaking PP	PDB	1616.98	109	60	644992	Line O/L
119	Bheramara 410 MW CAPP	NWPQCL	1278+1132	410	200	5688992	FGMO & gas shortage.
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	518.5	40	40	946125	
121	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	240000	Engine problem
122	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	93	2069760	Engine problem
123	Madhumati 100 MW PP	NWPQCL	618	105	105	2549376	
124	Mongla Orion 100 MW Solar PP	IPP	100	100	0	468000	
125	Khulna 330 MW CAPP (OIL)	BPDB	1220+1110	0	0	0	On test.
Khulna Area Total				2384	1429	34720539	
126	Barisal 110 MW PP (Summit)	IPP	717.076	110	48	615072	Line O/L
127	Bhola 33 MW PP (Venture)	NENP	134.50	40	31	572566	Engine problem
128	Bhola 225 MW CAPP	PDB	2163+1168	194	82	2048998	Gas shortage
129	Bhola 95 MW PP (Aggreko)	ORPP	981.10	0	0	0	Contract Expired
130	Payra 1320 MW	BCPCL	2162	1244	1060	25294800	FGMO
131	Bhola Nutan Biddut BD LTD	IPP	220	220	220	5120427	
132	United Payra Power Ltd.	IPP	818.5+119.5	150	17	468000	Transformer O/L
Barisal Area Total				1958			