

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9584667, 9551095

Month July 2022		Day : Wednesday				Date : 20.07.22							
Probable Maximum Demand :		14200 MW		Probable Maximum Generation :		12051 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 91.93 ft		Today = 91.31 ft		Rule Curve = 87.04 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.07.22 (Yesterday)		20.07.22 (Today)		19.07.22 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	89	89	89				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Harijpur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	176	198	200	200	162	Gas Shortage		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	190	170	170	170	280	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Harijpur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	283	288	280	280				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	40	55	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	88	93				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.9+1x4.73	80	80	46	50	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	28	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	125	115	130				
23	Kamaphuli 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	255	255	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	148	149	149	149				
26	Karangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Bramanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	35	0	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	17	35	144				
33	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	32	32	32				
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	40	40	40	40				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2579</b>	<b>2522</b>	<b>2479</b>	<b>2718</b>	<b>987</b>	<b>995</b>			
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	126	123	127	127		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0				
43	Patanganj 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	38	38	38				
44	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Shikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	265	285	278	285				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	61	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	42	51	51				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
*	Malanchar, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	30	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	76	85	89	89				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36				
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	92	92	110				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	77	77	50	50				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	31	33	33	33				
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	108	108				
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1213</b>	<b>1349</b>	<b>1322</b>	<b>1337</b>	<b>80</b>	<b>555</b>			
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0		Contract Expired		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	10	10	10				
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	150	208	210	210				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	250	290	290	290	70	Gas Shortage		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	300	300	300	300	60	Gas Shortage		
	Ashuganj 420 MW CCGP(East)	Gas (APSCL)				0	0	0	0	300	Gas Shortage		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	295	Gas Shortage		
64	Ashuganj 198MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187	Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	130	135	130				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	45	41	45				
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	120	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	25	25	25				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.40x1.015+19x1.058	200	200	0	0	0	0				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	18	8	8				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	76	35	54	75				
**	Impoport (Tripura)	India		160	160	66	128	60	79				
<b>Cumilla Zone Total</b>			<b>3059</b>	<b>2855</b>	<b>1306</b>	<b>1545</b>	<b>1409</b>	<b>1528</b>	<b>1046</b>	<b>163</b>			
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	105	106	105	105	96	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	104	60	105				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	180	116					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.07.22 (Yesterday)		20.07.22 (Today)		19.07.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	43	43		27	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatalullah)	Gas (RPP)	19x2.90	51	51	0	0	0	51		Gas Shortage		
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	109	54	ST under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11	Gas Shortage		
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	64	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	25	25	25				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas shortage	
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	290	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	404	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	398	396	360	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
<b>Sylhet Zone Total</b>					<b>2522</b>	<b>2477</b>	<b>1518</b>	<b>1520</b>	<b>1462</b>	<b>1510</b>	<b>308</b>	<b>559</b>	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	245	200	225	225	210		Gas Shortage	
107	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	0	42				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	55	60				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
111	Rupaha 105 MW PP (Orion rupaha)	HFO (IPP)	6x18.445	105	105	93	93	93	93				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	40	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	32	32				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	40	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	908	857	890	875				
<b>Khulna Zone Total</b>					<b>2388</b>	<b>2384</b>	<b>1447</b>	<b>1429</b>	<b>1540</b>	<b>1472</b>	<b>210</b>	<b>0</b>	
116	Bansail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	48				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	31	26	30				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	82	82	82	112		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1060	1100	1100				
120	Putakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
121	Bhola 220MW CCPP (Nutan Bidyut B)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220				
<b>Barishal Zone Total</b>					<b>1958</b>	<b>1958</b>	<b>1221</b>	<b>1458</b>	<b>1461</b>	<b>1497</b>	<b>112</b>	<b>0</b>	
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24	34				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	22	16	22				
126	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	85	85	85				
127	Katakahi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
128	Katakahi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	22	28				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	154	127	154	154	83		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	147	142	142	145	78		Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	325	360	360	89		Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	55	95	75	95				
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	94	113				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>914</b>	<b>1078</b>	<b>1085</b>	<b>1143</b>	<b>570</b>	<b>0</b>	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200				
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	79	103	68	103				
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Tabula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	2	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	109	108	109	109				
<b>Rangpur Zone Total</b>					<b>800</b>	<b>720</b>	<b>390</b>	<b>410</b>	<b>385</b>	<b>412</b>	<b>85</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>21924</b>	<b>21396</b>	<b>10923.0</b>	<b>11739</b>	<b>11520</b>	<b>12051</b>	<b>3494</b>	<b>2357</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>12548</b>	<b>11100</b>	<b>13233</b>	<b>13844</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>													
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
148	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
149	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				
<b>Gross Total</b>					<b>22348</b>	<b>21396</b>	<b>10923</b>	<b>11739</b>	<b>11520</b>	<b>12051</b>	<b>3494</b>	<b>2357</b>	
<b>(C) Actual data of 19.07.22 (Yesterday) Tuesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 14124 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 13485 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 12616 MW, at = 2:00 hrs											
04.	Minimum Generation (Generation end)	: 10633 MW, at = 8:00 hrs											
05.	Day-peak Generation (Generation end)	: 10923 MW, at = 10:00 hrs											
06.	Evening-peak Generation (Generation end)	: 11739 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 2385 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11182 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 3409 MW											
b)	Coal supply Limitation	: 85 MW											
c)	Low water level in Kaptai lake	: 0 MW											
d)	Plants under shut down/ maintenance	: 2357 MW											
10.	Total Energy (Generation + India Import)	: 275.23 MKWh											
		By Gas = 124.726 MKWh		By Oil = 92.805 MKWh									
		By Coal = 30.144 MKWh		By Hydro = 2.969 MKWh									
		By Solar= 1.073 MKWh											
11.	Total Gas Supplied	: 928.35 MMCFD											
				12.	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>								
					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
					Dhaka	4801	4038	763	Mymensingh	1082	862	220	
					Chattoagram	1289	1044	245	Sylhet	511	420	91	
					Khulna	1759	1429	330	Barishal	384	384	0	
					Rajshahi	1480	1177	303	Rangpur	857	677	180	
					Cumilla	1322	1069	253					
					<b>Total</b>	<b>13485</b>	<b>11100</b>						
				13.	Fuel cost :	(a) Gas = 139384679 Taka	(c) Coal = 253560532 Taka						
						(b) Oil = 1270375126 Taka	Total = 1663320337 Taka						
				14.	Maximum Temperature in Dhaka was : 34.4° C								
				15.	Export through East-West interconnections :								
					At evening peak-hour		: 10923 MW, at		21:00 hrs				
					Maximum		: 386 MW, at		5:00 hrs				
					Energy		: 0 MKWh						
<b>(D) Forecast of 20.07.22 (Today) Wednesday :</b>													
01.	Maximum Demand	: 14200 MW (Generation end)		04.	Maximum Load-shed : 2085 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 12051 MW (Generation end)		05.	Total Generation : 309.79 MKWh								
03.	Reserve / Shortage	: -2149 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :								