

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|------------------------------|---|----------------|---------------------|-------------|------------------|----------------------|------------------|---------------------------|
| | | | Unit No. X Capacity | MW | | | | |
| 1 | Ghorasal Repowered CAPP Unit-3 (GT) | PDB | 1*260 | 260 | 0 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CAPP Unit-4 | PDB | 1*210 | 180 | 0 | 0 | 0 | Under maint. |
| 3 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1*210 | 190 | 180 | 4378500 | 0 | Machine problem |
| 4 | Ghorasal 78.5 MW PP(MAX) | ORPP | 2*40 | 0 | 0 | 0 | 0 | Contract Expired |
| 5 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 88 | 2039681 | 0 | Engine problem |
| 6 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | 0 | Under maint. |
| 7 | Haripur 412 MW CAPP | EGCB | 1*273+1*139 | 412 | 334 | 8367280 | 0 | Gas shortage |
| 8 | Haripur 365 MW CAPP(HPL) | IPP | 1*236 | 243 | 243 | 6052000 | 0 | Gas shortage |
| 9 | Meghnaghat 450 MW CAPP(MPL) | IPP | 2*150+1*150 | 450 | 225 | 4726000 | 0 | Gas shortage & GT-2 Si/D. |
| 10 | Meghnaghat 100 MW(LEL) | NENP | 12*8.9 | 100 | 30 | 864000 | 0 | Engine problem |
| 11 | Meghnaghat CAPP(Summit) | IPP | 2*110+1*110 | 335 | 0 | 0 | 0 | Gas shortage |
| 12 | Madanganj 102 PP(Summit) | NENP | 6*17 | 102 | 0 | 0 | 0 | Under maint. |
| 13 | Madanganj-55 MW PP(Summit) | IPP | 3*17.08+1*11.3 | 55 | 55 | 1331210 | 0 | Contract Expired |
| 14 | Keraniganj 100 MW PP (Powerpac) | ORPP | 8*13.45 | 0 | 0 | 0 | 0 | Contract Expired |
| 15 | Narsingdi 22 MW (Doreen) | SIPP, REB | 8*2.90 | 22 | 19 | 410194 | 0 | 0 |
| 16 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | 0 | Under maint. |
| 17 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 0 | 0 | 0 | Gas shortage |
| 18 | Siddhirgonj 100 PP(Dutch Bangla) | NENP | 12*8.9 | 100 | 32 | 776141 | 0 | Engine problem |
| 19 | Siddhirgonj 335 MW CAPP | EGCB | 1*217+1*118 | 335 | 0 | 0 | 0 | Gas shortage |
| 20 | Gagnagar 102 MW PP (Digital Power) | IPP | 12*8.924 | 102 | 93 | 2193696 | 0 | Engine problem |
| 21 | Katpott 52 MW PP (Sinha) | IPP | 7*7.9 | 0 | 0 | 0 | 0 | Fuel shortage |
| 22 | Karnalghat 54 MW PP(Banco Energy) | IPP | 3*18 | 54 | 54 | 641880 | 0 | 0 |
| 23 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 132 | 2931840 | 0 | Engine problem |
| 24 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 269921 | 0 | 0 |
| 25 | Nabaganj 55 MW PP (Southern power) | IPP | 3*19.3 | 55 | 35 | 286512 | 0 | Engine problem |
| 26 | Bosila 108MW PP(CCLC) | IPP | 12*8.75+1*3.5 | 0 | 0 | 0 | 0 | 0 |
| 27 | Summit 102 MW PP (Madhatul-Ashulia) | SIPP, REB | 3*3.67+4*8.73 | 80 | 49 | 1177440 | 0 | Engine problem |
| 28 | Mazna 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 620560 | 0 | Engine problem |
| 29 | Rugganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 28 | 691800 | 0 | Engine problem |
| 30 | Gazipur 52 MW PP | RPCL | 6*8.9 | 52 | 50 | 1129440 | 0 | #REF! |
| 31 | Tongi 80 MW GTPP | PDB | 1* 105 | 105 | 0 | 0 | 0 | Under maint. |
| 32 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 275 | 6242616 | 0 | Engine problem |
| 33 | Keraniganj 300 MW PP (APR) | IPP | 258*1.4 | 300 | 0 | 0 | 0 | 0 |
| 34 | Brambaragan 100 MW PP (Aggreko) | IPP | 114*0.959 | 100 | 0 | 0 | 0 | 0 |
| 35 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | 0 | 0 |
| 36 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8*18.45+8.97 | 149 | 149 | 3557376 | 0 | 0 |
| 37 | Gazipur 100 MW PP | RPCL | 6*17.5 | 105 | 105 | 2454000 | 0 | 0 |
| 38 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5*6 | 104 | 104 | 2224000 | 0 | 0 |
| 39 | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 144 | 1652160 | 0 | Engine problem |
| 40 | Spectra Solar Plant Ltd | IPP | 35 | 35 | 35 | 147458 | 0 | 0 |
| 41 | Kanchan Purbachal Power Generation Ltd. | IPP | 18.4*3 | 55 | 55 | 1258560 | 0 | 0 |
| Dhaka area Total | | | | 5847 | 2859 | 6356419 | | |
| 41 | Chattogram TPP-1 | PDB | 1*210 | 180 | 100 | 2400000 | 0 | Machine problem |
| 42 | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage |
| 43 | Razzan 25 MW PP | RPCL | 3*8.9 | 25 | 25 | 591057 | 0 | 0 |
| 44 | Taknat 22 MW PP (Solartech) | IPP | 20 | 20 | 0 | 71260 | 0 | 0 |
| 45 | Patenga 50MW PP (Baraka) | IPP | 9*6.98 | 50 | 38 | 892320 | 0 | Engine problem |
| 46 | Kaptai Hydro. Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 125 | 3005591 | 0 | Low water level |
| 47 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 0 | 0 | 0 | HGPI for 30 days. |
| 48 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | 0 | Under maint. |
| 49 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6*17.5 | 105 | 105 | 2534181 | 0 | 0 |
| 50 | Hathazari 100 MW peaking PP | PDB | 11*9.9 | 98 | 51 | 1053760 | 0 | Fuel shortage |
| 51 | Hathazari 100 MW Peaking | PDB | 8*17 | 102 | 68 | 1292769 | 0 | Fuel shortage |
| 52 | Juidah 100 MW Unit-1 (Acorn) | NENP | 8*13.45 | 100 | 33 | 786360 | 0 | Engine problem |
| 53 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 8*13.5 | 100 | 30 | 1453440 | 0 | Engine problem |
| 54 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 19 | 446208 | 0 | 0 |
| 55 | Malancha, Ctg. EPZ (United) | IPP | 5*8.73+3*9.34 | 0 | 30 | 490560 | 0 | 0 |
| 56 | Chattogram 108 MW PP (ECVP) | IPP | 16*7 | 108 | 90 | 2073600 | 0 | Engine problem |
| 57 | Kaptai 7 MW Solar PP | PDB | 7.4 | 7 | 0 | 15098 | 0 | 0 |
| 58 | Anwara 300 MW PP (United) | IPP | 17*17.24 | 300 | 285 | 5585154 | 0 | Engine problem |
| 59 | Jodid Power | IPP | 3*18.55+1*3.6 | 54 | 36 | 908592 | 0 | Engine problem |
| 60 | Karnaphuli Power Ltd. | IPP | 18.415*6+6.5 | 110 | 92 | 2240608 | 0 | Engine problem |
| 61 | Juidah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 38 | 1065600 | 0 | 0 |
| 62 | Anilma Energy Ltd. | IPP | 6*21.2 | 116 | 108 | 2553000 | 0 | Engine problem |
| Chattogram area Total | | | | 2382 | 1273 | 2843170 | | |
| 61 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 0 | 0 | 0 | 0 | Contract Expired |
| 62 | Ashuganj TPP Unit-4 | APSCL | 1*150 | 0 | 0 | 0 | 0 | Contract Expired |
| 63 | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 0 | 0 | 0 | Gas shortage |
| 64 | Ashuganj 225 MW CAPP | APSCL | 1*142+1*75 | 221 | 208 | 4985000 | 0 | #REF! |
| 65 | Ashuganj 450 MW CAPP(North) | APSCL | 1*360 | 360 | 280 | 7406100 | 0 | Gas shortage |
| 66 | Ashuganj 450 MW CAPP(South) | APSCL | 1*360 | 360 | 280 | 7059000 | 0 | 0 |
| 67 | Ashuganj 420 MW CAPP(East) | APSCL | 284*1+36*1 | 0 | 0 | 0 | 0 | On test. |
| 68 | Ashuganj 50 MW PP | APSCL | 14*3.668 | 45 | 41 | 584856 | 0 | Engine problem |
| 69 | Ashuganj 55 MW PP (Precision) | ORPP | 15*4 | 55 | 5 | 142560 | 0 | Engine problem |
| 70 | Ashuganj 195MW PP (APSCL-United) | IPP | 20*9.73+1*16 | 195 | 8 | 217454 | 0 | Gas shortage |
| 71 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1184321 | 0 | 0 |
| 72 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 140 | 3226690 | 0 | Engine problem |
| 73 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 49 | 1089056 | 0 | 0 |
| 74 | Chandpur 150 MW CAPP | PDB | 1*163 | 163 | 0 | 0 | 0 | Machine problem |
| 75 | Chandpur 200MW (Dash energy) | IPP | 12*18.4 | 200 | 200 | 3502080 | 0 | 0 |
| 76 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 19 | 431208 | 0 | 0 |
| 77 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 10 | 231480 | 0 | 0 |
| 78 | Impoport (Tripura) | Imported power | 0 | 160 | 126 | 2760000 | 0 | 0 |
| 79 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 31 | 602500 | 0 | Engine problem |
| 80 | Jangalia 58 MW PP (Lakshnara) | IPP | 6*9.82 | 52 | 52 | 234744 | 0 | Fuel shortage |
| 81 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3*3.67+2*6.97 | 25 | 20 | 507930 | 0 | Engine problem |
| 82 | Daudkandi 200 MW PP (B. Trac) | IPP | 15*14.4 | 200 | 0 | 0 | 0 | 0 |
| 83 | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 99 | 458280 | 0 | 0 |
| 84 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 56 | 477960 | 0 | Fuel shortage |
| 85 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 35 | 785880 | 0 | 33 kV feeder problem. |
| 86 | Chandpur 115(Doreen) | IPP | 4*18.5+2*2.5 | 115 | 78 | 1489890 | 0 | Fuel shortage |
| Cumilla area Total | | | | 2868 | 1758 | 37376059 | | |
| 87 | RPCL 210MW CAPP | IPP | 4*35+1*70 | 202 | 106 | 2125440 | 0 | Gas shortage |
| 88 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 14 | 338292 | 0 | 0 |
| 89 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 0 | 0 | 0 | 0 | Under maint. |
| 90 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 9300 | 0 | 0 |
| 91 | Mymensingh 200 MW PP (United) | IPP | 9*78.21 | 200 | 194 | 3388800 | 0 | Engine problem |
| 92 | Jamalpur 115 MW PP (United) | IPP | 9*78.12 | 115 | 104 | 1654900 | 0 | Engine problem |
| 93 | Sultajhat 50 MW Solar PP | IPP | 50 | 50 | 50 | 240560 | 0 | 0 |
| 94 | Tangail Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 22 | 486720 | 0 | 0 |
| Mymensingh Area Total | | | | 614 | 440 | 8243912 | | |
| 95 | Fenchuganj CAPP Phase-1 | PDB | 2*32+1*33 | 70 | 43 | 1024000 | 0 | Machine problem |
| 96 | Fenchuganj CAPP Phase-2 | PDB | 2*35+1*35 | 90 | 42 | 934804 | 0 | Machine problem |
| 97 | Kushara 163 MW CAPP (KP) | IPP | 1*109+1*54 | 163 | 0 | 0 | 0 | Gas shortage |
| 98 | Shahjibazar 33 MW CAPP | PDB | 3*110 | 330 | 0 | 0 | 0 | Under maint. |
| 99 | Fenchuganj 51 MW PP (Barakatullah) | RPP | 19*2.90 | 0 | 0 | 21600 | 0 | Gas shortage |
| 100 | Fenchuganj 44MW (Energyprima) | NENP | 12*3.3+5*2 | 50 | 0 | 21672 | 0 | Gas shortage |
| 101 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 0 | 0 | 0 | Gas shortage |
| 102 | Shahjibazar GTPP Unit- 8 & 9 | PDB | 2*35 | 66 | 60 | 1437560 | 0 | Engine problem |
| 103 | Shahjibazar 86MW PP (Shahjibazar) | RPP | 32*2.90 | 86 | 50 | 816960 | 0 | Gas shortage |
| 104 | Shahjibazar 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | 0 | Under maint. |
| 105 | Sylhet 225 MW CAPP | PDB | 1*142+1*99 | 231 | 220 | 5376650 | 0 | 0 |
| 106 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 0 | 0 | 0 | Gas shortage |
| 107 | Sylhet 50MW PP (EPL) | NENP | 27*2 | 50 | 0 | 0 | 0 | Gas shortage |
| 108 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 8 | 151392 | 0 | Gas shortage |
| 109 | Bibiana-II 341 MW CAPP (Summit) | IPP | 1*222+1*119 | 341 | 300 | 7267500 | 0 | FGMO |
| 110 | Bibiana-III 400 MW CAPP | PDB | 400 MW | 400 | 391 | 9290000 | 0 | 0 |
| 111 | Sylhet 10MW PP (Desh) | RPP | 8*1.25 | 10 | 10 | 238500 | 0 | 0 |
| 112 | Bibiana South 400 MW | PDB | 400 MW | 383 | 380 | 8763200 | 0 | 0 |
| Sylhet Area Total | | | | 2477 | 1504 | 35343838 | | |
| 113 | Bheramara GTPP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | 0 | Reserve. |
| 114 | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 854 | 21275636 | 0 | 0 |
| 115 | Khulna 115 MW PP (KPCL-2) | NENP | 7*17 | 115 | 94 | 1456320 | 0 | Fuel shortage |
| 116 | Faidpur 50 MW Peaking PP | PDB | 6*8.99 | 54 | 44 | 463680 | 0 | Engine problem |
| 117 | Khulna 225 MW CAPP | NWPQCL | 1*150+1*75 | 230 | 0 | 0 | 0 | Reserve. |
| 118 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 63 | 912640 | 0 | Line O/L |
| 119 | Bheramara 410 MW CAPP | NWPQCL | 1*278+1*132 | 410 | 205 | 5086944 | 0 | FGMO & gas shortage. |
| 120 | Noapara 40 MW PP (Khanjahan Ali) | NENP | 5*8.5 | 40 | 40 | 759750 | 0 | 0 |
| 121 | Noapara 100 MW PP (Bangla Trac) | IPP | 70*1.4 | 100 | 0 | 0 | 0 | Engine problem |