

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9586667, 9551095

Month July, 2022		Day: Thursday				Date: 21.07.22									
Probable Maximum Demand: 14200 MW		Probable Maximum Generation: 12570 MW				Rule Curve = 87.20 ft									
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 91.31 ft		Today = 91.20 ft											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.07.22 (Yesterday)		21.07.22 (Today)		20.07.22 (Yesterday) Gen. shortfall for: Gas/Water/Coal limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening						Day	Evening
<b>(A) Plants in operation:</b>															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work			
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	88	89	89						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.			
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Harijpur 380MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	278	243	200	250	117		Gas Shortage			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling			
10	Harijpur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	361	334	300	330						
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	88	93						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.9+7x4.73	80	80	52	49	50	50						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25						
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	132	115	132						
23	Kamapahuli 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	257	275	255	275						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	143	149	149	149						
26	Karangon 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0						
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0						
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	35	0	35						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	89	104	104	104						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	144	35	144						
33	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	24	0	30	0						
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	40	55	55	55						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	32	32	32						
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	40	30	40	40						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0						
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2639</b>	<b>2859</b>	<b>2591</b>	<b>2882</b>	<b>1222</b>	<b>660</b>					
38	Kamapahuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	125	125	125	125			Unit 1 under rehabilitation			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.			
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0						
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0						
43	Paltangan 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	38	38	38						
44	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.			
46	Shikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	177	285	278	285						
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	30	30	30						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	41	51	51	51						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19						
*	Malanche, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			7	30	5	30						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	82	90	90	90						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36						
54	Kamapahuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	92	92	92						
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	38	50	50						
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	33	33	33	33						
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	108	108						
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1174</b>	<b>1273</b>	<b>1261</b>	<b>1285</b>	<b>80</b>	<b>555</b>					
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0			Contract Expired			
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	41	20	40						
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	209	208	210	210						
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	265	280	290	300	80		Gas Shortage			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	280	300	300	80		Gas Shortage			
	Ashuganj 420 MW CCGP(East)	Gas (APSCL)				0	0	0	0	300		Gas Shortage			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	295		Gas Shortage			
64	Ashuganj 198MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187		Gas Shortage			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	133	140	135	140						
67	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	49	41	49						
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	120	200						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10						
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	31	25	31						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	16						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20						
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.915+19x1.958	200	200	0	0	0	0						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	99	0	70						
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	56	8	56						
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	23	35	35	35						
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	76	54	75						
**	Impoport (Tripura)	India		160	160	98	126	120	126						
<b>Cumilla Zone Total</b>			<b>3059</b>	<b>2885</b>	<b>1361</b>	<b>1750</b>	<b>1479</b>	<b>1761</b>	<b>1076</b>	<b>163</b>					
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	83	106	105	110	96		Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	14	22	22						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	104	60	105						
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	194	120	200						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.07.22 (Yesterday)		21.07.22 (Today)		20.07.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					Gas/water/Coal limitation MW
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatalullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109-1x54	163	163	0	0	0	0	109	54	ST under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	60	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	25	50	25	60				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142-1x89	231	231	220	220	220	220				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas shortage	
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8	17		Gas shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	290	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	391	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	380	360	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
<b>Sylhet Zone Total</b>					<b>2522</b>	<b>2477</b>	<b>1482</b>	<b>1504</b>	<b>1460</b>	<b>1545</b>	<b>308</b>	<b>559</b>	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	205	225	225	205		Gas Shortage	
107	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	44				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	55	63	55	60				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	93	93	93	93				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	88	105	105	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	36	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	65	94	32	100				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	878	854	890	875				
<b>Khulna Zone Total</b>					<b>2388</b>	<b>2384</b>	<b>1470</b>	<b>1498</b>	<b>1540</b>	<b>1542</b>	<b>205</b>	<b>0</b>	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	35	32	48				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	26	31				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	82	82	82	112		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	850	1010	1100	1100				
120	Putuakali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	17				
121	Bhola 220MW CCPP (Nutan Bidyut B)	Gas/HSD (IPP)	2x75+1x70	220	220	182	217	220	220				
<b>Barishal Zone Total</b>					<b>1958</b>	<b>1958</b>	<b>1150</b>	<b>1392</b>	<b>1477</b>	<b>1498</b>	<b>112</b>	<b>0</b>	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	25	34	24	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	16	30				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	88	86	85	86				
128	Katakahi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32				
129	Katakahi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	35	22	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	152	142	150	150	68		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	201	0	220	84		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	137	136	140	140	84		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	372	353	360	360	61		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	55	95	75	95				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	88	113	90	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0	85			
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>1176</b>	<b>1366</b>	<b>1075</b>	<b>1185</b>	<b>533</b>	<b>0</b>	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200				
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	79	105	68	105				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tabula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	109	108	100	108				
<b>Rangpur Zone Total</b>					<b>800</b>	<b>720</b>	<b>387</b>	<b>412</b>	<b>376</b>	<b>413</b>	<b>85</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>21924</b>	<b>21396</b>	<b>11155.0</b>	<b>12494</b>	<b>11640</b>	<b>12570</b>	<b>3717</b>	<b>2022</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>11742</b>	<b>11981</b>	<b>12252</b>	<b>13231</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>													
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
148	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
149	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>				
<b>Gross Total</b>					<b>22348</b>	<b>21396</b>	<b>11155</b>	<b>12494</b>	<b>11640</b>	<b>12570</b>	<b>3717</b>	<b>2022</b>	
<b>(C) Actual data of 20.07.22 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13664 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 13151 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 12567 MW, at = 22:00 hrs											
04.	Minimum Generation (Generation end)	: 11054 MW, at = 9:00 hrs											
05.	Day-peak Generation (Generation end)	: 11155 MW, at = 10:00 hrs											
06.	Evening-peak Generation (Generation end)	: 12494 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 1170 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10866 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 3632 MW											
b)	Coal supply Limitation	: 85 MW											
c)	Low water level in Kaptai lake	: 0 MW											
d)	Plants under shut down/ maintenance	: 2022 MW											
10.	Total Energy (Generation + India Import)	: 282.12 MKWh											
	By Gas =	129.085 MKWh											
	By Coal =	30.073 MKWh											
	By Solar =	1.031 MKWh											
11.	Total Gas Supplied	: 954.10 MMCFD											
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	4539	4339	200	Mymensingh	1123	903	220					
	Chattoagram	1234	1234	0	Sylhet	519	444	75					
	Khulna	1700	1550	150	Barishal	374	374	0					
	Rajshahi	1496	1316	180	Rangpur	936	751	185					
	Cumilla	1230	1070	160									
	<b>Total</b>	<b>13151</b>	<b>11981</b>	<b>1170</b>									
13.	Fuel cost :	(a) Gas = 144291554 Taka		(c) Coal = 252865783 Taka									
		(b) Oil = 1299545734 Taka		Total = 1696703071 Taka									
14.	Maximum Temperature in Dhaka was :	31.8° C											
15.	Export through East-West interconnections :												
	At evening peak-hour	: 11155 MW, at 21:00 hrs											
	Maximum Energy	: 438 MW, at 6:00 hrs											
	Energy	: 0 MKWh											
<b>(D) Forecast of 21.07.22 (Today) Thursday :</b>													
01.	Maximum Demand	: 14200 MW (Generation end)											
02.	Maximum Generation	: 12570 MW (Generation end)											
03.	Reserve / Shortage	: -1630 MW (Generation end)											
04.	Maximum Load-shed	: 1365 MW At evening peak (Sub-station end)											
05.	Total Generation	: 318.77 MKWh											
06.	Probable Max. Temperature in Dhaka :												