

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 25-Jul-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	280	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	160	0	0	Under maint.
3	Ghorasal 190 MW CAPP Unit-5	PDB	1210	180	0	4347000	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	0	0	Machine problem
5	Ghorasal 78.5 MW PP(MAX)	GRPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	92	2091954	Engine problem
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	408	9875460	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1'236+1'125	360	360	7558000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	225	5123000	Gas shortage & GT-2 S/D.
11	Meghnaghat 100 MW(IEEL)	NENP	12'8.9	100	8	197760	Fuel shortage
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
14	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1339389	
15	Karaniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW (Doreen)	SIPP, REB	8'7.90	22	0	317828	Engine problem
17	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	8	197654	Fuel shortage
20	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	7	191378	Fuel shortage
22	Katpott 52 MW PP (Sinha)	IPP	7'7.5	0	0	0	Fuel shortage
23	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	17	436320	Fuel shortage
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	133	2519040	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	296967	
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	0	648914	Force S/D
27	Bosila 108MW PP(IEEL)	IPP	12'8.75+1'13.5	0	0	0	
28	Summit Power Plant	SIPP, REB	3'3.67+4'18.73	48	48	1153500	Engine problem
29	Macona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	606960	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	804300	
31	Gazipur 52 MW PP	RPCL	6'8.9	52	51	1108320	#REF!
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	293	6940143	Engine problem
34	Karaniganj 300 MW PP (ARH)	PDB	2581'4	300	0	0	Fuel conservation
35	Bramhanaganj 100 MW PP (Aggreko)	IPP	114'0.959	100	0	0	Fuel conservation
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	125	3029040	Engine problem
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	1899600	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.6	104	17	440640	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	90	774720	Fuel shortage
41	Spectra Solar Plant Ltd	IPP	35	0	0	128225	
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	1287000	
<b>Dhaka area Total</b>				<b>5847</b>	<b>2324</b>	<b>53372910</b>	
43	Chattogram TPP-1	PDB	1'210	180	100	2400000	Machine problem
44	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3'8.9	25	25	596120	
46	Teknaf 25MW PP (Solartech)	IPP	20	20	0	108405	
47	Palenga 50MW PP (Branke)	IPP	8'6.88	50	31	514560	Engine problem
48	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	127	3090780	Low water level
49	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalabaha)	IPP	6'17.5	105	87	2121854	Fuel shortage
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	52	1159624	Engine problem
53	Dahazari 100 MW Peaking	PDB	6'17	100	82	617	Fuel shortage
54	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	258600	Fuel shortage
55	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	11	258240	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	20	468864	
57	Malancha, Clg. EPZ (United)	IPP	5'8.73+3'9.34	0	28	565920	
58	Chattogram 108 MW PP (ECPV)	IPP	18'7	108	12	299520	Fuel shortage
59	Kaptai 7 MW Solar PP	PDB	7.4	7	0	18238	
60	Anwasa 300 MW PP (United)	IPP	17'17+24	300	285	4681864	Engine problem
61	Jodiac Power	IPP	3'18.55+1'3.6	54	36	957995	Engine problem
62	Karnaphuli Power Ltd.	SIPP	18.415'6+6.5	110	72	1942871	Engine problem
63	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	251520	
64	Anilma Energy Ltd.	IPP	6'21.2	116	108	1873036	Engine problem
<b>Chattogram area Total</b>				<b>2382</b>	<b>1065</b>	<b>21950514</b>	
65	Ashuganj TPP Unit-3	APSCCL	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-5	APSCCL	1'150	134	0	0	Gas shortage
68	Ashuganj 225 MW CAPP	APSCCL	1'142+1'175	221	211	4840000	#REF!
69	Ashuganj 450 MW CAPP(North)	APSCCL	1'360	360	280	7389000	Gas shortage
70	Ashuganj 450 MW CAPP(South)	APSCCL	1'360	360	280	6939000	Gas shortage
71	Ashuganj 420 MW CAPP(East)	APSCCL	284'1+386'1	0	0	0	On test.
72	Ashuganj 50 MW PP	APSCCL	14'3.868	45	15	278280	Engine problem
73	Ashuganj 55 MW PP (Precision)	GRPP	15'4	55	5	144960	Gas shortage
74	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73+1'116	195	8	200727	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1248403	
76	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	127	3106254	Engine problem
77	Titas 50 MW Peaking PP	PDB	6'8.92	52	47	1149624	
78	Chandpur 150 MW CAPP	PDB	11'06+1'157	127	163	2569400	
79	Chandpur 200MW Dash energy	IPP	12'18.4	200	120	1724640	Machine problem
80	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	457488	Fuel shortage
81	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	227880	
82	Imported (Tripura)	Imported power	0	180	152	3425280	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	32	692400	
84	Jangalia 52 MW PP (Lakshana)	IPP	6'18.22	52	43	368428	Engine problem
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	518140	
86	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0	Fuel conservation
87	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	906300	
88	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	89	809760	Engine problem
89	Bhairab 54.5 MW	IPP	3'18.2	54	35	889200	33 kV feeder problem.
90	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	95	1510080	Engine problem
<b>Cumilla Area Total</b>				<b>2885</b>	<b>1689</b>	<b>38390645</b>	
91	RPCL 210MW CAPP	IPP	4'35+1'70	202	106	2422090	Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	364032	
93	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11800	
95	Mymensingh 200 MW PP (Unite)	IPP	9'78.21	200	200	4562400	
96	Jamalpur 115 MW PP (Unite)	IPP	9'78.21	115	63	1154400	Engine problem
97	Sultajhal 50 MW Solar PP	IPP	50	0	0	183310	Fuel conservation
98	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	24	575280	
<b>Mymensingh Area Total</b>				<b>614</b>	<b>433</b>	<b>9273302</b>	
99	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	43	1023000	Machine problem
100	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	42	970728	Machine problem
101	Kushaura 163 MW CAPP (KP)	IPP	1'108+1'54	163	0	0	Gas shortage
102	Shahjibazar 33 MW CAPP	PDB	3'110	330	0	0	Under maint.
103	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	8	198900	Gas shortage
104	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	5	142344	Gas shortage
105	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	Gas shortage
106	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	55	1343136	Engine problem
107	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	50	528000	gas shortage
108	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
109	Sylhet 225 MW CAPP	PDB	1'142+1'189	231	220	5371210	
110	Sylhet 20 MW GTTP	PDB	1'20	20	0	0	Gas shortage
111	Sylhet 50MW PP (EPL)	NENP	27'2	50	6	175320	Gas shortage
112	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	184848	Gas shortage
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	260	7172500	FGMO
114	Biyayana-II 400 MW CAPP	PDB	400 MW	400	390	9356000	
115	Sylhet 10MW PP (Dash)	RPP	6'18.5	10	10	235260	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	314640	
117	Khulna 330 MW CAPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
<b>Khulna Area Total</b>				<b>2384</b>	<b>1371</b>	<b>31918247</b>	
118	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	609792	Line OIL
119	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	27	508900	Engine problem
120	Bhola 225 MW CAPP	PDB	2'63+1'88	194	65	1331000	Under maint.
121	Bhola 95 MW PP (Aggreko)	GRPP	96'11.0	0	0	0	Contract Expired
122	Payra 1320 MW	BCPCL	2'822	1244	1030	24539400	Line OIL
123	Bhola Nutan Biddut BD LTD	IPP	220	220	225	5013791	
124	Unite Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line OIL
<b>Barisal Area Total</b>				<b>1958</b>	<b>1379</b>	<b>32002883</b>	
125	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
126	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
127	Baghabari 50 MW Peaking PP	PDB	6'8.9	50	34	374480	Engine problem
128	Bera 70 MW Peaking PP	PDB	9'8.29	71	25	298424	Engine problem
129	Amnara 50 MW PP(Sinha)	GRPP	7'7.79	0	0	0	Contract Expired
130	Katakhal 50 MW PP(Northern)	GRPP	6'8.9	50	34	530928	Engine problem
131	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	32	268554	Engine problem
132	Sirajgonj Unit-1 225MW	NWP/GCL	1'150+1'175	210	145	4088327	Gas shortage
133	Sirajgonj Unit-2 225MW	NWP/GCL	1'150+1'175	220	216	4569300	
134	Sirajgonj Unit-3 225MW	NWP/GCL	1'141	220	125		

