

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551085

Month July, 2022			Day : Tuesday				Date : 26.07.22				
Probable Maximum Demand :			13850 MW		Probable Maximum Generation :				11810 MW		
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 90.99 ft		Today = 91.01 ft				Rule Curve = 88.00 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.07.22 (Yesterday)		26.07.22 (Today)		25.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	92	92	92		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	341	295	300	300	65	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	407	406	400	406		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	7	7	7		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	20	22		
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x4.73	80	80	53	49	49	49		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	25	25	25	25		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	50	51		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	90	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	100	133	130	133		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	293	293	290	295		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	143	125	120	125		
26	Kerangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Aurash 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	0	0	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	90	35	90		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8		
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	7	8	8	8		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2269	2324	2236	2408	1170	1025
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	127	127	127	127		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
40	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	31	30	31		
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	87	85	87		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	177	285	175	285		
49	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	52	51	52		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
53	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			8	28	10	25		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	12	12	12		
55	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	83	72	80	80		
57	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10		
58	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10		
59	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108		
Chattogram Zone Total				2442	2382	901	1065	915	1070	80	555
60	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		
61	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	15	15	15	30	Gas Shortage
62	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	214	211	200	211		
63	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	280	280	280	80	Gas Shortage
64	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	280	280	300	80	Gas Shortage
65	Ashuganj 420 MW CCGP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test
66	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage
67	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+11*16	195	195	8	8	8	8	187	Gas Shortage
68	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
69	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	132	127	130	130		
70	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	48	47	48	48		
71	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	78	127	130	130		
72	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	120	100	120		
73	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
74	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	10	11	11		
75	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	32	33	33		
76	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43		
77	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	20	20		
78	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.024	200	200	0	0	0	0		
79	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+19.78	114	114	17	114	17	114		
80	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	89	8	90		
81	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
82	Chandpur 116MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	95	54	95		
83	** Impoprt (Tiptura)	Inda		160	160	132	152	125	165		
Cumilla Zone Total				3193	3169	1486	1880	1577	1923	427	0
84	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	109	106	108	108	96	Gas Shortage
85	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
86	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	83	40	83		
87	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200		
88	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
89	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	9	0	50	0		
90	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensingh Zone Total				622	614	399	433	442	433	96	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.07.22 (Yesterday)		26.07.22 (Today)		25.07.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32-1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35-1x35	104	90	41	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	8	8	8	8		43	Gas Shortage	
91	Kushara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		109	Gas Shortage	
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	0	0	0	0		11	Gas Shortage	
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	55	55	60				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110-1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	50	10	50		36	Gas shortage	
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	219	220	210	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	8	8	8	8		17	Gas shortage	
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	260	280	280				
101	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	402	390	400	400				
102	Bibiana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6	6		44	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	5	5	5	5		45	Gas Shortage	
Sylhet Zone Total					2522	2477	1502	1497	1477	1532	325	559	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	215	170	200	200		240	Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	66	40	66				
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	105	105	85	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	8	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	33	83	33	83				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	8	40				
**	Bheramara (HVDC)	India		1000	1000	893	848	877	866				
Khulna Zone Total					2388	2384	1279	1371	1360	1417	240	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	27	15	25				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65		129	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	850	1030	910	1100				
121	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				
122	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	182	225	200	220				
Barishal Zone Total					1958	1958	1136	1379	1206	1459	129	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	16	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	16	25				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	88	88	88	88				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
129	Katakhal 50 MW PP (Northern)	HFO (GRPP)	6x8.9	50	50	16	34	25	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	183	145	171	150		65	Gas Shortage	
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	148	216	0	0		220	Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	149	125	150	140		95	Gas Shortage	
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	391	325	330	350		89	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	75	113	75	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	113	70	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2129	2129	1162	1326	1039	1155	640	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	87	106	92	105				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	108	108	108	108				
Rangpur Zone Total					800	720	397	414	408	413	85	85	
Sub-total: Plants in operation					22058	21680	10531.0	11689	10660	11810	3192	2224	
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
151	Keraniganj 100 MW PP (Powerpac)	HFO (GRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
152	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22482	21680	10531	11689	10660	11810	3192	2224	
(C) Actual data of 25.07.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13266	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12843	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	11763	MW, at = 22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10096	MW, at = 7:00 hrs	Dhaka	4571	4168	403	Mymensingh	1103	854	249	
05.	Day-peak Generation (Generation end)	:	10531	MW, at = 9:00 hrs	Chattogram	1156	1156	0	Sylhet	477	416	61	
06.	Evening-peak Generation (Generation end)	:	11689	MW, at = 21:00 hrs	Khulna	1605	1380	225	Barishal	350	350	0	
07.	Evening Peak Load-shed (Sub-station end)	:	1577	MW, at = 21:00 hrs	Rajshahi	1435	1178	257	Rangpur	917	735	182	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10312	MW, at = 5:00 hrs	Cumilla	1229	1029	200					
09.	Generation shortfall at evening peak due to :	:							Total	12843	11266	1577	
	a) Gas limitation	:	3107	MW	13.	Fuel cost :	(a) Gas = 143221786 Taka	(c) Coal = 246898795 Taka					
	d) Coal supply Limitation	:	85	MW		(b) Oil = 1064801840 Taka	Total = 1454922420 Taka						
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2224	MW	14.	Maximum Temperature in Dhaka was :	33.5° C						
10.	Total Energy (Generation + India Import)	:	263.03	MKWh	15.	Export through East-West interconnections :							
	By Gas = 128.188	MKWh	By Oil = 77.014	MKWh		At evening peak-hour	:	10531	MW, at	21:00 hrs			
	By Coal = 29.416	MKWh	By Hydro = 3.091	MKWh		Maximum	:	642	MW, at	21:00 hrs			
	By Solar = 0.818	MKWh				Energy	:	0	MKWh				
11.	Total Gas Supplied	:	957.53	MKWh									
(D) Forecast of 26.07.22 (Today) Tuesday :													
01.	Maximum Demand	:	13850	MW (Generation end)	04.	Maximum Load-shed	:	1879.824102	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11810	MW (Generation end)	05.	Total Generation	:	309.69	MKWh				
03.	Reserve / Shortage	:	-2040	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	33.6° C					

* Coactive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation