

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 26-Jul-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation	Energy Generated	Remarks
				Unit No.	X Capacity			
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260		260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1'210		180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210		190	180	4347000	
3	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122		365	200	1776300	Machine problem
4	Ghorasal 78.5 MW PP (MAX)	ORPP	2'40		0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35		108	85	2024000	Engine problem
5	Harpur GTPP	SBU, PDB	2'32		20	0	0	Under maint.
6	Harpur 412 MW CAPP	EGCB	1'273+1'139		412	407	9893650	Gas shortage
7	Harpur 350 MW CAPP (HPL)	IPP	1'236+1'125		360	360	7722000	Gas shortage
8	Meghnaghat 450 MW CAPP (MPL)	IPP	2'150+1'150		450	225	5154500	Gas shortage & GT-2 S/D.
9	Meghnaghat 100 MW (IEL)	NENP	1'28.9		100	7	197760	Fuel shortage
10	Meghnaghat CAPP (Summit)	IPP	2'110+1'110		335	0	0	Gas shortage
11	Madanganj 102 PP (Summit)	NENP	6'17		102	0	0	Under maint.
12	Madanganj-55 MW PP (Summit)	IPP	3'17.08+1'113.0		55	55	1339764	
13	Karaniganj 100 MW PP (Powerpac)	ORPP	8'13.45		0	0	0	Contract Expired
14	Narsingdi 22 MW (Doreen)	SIPP, REB	8'2.90		22	22	360180	
15	210 MW Siddhirganj TPP	PDB	1'210		115	0	0	Under maint.
16	Siddhirganj 2'120 MW GTPP	EGCB	2'105		210	0	0	Gas shortage
17	Siddhirganj 100 PP (Dutch Bangla)	NENP	12'8.9		100	8	195648	Fuel shortage
18	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118		335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924		102	7	192960	Fuel shortage
20	Katpatti 52 MW PP (Sinha)	IPP	7'7.9		0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP (Banco Energy)	IPP	3'18		54	17	433440	Fuel shortage
22	Kodda 150MW PP	BPDB-RPCL	9'17.06		149	150	2640000	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3		55	55	301518	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3		55	35	253704	Engine problem
25	Bosila 100MW PP (CLC)	IPP	12'8.775+1'33.0		0	0	0	
26	Summit 300 MW PP (APR)	SIPP, REB	33'67+4'8.73		80	53	1164900	Engine problem
27	Macona 33 MW PP (Summit)	SIPP, REB	4'8.73		33	25	539200	Engine problem
28	Rupganj 33 MW PP (Summit)	SIPP, REB	4'8.73		33	30	669900	
29	Gazipur 52 MW PP	RPCL	6'8.9		52	51	1192320	#REF!
30	Tongi 80 MW GTPP	PDB	1'105		105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076		300	240	6225052	Engine problem
32	Karaniganj 300 MW PP (APR)	IPP	258'1.4		300	0	0	Fuel conservation
33	Bramhanganj 100 MW PP (Aggreko)	IPP	114'0.959		100	0	0	Fuel conservation
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91		100	0	0	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97		149	122	2924352	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5		105	105	2520000	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18'5'6		104	17	426240	Fuel shortage
38	Manikganj 162MW PP (MPL)	IPP	9'18		162	90	770400	Fuel shortage
39	Spectra Solar Plant Ltd	IPP	35		35	0	117895	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18'4'3		55	55	1185560	
Dhaka area Total					5847	2541	54621243	
41	Chattogram TPP-1	PDB	1'210		100	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1'210		180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'9.9		25	25	556272	
43	Teknaf 25 MW PP (SolarTech)	IPP	25		20	0	121095	
44	Balenga 50MW PP (Boraka)	IPP	8'6.98		50	28	674400	Engine problem
45	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50		230	127	3008527	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175		225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150		150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5		105	105	2443007	
49	Hafizganj 100 MW peaking PP	PDB	11'8.9		92	51	796368	Engine problem
50	Dohazari 100 MW Peaking	PDB	8'17		102	36	284189	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45		100	10	250920	Fuel shortage
52	Juidah 100 MW Unit-3 (Acorn)	IPP	8'13.5		100	11	250560	Fuel shortage
53	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90		22	19	434304	
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34		0	29	516000	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7		108	87	1102080	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4		7	0	3281	
56	Anwara 300 MW PP (United)	IPP	171'24		300	285	4923545	Engine problem
57	Jodac Power	IPP	3'18.55+1'3.6		54	54	1050765	
58	Karnaphuli Power Ltd.	IPP	18'41.5+6+5		110	105	2264862	Engine problem
59	Juidah unit-2 (Acorn)	IPP	8'13.6		100	10	264000	
60	Anilma Energy Ltd.	IPP	6'21.2		116	108	2108891	Engine problem
Chattogram area Total					2382	1190	23484466	
61	Ashuganj TPP Unit-3	APSCCL	1'150		0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCCL	1'150		0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCCL	1'150		134	0	0	Gas shortage
62	Ashuganj 225 MW CAPP	APSCCL	1'142+1'175		221	212	4781000	#REF!
63	Ashuganj 450 MW CAPP (North)	APSCCL	1'360		310	310	7558900	Gas shortage
64	Ashuganj 450 MW CAPP (South)	APSCCL	1'360		360	305	7185000	FGMO
65	Ashuganj 420 MW CAPP (East)	APSCCL	284'1+136'1		284	0	0	On test.
65	Ashuganj 50 MW PP	APSCCL	14'3.968		45	30	618408	Engine problem
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4		55	5	145920	Gas shortage
67	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73+1'116		195	8	217454	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34		51	51	1246361	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015		150	130	2922254	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92		52	48	790448	
71	Chandpur 100 MW CAPP	PDB	1'163+1'157		163	128	3165030	
72	Chandpur 200MW (Desh energy)	IPP	12'18.4		200	100	3376320	Machine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90		22	19	433836	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90		11	10	233460	
**	Imported (Tripura)	Imported power	0		160	156	3340800	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73		33	33	662200	
76	Jangalia 52 MW PP (Lakshana)	IPP	6'8.92		52	43	364983	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97		25	20	511510	Engine problem
78	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4		200	0	0	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415+1'9.78		114	114	1029420	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1		113	116	1157520	
81	Bhairab 54.5 MW	IPP	3'18.2		54	35	889560	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'2.5		115	72	1442890	Engine problem
Cumilla Area Total					3168	2045	42829244	
83	RPCL 210MW CAPP	IPP	4'35+1'70		202	87	2168880	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90		22	20	355140	
85	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924		0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3		3	0	8900	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21		200	200	4675200	
88	Jamalpur 115 MW PP (United)	IPP	9'78'12		115	92	1214400	Engine problem
89	Sutikatshahi 50 MW Solar PP	IPP	50		50	0	217220	Contract Expired
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7		22	24	560880	
Mymensingh Area Total					614	423	9218620	
91	Fenchuganj CAPP Phase-1	PDB	2'32+1'33		70	43	1023000	Machine problem
92	Fenchuganj CAPP Phase-2	PDB	2'35+1'35		90	42	945424	Machine problem
93	Kushara 163 MW CAPP (KP)	IPP	1'109+1'154		163	0	0	Gas shortage
94	Shahbazar 330 MW CAPP	PDB	3'110		330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatalah)	RPP	19'2.90		51	5	169200	Gas shortage
96	Fenchuganj 44MW (Energyprima)	NENP	12'3+5'2		50	5	141840	Gas shortage
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90		11	0	0	Gas shortage
97	Shahbazar GTPP Unit- 8 & 9	PDB	2'35		66	59	1371072	Engine problem
98	Shahbazar 86MW PP (Shahbazar)	RPP	32'2.90		86	50	552000	Gas shortage
99	Shahbazar 100 MW GTPP	PDB	1'100		100	0	0	Under maint.
100	Sylhet 225 MW CAPP	PDB	1'142+1'189		231	220	5271380	
101	Sylhet 20 MW GTPP	PDB	1'20		20	0	0	Gas shortage
102	Sylhet 50MW PP (EPL)	NENP	27'2		50	6	166920	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34		25	8	192000	Gas shortage
103	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119		341	290	7169000	FGMO
104	Bibiana-III 400 MW CAPP	PDB	400 MW		400	402	9250000	
105	Sylhet 100MW PP (Desh)	RPP	8'11.95		10	10	240120	
106	Bibiana South 400 MW	PDB	400 MW		383	400	9157300	
Sylhet Area Total					2477	1540	35649256	
**	Bheramara GTPP Unit-3	PDB	1'20		16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500		1000	849	21137454	
108	Khulna 115 MW PP (KPCL-2)	NENP	7'17		115	83	1204800	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	6'8.99		54	46	480960	Engine problem
110	Khulna 225 MW CAPP	NWPGCL	1'150+1'175		230	0	0	Fuel conservation
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98		109	66	976128	Line O/L
112	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132		410	160	4645440	Gas shortage.
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5		40	24	240000	
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4		100	0	0	Fuel shortage
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445		105	17	238560	
115	Madhumati 100 MW PP	PDB	8'18		105	105	2443968	
116	Mongla Orion 100 MW Solar PP	IPP						