

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9584667, 9551085

Month July, 2022				Day : Wednesday				Date : 27.07.22					
Probable Maximum Demand : 14400 MW				Probable Maximum Generation : 11965 MW				Rule Curve = 88.16 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.01 ft				Today = 91.34 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.07.22 (Yesterday)		27.07.22 (Today)		26.07.22 (Yesterday)		Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	MW				
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
2	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	200	200	200				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	85	92	92				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	300	300	300			60	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	408	407	400	406				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	7	7	7			95	Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	20	22				
17	Summit Power, (Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	53	49	49				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	50	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	100	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17			37	Fuel Oil Shortage
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	276	240	245	245				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	112	122	110	120				
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			87	Fuel Oil Shortage
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	90	17	90			72	Fuel Oil Shortage
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8			92	Fuel Oil Shortage
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	7	8	8			93	Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			102	S/D after fire incident
Dhaka Zone Total				6004	5847	2178	2541	2348	2570	1641	762		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	126	127	127	127				Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			80	Gas Shortage
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	16	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	28	30	31				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0			225	Awaiting for HGPL
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	177	285	175	285				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11			89	Fuel Oil Shortage
49	Dohazari -Kalaiash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	36	0	36			66	Generation raised to 51MW. Fuel loading ongoing
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	51	52				Problem in transformer set
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	16	16				
*	Melancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			8	29	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	87	90	90			21	Fuel Oil Shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	89	105	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10			90	Fuel Oil Shortage
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10			90	Fuel Oil Shortage
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	48	108	108	108				
Chattogram Zone Total				2442	2382	823	1190	1039	1195	436	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	30	30	42	42			15	Gas Shortage
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+175	221	221	174	212	200	211				
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	330	305	280	280				
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	320	310	300	300				
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test
64	Ashuganj 55 MW PP. (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5			50	Gas Shortage
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8			187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	130	130	130				
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	48	48				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	135	128	130	130				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+42x1.315+1x1.058	200	200	0	0	0	0				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	116	107	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	72	36	95			43	Fuel Oil Shortage
**	Impoort (Tripura)	India		160	160	114	156	125	165				
Cumilla Zone Total				3193	3169	1605	2045	1705	2053	295	0		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	96	87	90	90			115	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	92	40	92				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0				
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total				622	614	390	423	424	424	115	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.07.22 (Yesterday)		27.07.22 (Today)		26.07.22 (Yesterday)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gen. shortfall for : Gas/Coal/Water Limitation	Machines shut down (MW)
					Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	G1-Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42	48	G1-Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	8	5	47	20	46	Gas Shortage	
91	Kushlira 163 MW CCPP (KIP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	110	109	54	Gas Shortage
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11	Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	59	62	60			
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	50	78	78	36	Gas shortage	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	210	220			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Gas shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8		Gas shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	280	280			
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400			
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	0	0			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	25	25	44	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.5+5'2	50	50	5	5	43	20	45	Gas Shortage	
Sylhet Zone Total												
			2522	2477	1522	1540	1248	1317	328	559		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	195	160	180	160	250	Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	46	0	40			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	66	0	66	43	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17	88	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	25	0	100	0			
115	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	33	83	33	83	32	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8	40	40	8	8	8	24	16	Fuel Oil Shortage	
**	Bheramara (HVDC)	India	1000	1000	900	849	865	881				
Khulna Zone Total												
			2388	2384	1283	1350	1308	1376	386	43		
117	Barsal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	16	32		Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	29	15	25			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	85	129	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	970	910	1100			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17		Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	GasHSD (IPP)	2x75+1x70	220	220	222	225	225	220			
Barishal Zone Total												
			1958	1958	1238	1338	1231	1479	129	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34	18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	25		Maintenance ongoing	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	89	88	88			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	16	24			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	25	25	25			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	35	13	1 Engine TIC problem, 1 engine has high temperature.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	170	138	150	150	72	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	142	0	220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	127	150	140	93	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	388	310	330	350	104	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8	52	Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	113	75	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	70	113	70	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
Rajshahi Zone Total												
			2129	2129	1030	1203	985	1138	712	84		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overheating	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	85	105	92	105			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	109	108	108	108			
Rangpur Zone Total												
			800	720	395	412	408	413	85	85		
Sub-total: Plants in operation												
			22058	21680	10464.0	12042	10696	11965	4127	2088		
(B) Plants under long term maintenance/ contract expired												
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0		Contract Expired	
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Forced Outage	
151	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0		Contract expired	
152	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired												
			424	0	0	0	0	0	0			
Gross Total												
			22482	21680	10464	12042	10696	11965	4127	2088		
(C) Actual data of 26.07.22 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)		13421 MW,	at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)		13006 MW,	at = 21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)		12042 MW,	at = 21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)		10312 MW,	at = 8:00 hrs	Dhaka	4676	4399	276.9495595	Mymensingh	1010	868	142
05.	Day-peak Generation (Generation end)		10464 MW,	at = 9:00 hrs	Chattogram	1374	1229	145.178817	Sylhet	478	424	53.81745631
06.	Evening-peak Generation (Generation end)		12042 MW,	at = 21:00 hrs	Khulna	1611	1405	206	Barishal	367	367	0
07.	Evening Peak Load-shed (Sub-station end)		1379 MW,	at = 21:00 hrs	Rajshahi	1405	1185	220	Rangpur	858	708	150
08.	Minimum Generation Forecast up to 8:00 hrs.		10386 MW,	at = 5:00 hrs	Cumilla	1228	1043	185				
09.	Generation shortfall at evening peak due to :					Total			13006	11627	1379	
a)	Gas limitation		4042 MW		13.	Fuel cost :			(a) Gas = 146210971 Taka	(c) Coal = 246921736 Taka		
c)	Coal supply Limitation		85 MW			(b) Oil = 1073282935 Taka			Total = 1466415642 Taka			
b)	Low water level in Kapitai lake		0 MW			Maximum Temperature in Dhaka was :			31.2° C			
c)	Plants under shut down/ maintenance		2088 MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)		266.89 MKWh			At evening peak-hour		10464 MW,	at 21:00 hrs			
	By Gas = 130.702 MKWh		By Oil = 78.305 MKWh			Maximum		470 MW,	at 22:00 hrs			
	By Coal = 29.415 MKWh		By Hydro = 3.009 MKWh			Energy		0 MKWh				
11.	Total Gas Supplied		963.54 MMCFD									
(D) Forecast of 27.07.22 (Today) Wednesday :												
01.	Maximum Demand		14400 MW	(Generation end)	04.	Maximum Load-shed						
02.	Maximum Generation		11965 MW	(Generation end)	05.	Total Generation						
03.	Reserve / Shortage		-2435 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :						
						35.2° C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation