

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated		Remarks
						MW	KWH	
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	260	0	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0	0	Under maint.
3	Ghorasal TPP Unit-1	PDB	1210	190	180	4347000	0	Gas shortage
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	300	7117009	0	Contract Expired
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2140	0	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	85	1990545	0	Engine problem
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	408	9795590	0	Gas shortage
9	Haripur 360MW CAPP (HPL)	IPP	1235+1125	360	333	7736000	0	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	5051050	0	Gas shortage & GT-2 S/D
11	Meghnaghat 100 MW(IEI)	NENP	12*9	100	85	821280	0	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	335	0	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	0	Under maint.
14	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	0	1179200	0	Fuel shortage
15	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	0	Contract Expired
16	Narsingdi 22 MW (Doreen)	SIPP, REB	8*2.90	22	19	443448	0	Engine problem
17	210 MW Siddhirgonj TPP	PDB	12*10	115	0	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	0	Gas shortage
19	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12*8.9	100	90	887664	0	Engine problem
20	Siddhirgonj 335 MW CAPP	EGCB	12*17+118	335	0	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	94	974016	0	Engine problem
22	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	0	Fuel shortage
23	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	408960	0	Fuel shortage
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	149	2711040	0	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	300216	0	Engine problem
26	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	265099	0	Engine problem
27	Bosila 108MW PP(CLC)	IPP	12*8.75+1*3.5	0	0	0	0	Under maint.
28	Suait Power (Madhat-Ashulia)	SIPP, REB	33.67+4*8.73	80	52	1214340	0	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	619300	0	Engine problem
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	624700	0	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	1164000	0	#REF!
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	288	5136107	0	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	258*1.4	300	0	0	0	Fuel conservation
35	Brambaraganj 100 MW PP (Aggreko)	IPP	114*0.959	100	0	0	0	Fuel conservation
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	0	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	115	2757890	0	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2328000	0	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	54	853440	0	Fuel shortage
40	Karnaliganj 162MW PP(MPL)	IPP	9*18	162	162	1636680	0	Engine problem
41	Spectra Solar Plant Ltd	IPP	35	35	0	194960	0	Engine problem
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	55	1328760	0	Engine problem
<b>Dhaka area Total</b>				<b>5847</b>	<b>3012</b>	<b>62788394</b>		
43	Chattogram TPP-1	PDB	1210	180	100	1400000	0	Machine problem
44	Chattogram TPP-2	PDB	1210	180	0	0	0	Gas shortage
45	Raizan 25 MW PP	RPCL	3*8.9	25	25	563092	0	Engine problem
46	Teknaf 20MW PP (Solartech)	IPP	20	20	0	115830	0	Engine problem
47	Balanga 50MW PP (Baraka)	IPP	8*6.98	50	36	649440	0	Engine problem
48	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	128	3052806	0	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	0	HGPI for 30 days.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	2436327	0	Engine problem
52	Hathazari 100 MW peaking PP	PDB	11*8.9	98	50	894552	0	Engine problem
53	Dahazari-Kalash 100 MW Peaking	PDB	8*17	102	52	371045	0	Engine problem
54	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	80	1479600	0	Engine problem
55	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	2064000	0	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	17	381648	0	Engine problem
57	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	28	564960	0	Engine problem
58	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	88	2092800	0	Engine problem
59	Kaptai 7 MW Solar PP	PDB	7.4	7	0	26639	0	Engine problem
60	Amara 300 MW PP (United)	IPP	17*17.24	300	300	3710945	0	Engine problem
61	Jodac Power	IPP	3*18.55+1*3.6	54	54	1059007	0	Engine problem
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2489007	0	Engine problem
63	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2351040	0	Engine problem
64	Anilma Energy Ltd.	IPP	6*21.2	116	108	2569309	0	Engine problem
<b>Chattogram area Total</b>				<b>2382</b>	<b>1487</b>	<b>28272047</b>		
65	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	0	Contract Expired
67	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	0	Gas shortage
68	Ashuganj 225 MW CAPP	APSCL	1142+175	221	209	4924000	0	#REF!
69	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	290	7652100	0	Engine problem
70	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	345	7485000	0	FGMO
71	Ashuganj 420 MW CAPP(East)	APSCL	284*1+36*1	284	0	0	0	On test.
72	Ashuganj 50 MW PP (Precision)	APSCL	143.968	45	32	530280	0	Gas shortage
73	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	5	168000	0	Gas shortage
74	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	200727	0	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1171529	0	Engine problem
76	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	130	2961953	0	Engine problem
77	Titas 50 MW Peaking PP	PDB	6*8.92	52	38	962856	0	Engine problem
78	Hindpur 150 MW CAPP	PDB	11*06+1*57	163	135	3233400	0	Machine problem
79	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	3091680	0	Engine problem
80	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	379440	0	Engine problem
81	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	208980	0	Engine problem
82	Imoport (Tripura)	Imported power	0	160	162	3798720	0	Engine problem
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	731000	0	Engine problem
84	Jangalia 52 MW PP (Kishore)	IPP	6*8.92	52	43	396514	0	Engine problem
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	516510	0	Engine problem
86	Daudkandi 200 MW PP (B. Trac)	IPP	15*1.4	200	0	0	0	Fuel conservation
87	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	1077300	0	Engine problem
88	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	117	2684640	0	Engine problem
89	Bhairab 54.5 MW	IPP	3*18.2	54	35	888120	0	33 kV feeder problem.
90	Chandpur 115(Doreen)	IPP	4*18.5+2*2.5	115	52	1304640	0	Fuel shortage
<b>Cumilla Area Total</b>				<b>3168</b>	<b>2063</b>	<b>44361389</b>		
91	RPCL 210MW CAPP	IPP	4*35+1*70	202	103	2163840	0	Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	445680	0	Engine problem
93	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	6650	0	Engine problem
95	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	200	4027200	0	Engine problem
96	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	107	1471200	0	Engine problem
97	Sulatah 50 MW Solar PP	IPP	50	50	0	182750	0	Engine problem
98	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	18	547440	0	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>448</b>	<b>8844760</b>		
99	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	44	1028000	0	Machine problem
100	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	989677	0	Machine problem
101	Kushara 163 MW CAPP (KP)	IPP	11*09+1*54	163	110	2619491	0	Gas shortage
102	Shahjibazar 330 MW CAPP	PDB	3*110	330	0	0	0	Under maint.
103	Fenchugonj 51 MW PP (Barakattullah)	RPP	19*2.90	51	33	1006800	0	Engine problem
104	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	30	928584	0	Engine problem
105	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	177100	0	Engine problem
106	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	59	1449504	0	Engine problem
107	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	78	1080000	0	Engine problem
108	Shahjibazar 100 MW GTPP	PDB	11*00	100	0	0	0	Under maint.
109	Sylhet 225 MW CAPP	PDB	11*42+1*99	231	220	5265320	0	Engine problem
110	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	0	Engine problem
111	Sylhet 50MW PP (EPL)	NENP	27*2	50	32	754100	0	Gas shortage
112	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	392544	0	Gas shortage
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	290	7563500	0	FGMO
114	Bibiana-III 400 MW CAPP	PDB	400 MW	400	403	9550000	0	Engine problem
115	Sylhet 10MW PP (Desh)	RPP	8*1.95	10	10	239040	0	Engine problem
116	Bibiana South 400 MW	PDB	400 MW	383	0	0	0	Under maint.
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1378</b>	<b>33043660</b>		
117	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	0	Reserve.
118	Bheramara (HVDC)	Imported power	2*500	1000	845	21023272	0	Engine problem
119	Khulna 115 MW PP (KPCL-2)	NENP	7*17	115	82	976320	0	Engine problem
120	Fandpur 50 MW Peaking PP	PDB	6*8.98	54	43	447840	0	Engine problem
121	Khulna 225 MW CAPP	NWPGCL	11*50+1*75	230	0	0	0	Fuel conservation
122	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	61	562176	0	Line O/L
123	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	160	3949920	0	Gas shortage
124	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5					