

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month July, 2022			Day : Friday						Date : 29.07.22			
Probable Maximum Demand :			12800 MW			Probable Maximum Generation :			12994 MW			
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 91.54 ft			Today = 91.88 ft			Rule Curve = 88.49 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.07.22 (Yesterday)		29.07.22 (Today)		28.07.22 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Oil/Water Limitation	Machines shut down	Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	MW	(MW)		
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	83	85	86	88			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Under maint. Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	333	300	300			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	407	408	400	412			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	0	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	94	24	94			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	20	22			
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x3.73	80	80	53	52	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	50	51			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPger)	9x17.06	149	149	100	149	100	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35			Fuel Oil Shortage
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	268	245	245			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	115	115	110	120			
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	48	54	17	54			
32	Manikganj 162MW PPI(MPGL)	HFO (IPP)	9x18	162	162	17	162	54	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	90	24	90			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	24	85	25	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		102	S/D after fire incident
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2486</b>	<b>3012</b>	<b>2532</b>	<b>3052</b>	<b>1142</b>	<b>762</b>		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	128	128	127	127			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	36	37	37			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	141	300	150	285			
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	21	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	68			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	50	51	52			Problem in transformer set
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	18			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			8	28	42	42			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	90	88	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	99	110	110	110			
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	78	100	20	100			
56	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	44	80	80	80			
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108			
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1121</b>	<b>1487</b>	<b>1195</b>	<b>1491</b>	<b>0</b>	<b>555</b>		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	32	35	35		13	Gas Shortage
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1x75	221	221	201	209	180	211			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	270	345	300	330			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	275	290	300	320			
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0			On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	30	30		50	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8		187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	130	117	130			
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	38	48	48			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	135	135	135	135			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	200	50	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14+6x15.05+1x11.086	200	200	0	0	0	0			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	108	117	107	113			
79	Bhairor 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	53	36	36		62	Fuel Oil Shortage
**	Impport (Tripura)	India		160	160	160	162	143	166			
<b>Cumilla Zone Total</b>			<b>3193</b>	<b>3169</b>	<b>1626</b>	<b>2053</b>	<b>1686</b>	<b>2091</b>	<b>312</b>	<b>0</b>		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	82	103	105	104		99	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	107	50	107			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	183	200	200	200			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
86	Sutakhirai 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	25	18	22	22			
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>398</b>	<b>448</b>	<b>449</b>	<b>453</b>	<b>99</b>	<b>0</b>		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.07.22 (Yesterday)		29.07.22 (Today)		28.07.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening				
88	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT-1 Under maint.	
89	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42	43		48	GT-4 Under maint.	
90	Fenchugonj	51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	33	33	33				
91	Kushiera	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.	
92	Hobgajj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	0	0				
93	Shahjibazar	GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	59	60	60				
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	78	78				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet	20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	24				
100	Bibiya-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	300	330				
101	Bibiya-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	403	400	400				
102	Bibiya South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection	
103	Shahjibazar	100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet	50MW PP (EPL)	Gas (NENP)	2x27	50	50	32	32	25	32	18		Gas Shortage	
105	Fenchugonj	44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	42	30	30	30				
<b>Sylhet Zone Total</b>				<b>2522</b>	<b>2477</b>	<b>1326</b>	<b>1378</b>	<b>1367</b>	<b>1413</b>	<b>18</b>	<b>941</b>			
106	Bheramara	GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	160	170	170	250		Gas Shortage	
108	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	40				
109	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	61	0	66		48	Maintenance ongoing	
110	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	19	35	35	86		Fuel Oil Shortage	
113	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105				
114	Mongla Orion	100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0				
115	Khulna	115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	82	33	83	33		Fuel Oil Shortage	
116	Noapara	40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	24	8	24	16		Fuel Oil Shortage	
**	Bheramara (H/DC)		India		1000	1000	860	845	861	876				
<b>Khulna Zone Total</b>				<b>2388</b>	<b>2384</b>	<b>1233</b>	<b>1339</b>	<b>1312</b>	<b>1399</b>	<b>385</b>	<b>48</b>			
117	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	16	32			Line Overload	
118	Bhola	33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	33	23	25				
119	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	63	60	65	85	134		Gas Shortage	
120	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	1000	970	1100				
121	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17			Line Overload	
122	Bhola	220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	217	220	225	220				
<b>Barishal Zone Total</b>				<b>1958</b>	<b>1958</b>	<b>1233</b>	<b>1362</b>	<b>1299</b>	<b>1479</b>	<b>134</b>	<b>0</b>			
123	a) Baghabari	71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari	100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	34	34	34		18	Turbocharger problem	
125	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	34	0	25		37	Maintenance ongoing	
127	Chapainawabganj	100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	82	87	88	88				
128	Katakhali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	32	32				
129	Katakhali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	25	25				
130	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	35	35		20	1 Engine TIC problem, 1 engine has high temperature.	
131	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	122	161	165	163	49		Gas Shortage	
132	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	153	208	0	0	220		Gas Shortage	
133	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	129	128	150	140	92		Gas Shortage	
134	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	291	285	330	350	129		Gas Shortage	
135	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
136	Uliapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
138	Bagura	113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	113	75	113				
139	Bagura	113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	113	70	113				
140	Sirajgonj	6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2129</b>	<b>2129</b>	<b>1010</b>	<b>1310</b>	<b>1051</b>	<b>1203</b>	<b>661</b>	<b>75</b>			
141	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
143	Rangpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	78	105	92	105				
145	Saidpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara	Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon	115MW PP (Energypac)	HFO (IPP)	6'20	115	115	89	90	108	108				
<b>Rangpur Zone Total</b>				<b>800</b>	<b>720</b>	<b>373</b>	<b>395</b>	<b>408</b>	<b>413</b>	<b>85</b>	<b>85</b>			
<b>Sub-total: Plants in operation</b>				<b>22058</b>	<b>21680</b>	<b>10806.0</b>	<b>12784</b>	<b>11299</b>	<b>12994</b>	<b>2836</b>	<b>2466</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>														
148	Jamalpur	95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired
149	Katpotti	52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired
150	Bosila	108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forecast Outage
151	Keraniganj	100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired
152	Bogra	20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
153	Amnura	50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			
<b>Gross Total</b>				<b>22482</b>	<b>21680</b>	<b>10806</b>	<b>12784</b>	<b>11299</b>	<b>12994</b>	<b>2836</b>	<b>2466</b>			
<b>(C) Actual data of 28.07.22 (Yesterday) Thursday :</b>														
01.	Max. Demand at eve. peak (Generation end)			13500	MW, at = 21:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)			13129	MW, at = 21:00 hrs									
03.	Highest Generation (Generation end)			12792	MW, at = 22:00 hrs									
04.	Minimum Generation (Generation end)			10599	MW, at = 9:00 hrs									
05.	Day-peak Generation (Generation end)			10806	MW, at = 12:00 hrs									
06.	Evening-peak Generation (Generation end)			12784	MW, at = 21:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)			936	MW, at = 21:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.			10521	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation			2751	MW									
	c) Coal supply Limitation			85	MW									
	b) Low water level in Kaptai lake			0	MW									
	c) Plants under shut down/ maintenance			2466	MW									
10.	Total Energy (Generation + India Import)			277.41	MKWh									
	By Gas = 129.923				MKWh									
	By Coal = 29.924				M									