

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TFP Unit-5	PDB	1'210	190	180	4410000	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1243*1122	365	300	7199127	Machine problem
3	Ghorashal 78.5 MW PP(IMAX)	ORPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	77	1894363	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273*1139	412	411	8889790	
7	Haripur 360MW CCPP(HPL)	IPP	1'235*1125	360	333	7712000	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150*1150	450	225	5041950	Gas shortage & GT-2 S/D.
9	Meghnaghat 100 MW(EL)	NENP	1'28.9	100	86	531840	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110*1110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08*1111.3	55	40	991722	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8'13.45	0	0	0	Contract Expired
14	Narshingaj 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	446652	
15	210 MW Siddhirganj TTP	PDB	1'210	115	0	0	Under maint.
16	Siddhirganj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	89	538522	Fuel shortage
18	Siddhirganj 335 MW CCPP	EGCB	1'217*118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	94	619632	Fuel shortage
20	Kapoti 52 MW PP (Sinha)	IPP	7'7.9	52	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1004760	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	132	1754880	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1318025	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	1081665	Engine problem
25	Bosila 108MW PP(CLO)	IPP	12'8.775*113.5	0	0	0	
26	Summit Power, (Madhabad+Ashulia)	SIPP, REB	3'3.67*4'8.73	80	52	1194360	Engine problem
27	Maara 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	599900	
28	Ruggan 33 MW PP(Summit)	SIPP, REB	4'8.73	33	28	708500	
29	Gazipur 52 MW PP	RPCL	6'8.9	52	51	1097760	#REF!
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.06	300	275	3640690	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Fuel conservation
33	Bramhanaganj 100 MW PP (Aggreko)	IPP	114'0.95	100	0	0	Fuel conservation
34	Aurahat 100MW PP (Aggreko)	IPP	0.8573*3.95'91	100	0	0	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45*8.97	149	134	2650896	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2461800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	88	738240	Fuel shortage
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	3309120	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	166621	
40	Kanchan Purachal Power Generation Ltd.	IPP	18.4'3	55	55	975600	
Dhaka area Total				5847	3705	61981415	
41	Chattogram TTP-1	PDB	1'210	180	100	2400000	Machine problem
42	Chattogram TTP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	443048	
43	Teknaf 200 MW PP (Solartech)	IPP	20	20	0	117990	
44	Patenga 50MW PP (Baraka)	IPP	6'8.98	50	32	758400	Engine problem
45	Kapla Hydro Unit-1, 2, 3, 4, 5	PDB	2'40*3'50	230	113	2892827	Low water level
46	Sikalbaha 225MW	PDB	1'150*1'175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	IPP	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2126027	
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	25	597888	Fuel shortage
50	Dohazari-Kalash 100 MW Peaking	PDB	6'17	102	51	1218317	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	56	1315560	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	877440	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	382368	Engine problem
54	Malancha, Cig, EPZ (United)	IPP	5'8.73*3'9.34	0	18	523200	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	6	1553280	Engine problem
55	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	25439	
56	Anwara 300 MW PP (United)	IPP	17'17*24	300	214	1653491	Engine problem
57	Juidah Power	IPP	3'18.55*13'6	54	36	732073	Fuel shortage
58	Karnaghuli Power Ltd.	IPP	18.415*6'5.5	110	55	1330549	Fuel shortage
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	982080	Engine problem
60	Anilima Energy Ltd.	IPP	6'21.2	116	108	2593145	
Chattogram area Total				2382	1151	22323222	
61	Ashuganj TTP Unit-3	APSCCL	1'150	0	0	0	Contract Expired
61	Ashuganj TTP Unit-4	APSCCL	1'150	0	0	0	Contract Expired
61	Ashuganj TTP Unit-5	APSCCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCCL	1'142*1175	221	209	4801000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCCL	1'360	360	280	7782100	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCCL	1'360	360	260	7259000	Gas shortage
64	Ashuganj 420 MW CCPP(East)	APSCCL	284'1*136'1	284	0	0	On test.
65	Ashuganj 50 MW PP	APSCCL	14'3.968	45	37	866664	Machine problem
66	Ashuganj 55 MW PP (Precision)	ORPP	6'8.9	55	30	1058640	Gas shortage
67	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73*11'6	195	8	217454	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1210675	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	133	3111272	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	48	1028440	Engine problem
71	Chandpur 150 MW CCPP	PDB	1'106*1'157	163	142	3363240	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	3232800	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	503760	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	228060	
**	Imported power (Tripura)	Imported power	0	160	158	3801600	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	768000	
76	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	43	403258	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67*2'6.97	25	20	46230	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	15'41.4	200	0	0	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415*11'9.78	114	114	927960	
80	Chowmuhani 113 MW	IPP	12'9.78*2'3.1	113	114	2474640	
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	857880	33 kv feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5*2'22.5	115	56	1375680	Fuel shortage
Cumilla Area Total				3169	2003	45732153	
83	RPCL 210MW CCPP	IPP	4'35*1'70	202	101	1934400	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	385740	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11900	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	180	1881600	Engine problem
88	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	79	1346400	Engine problem
89	Sunahali 50 MW Solar PP	IPP	50	50	0	232780	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	0	0	Engine problem
Mymensingh Area Total				614	380	5792820	
91	Fenchuganj CCPP Phase-1	PDB	2'32*1'33	70	44	1023000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2'35*1'35	90	41	957920	Machine problem
93	Kushara 163 MW CCPP (KP)	IPP	1'109*1'54	163	110	2602554	ST under maint.
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakattullah)	RPP	18'2.90	51	53	924800	
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.2*5'12	50	49	1159992	
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	110000	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	61	1360128	
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	959040	Engine problem
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142*1'89	231	221	5368890	
101	Sylhet 20 MW GTTP	PDB	1'120	20	0	0	
102	Sylhet 50MW PP (EPL)	NENP	2'72	50	33	755800	Gas shortage
103	Shahjibazulla 25 MW PP	SIPP, REB	3'9.34	25	8	345960	Engine problem
102	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222*1'119	341	295	7590000	FGMO
104	Bibiana-III 400 MW CCPP	PDB	400 MW	400	403	9503000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	228600	
106	Bibiana South 400 MW	PDB	400 MW	382	0	0	Under maint.
Sylhet Area Total				2477	1409	32892884	
107	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	907	21944000	
108	Khuina 115 PP MW (KPCL-2)	NENP	7'17	115	16	381120	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	6'8.89	54	39	260640	Engine problem
110	Khuina 225 MW CCPP	NWPGCL	1'150*1'175	230	0	0	Fuel conservation
111	Gopalganj 100 MW Peaking PP	PDB	15'6'98	100	78	718744	Line O/L
112	Bheramara 410 MW CCPP	NWPGCL	1'278*1'132	410	135	3417120	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	140625	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	7'01.4	100	0	0	
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	28	306190	Fuel shortage
115	Madhumali 100 MW PP	NWPGCL	6'18	105	105	2424240	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	565200	
116	Khuina 330 MW CCPP (OIL)	BPDB	1'220*1'110	0	0	0	On test.
Khuina Area Total				2384	1314	30158879	
117	Barisal 110 MW PP (Summit)	IPP	7'17.078	110	32	588608	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	30	614891	Engine problem
119	Bhola 225 MW CCPP	PDB	2'63*1'68	194	88	2066744	ST under S/D
120	Bhola 95 MW PP (Aggreko)	ORPP	96'1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2'622	1244	1040	25378000	Line O/L
122	Bhola Nutan Baku BD LTD	IPP	220	220	219	5131399	
123	United Payra Power Ltd.	IPP	8'18.5*11'9.5	150	0	98400	Line O/L
Barisal Area Total				1958	1409	33917952	
124	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
124	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
125	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	635424	Engine problem
126	Bara 70 MW Peaking PP	PDB	6'8.9	71	41	489185	Engine problem
127	Amnua 50 MW PP(Sinha)	ORPP	7'77.79	0	0	0	Contract Expired
128	Katakhal 50 MW PP (Northern)	ORPP	6'8.9	50	42	977008	Engine problem
129	Katakhal 50 MW Peaking PP	PDB	6'8.9	50	32	652370	Engine problem
130	Sirajgonj Unit-1 225MW	NWPGCL	1'150*1'175	210	182	4516064	Gas shortage
131	Sirajgonj Unit-2 225MW	NWPGCL	1'150*1'175	220	218	5033245	
132	Sirajgonj Unit-3 225MW	NWPGCL	1'144	220	142	3597591	Gas shortage
133	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'282*1'132	414	260	6325418	Gas shortage
134	Santihar 50 MW Peaking PP	PDB	6'8.7	50	33	783240	Engine problem
135	Bogra 22 MW PP (GBB)	RPP	6'4	22	22	444240	
136	Bogra 20 MW PP (Energyprima)	NENP	5'3.345'2	0	0	0	
137	Ullapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	265230	
138	Natore						