

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW				
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.	
3	Ghorasal 180 MW CCPP	PDB	1'210	180	180	4378500		
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	300	7018945	Machine problem	
4	Ghorasal 78.5 MW PPI(MAX)	ORPP	2'40	0	0	0	Contract Expired	
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	89	1952909	Engine problem	
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.	
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	412	9887750		
7	Haripur 365 MW CCPP(HPL)	IPP	1'235+1'125	365	332	7708800		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5035400	Machine problem Gas shortage & GT-2 S/D.	
9	Meghnaghat 100 MW(IE/L)	NENP	1'28.9	100	80	499200	Engine problem	
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage	
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.	
12	Madanganj 55 MW PPI(Summit)	IPP	3'17.08+1'11.3	55	30	853556	Engine problem	
13	Keraniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	Contract Expired	
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	9'2.90	22	19	392184		
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.	
16	Siddhirgonj 2'210 MW GTPP	EGCB	2'105	210	92	966000	Gas shortage	
17	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	88	522240	Fuel shortage	
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	0	0	Gas shortage	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	94	495216	Fuel shortage	
20	Katpott 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage	
21	Karnalghat 54 MW PPI(Banco Energy)	IPP	3'18	54	54	870120		
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	127	1669920	Engine problem	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1330984		
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	954209		
25	Bosila 108MW PPI(CLO)	IPP	12'8.75+1'3.5	0	0	0		
26	Summit 33 MW PPI(Madhabad-Ashulia)	SIPP, REB	33.67+4'7.3	80	50	1089240		
27	Maona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	686160	Engine problem	
28	Ruggan 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	718400		
29	Gazipur 52 MW PP	RPCL	6'8.9	52	48	1122720	#REF!	
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	245	3748580	Engine problem	
32	Keraniganj 300 MW PP (APR)	IPP	250'1.4	300	0	0	Fuel conservation	
33	Bramharanganj 100 MW PP (Aggreko)	IPP	11'40.959	100	0	0	Fuel conservation	
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel conservation	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	133	2607696	Engine problem	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2466000		
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	88	650880	Fuel shortage	
38	Manikganj 162MW PPI(MPL)	IPP	9'18	162	162	2760480		
39	Spectra Solar Plant Ltd	IPP	35	35	0	249991		
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	458640		
Dhaka area Total			5847	3184	61093820			
41	Chattogram TPP-1	PDB	1'210	180	100	2300000	Machine problem	
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	580883		
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	112455		
44	Patenga 80MW PP (Baraka)	IPP	9'8.98	50	32	740640	Engine problem	
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	112	2657440	Low water level	
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.	
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.	
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2043227		
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	15	552048	Fuel shortage	
50	Dhazari Peaking 100 MW Peaking	PDB	8'17	102	51	1201628	Fuel shortage	
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	56	1309080	Fuel shortage	
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	862080	Engine problem	
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	375456	Engine problem	
54	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	31	869760		
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	89	731520	Engine problem	
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	23641		
56	Anwara 300 MW PP (United)	IPP	17'1+24	300	214	2023955	Engine problem	
57	Joidac Power	IPP	3'18.55+1'3.6	54	36	776329	Fuel shortage	
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	55	1317267	Fuel shortage	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	954240		
60	Anilma Energy Ltd.	IPP	6'21.2	116	108	2589382	Engine problem	
Chattogram area Total			2382	1236	22026929			
61	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired	
61	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	Contract Expired	
61	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage	
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	206	4728000	#REF!	
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	310	310	7763000	Gas shortage	
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	305	7594000	Gas shortage	
65	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.	
65	Ashuganj 50 MW PPI	APSCL	14'3.968	45	36	831024	Machine problem	
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	55	1100640		
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	8	284363	Gas shortage	
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1175026		
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	128	3082836	Engine problem	
70	Tras 50 MW Peaking PP	PDB	6'8.92	52	39	1057560	Engine problem	
71	Chandpur 163 MW CCPP	PDB	1'106+1'157	163	143	3402030	Machine problem	
72	Chandpur 200MW (Dash energy)	IPP	12'18.4	200	200	3254880		
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	502416		
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	201240		
**	Impoport (Tripura)	Imported power	0	160	162	3364800		
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	807900		
76	Jangalia 52 MW PP (Ladawan)	IPP	9'8.92	52	43	404381	Fuel shortage	
77	Umiltia 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	493360	Engine problem	
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel conservation	
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1061340		
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2550240		
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	887760	33 kV feeder problem.	
82	Chandpur 115(Doreen)	IPP	4'18.5+2'2.5	115	74	1710720	Fuel shortage	
Cumilla Area Total			3169	2106	4625716			
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	102	2030400	Gas shortage	
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	408528		
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.	
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	15450		
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	179	1900980	Engine problem	
88	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	79	1342800	Engine problem	
89	Sutahali 50 MW Solar PP	IPP	50	50	0	286310		
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	0	0	Engine problem	
Mymensingh Area Total			614	380	5984288			
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1024000	Machine problem	
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	956624	Machine problem	
93	Kushara 163 MW CCPP (KP)	IPP	1'109+1'54	163	110	2591263	ST under maint.	
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.	
95	Fenchugonj 51 MW PP (Barakattallah)	RPP	19'2.90	51	53	1069800		
96	Fenchugonj 44MW (Energytina)	NENP	12'3.3+5'2	50	49	1069800		
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	56000		
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	61	1416480		
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	1261440	Engine problem	
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.	
100	Sylhet 225 MW CCPP	PDB	1'142+1'139	221	220	5246580		
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0		
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	32	749480	Gas shortage	
102	Shahjibahulla 25 MW PP	SIPP, REB	3'9.34	25	16	233024	Engine problem	
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	7427500	FGMO	
104	Biyana-III 400 MW CCPP	IPP	400 MW	400	402	9387000		
105	Sylhet 100MW PP (Dash)	RPP	8'11.95	100	9	236880		
106	Biyana South 400 MW	PDB	400 MW	383	0	0	Under maint.	
Sylhet Area Total			2477	1398	32724871			
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.	
**	Bheramara (HVDC)	Imported power	2'500	1000	913	21995636		
108	Khulna 115 MW PP (KPL-2)	NENP	7'17	115	16	375360	Fuel shortage	
109	Faidpur 50 MW Peaking PP	PDB	6'8.99	54	32	292320	Engine problem	
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel conservation	
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	71	854528	Line O/L	
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	185	3989376	Gas shortage.	
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	143250	Fuel shortage	
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0		
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	35	175200	Fuel shortage	
115	Nadhumandir 60 MW PP	PDB	6'18	105	105	2562192		
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	609120		
116	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.	
Khulna Area Total			2384	1365	30996982			
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	724032	Line O/L	
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	31	634351	Engine problem	
119	Bhola 225 MW CCPP	PDB	2'63+1'68	194	88	2076507	ST under S/D	
120	Bhola 85 MW PP (Aggreko)	ORPP	98'1.0	0	0	0	Contract Expired	
121	Payra 1320 MW	BCPCL	2'622					