

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022										Day : Saturday				Date : 06.08.22					
Probable Maximum Demand : 13800 MW										Probable Maximum Generation : 12778 MW									
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 92.73 ft		Today = 93.01 ft		Rule Curve = 90.60 ft					
Sl. No.	Name of Power Station	Fuel	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.08.22 (Yesterday)		06.08.22 (Today)		Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)											
						Day	Evening	Day	Evening										
(A) Plants in operation:																			
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work							
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.							
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300										
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	85	89	90	90										
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.							
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contact Expired							
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	332	300	330										
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage							
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling							
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	410	412	412	412										
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	92	90	90		118	Gas Shortage							
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage							
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Gas Shortage							
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	30	30	30										
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	94	8	94										
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19										
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	50	50	50										
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	33										
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33										
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	48	51	51										
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	88	105										
22	Kodda 150MW PP	HFO (BRPger)	9x17.06	149	149	48	127	50	132										
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54										
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	245	110	275										
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	98	133	100	133										
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0										
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0										
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0										
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55										
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55										
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	88	17	104										
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	70	162										
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	30	0										
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	55	55	55										
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	88	8	50										
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	7	80	8	50										
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0										
Dhaka Zone Total										6004	5847	2373	3184	2474	3167	1013	660		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	111	112	111	112			Unit 1 under rehabilitation							
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	100	100	100	100		180	Under maint.							
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0										
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25										
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0										
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	32	25	32										
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	68	105										
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.							
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Awaiting for HGPI							
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	50	214	50	214										
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	21	90	21	90										
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	17	51										
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	15	26	26										
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17										
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			39	31	10	30										
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	89	90	95										
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36										
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55										
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	20	100	20	100										
56	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	56	56	55	56										
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108										
Chattogram Zone Total										2442	2382	823	1236	859	1252	0	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0										
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	36	37	37										
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	179	206	210	210										
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	305	305	305	305	55		Gas Shortage							
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	280	310	310	310	50		Gas Shortage							
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test							
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	35	55	55	55										
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187		Gas Shortage							
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51										
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	128	128	128										
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	47	39	32	40										
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	141	142	142	142										
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	100	200										
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22										
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	10	10										
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33										
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43										
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20										
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x10	200	200	0	0	0	0										
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114										
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	106	113	78	113										
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35										
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	65	74	60	60										
**	Impoport (Tripura)	India		160	160	138	162	143	166										
Cumilla Zone Total										3193	3169	1765	2106	1804	2102	292	0		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	67	102	102	102	100		Gas Shortage							
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20										
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	79	49	79										
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	179	48	180										

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.08.22 (Yesterday)		06.08.22 (Today)		05.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down (MW)			
88	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	33	53				
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	61	61				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	8	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	290	290				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	402	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	32	32	31	32		18	Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5*5*2	50	50	49	49	30	49				
Sylhet Zone Total					2522	2477	1376	1398	1287	1406	38	943	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	155	185	180	185		225	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	15	32				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	71	20	70		38	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	0	35				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	67	0	100	0				
115	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	16	16	16		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8		32	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	909	913	930	930				
Khulna Zone Total					2388	2384	1252	1365	1366	1381	356	38	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	16	32			Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	31	23	30				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	88	88	88		106	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPL)	2x622	1244	1244	900	1040	1110	1100				
121	Potuaikhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	220	214	225	220				
Barisal Zone Total					1958	1958	1260	1405	1462	1470	106	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	24	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40		31	Maintenance ongoing	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	36	86	80	86				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	32	32				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	33	33	33		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	180	190	188	190				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	172	0	0		220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	146	167	162	167		53	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	310	370	350	350		44	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	21				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2129	2129	1080	1429	1054	1237	488	66	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	56	92				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Wajpara, Talia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	52	90	52	90				
Rangpur Zone Total					800	720	311	382	316	382	85	85	
Sub-total: Plants in operation					22058	21680	10438.0	12885	10893	12778	2478	2347	

(B) Plants under long term maintenance/ contract expired													
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0				
Gross Total					22482	21680	10438	12885	10893	12778	2478	2347	

(C) Actual data of 05.08.22 (Yesterday) Friday :																
01.	Max. Demand at eve. peak (Generation end)	:	13450	MW, at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12945	MW, at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	12951	MW, at =	22:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	10438	MW, at =	9:00	hrs	Dhaka	4406	4336	70	Mymensingh	1070	944	126		
05.	Day-peak Generation (Generation end)	:	10438	MW, at =	9:00	hrs	Chattogram	1344	1344	0	Sylhet	585	585	0		
06.	Evening-peak Generation (Generation end)	:	12885	MW, at =	21:00	hrs	Khulna	1621	1536	85	Barishal	388	388	0		
07.	Evening Peak Load-shed (Sub-station end)	:	521	MW, at =	21:00	hrs	Rajshahi	1387	1302	85	Rangpur	844	779	65		
08.	Minimum Generation Forecast up to 8.00 hrs.	:	10552	MW, at =	5:00	hrs	Cumilla	1300	1210	90						
09.	Generation shortfall at evening peak due to :	:									Total	12945	12424	521		
a)	Gas limitation	:	2393	MW			13. Fuel cost :			(a) Gas =	157364122	Taka	(c) Coal =	254834817	Taka	
d)	Coal supply Limitation	:	85	MW						(b) Oil =	1043319480	Taka	Total =		1455518419	Taka
b)	Low water level in Kaptai lake	:	0	MW												
c)	Plants under shut down/ maintenance	:	2347	MW						14. Maximum Temperature in Dhaka was : 35.4° C						
10.	Total Energy (Generation + India Import)	:	270.22	MW						15. Export through East-West interconnections :						
	By Gas =	135.375	MKWH	By Oil =	75.146	MKWH				At evening peak-hour : 10438 MW, at 21:00 hrs						
	By Coal =	30.301	MKWH	By Hydro =	2.657	MKWH				Maximum : 274 MW, at 22:00 hrs						
	By Solar =	1.381	MKWH							Energy : 0 MKWH						
11.	Total Gas Supplied	:	1024.74	MMCFD												

(D) Forecast of 06.08.22 (Today) Saturday :												
01.	Maximum Demand	:	13800	MW	(Generation end)	04. Maximum Load-shed : 942.2963149 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	12778	MW	(Generation end)	05. Total Generation : 287.93 MKWH						
03.	Reserve / Shortage	:	-1022	MW	(Generation end)	06. Probable Max. Temperature in Dhaka : 35.3° C						

* Captive Power ** Imported Power
 #Remarks: