

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022			Day : Sunday						Date : 07.08.22		
Probable Maximum Demand :			14200 MW			Probable Maximum Generation : 13539 MW					
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 93.54 ft			Today = 94.17 ft			Rule Curve = 91.24 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.08.22 (Yesterday)		07.08.22 (Today)		07.08.22 Gen. shortfall for : Gas/Coal/Oil/Water Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	200	200	200		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	81	90	93		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contact Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	257	320	330	103	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	402	397	412	412		
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	8	30		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x1.73	80	80	45	52	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	30	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	51	51		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	50	128	50	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	242	110	275		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	97	149	90	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	284	250	284		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	96	97	96		
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	93	100		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	17	104		
32	Manikganj 162MW PPI(MPL)	HFO (IPP)	9x18	162	162	54	162	70	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	48	8	50		
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	7	48	8	48		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	2097	3239	2759	3410	1208	660	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	111	116	118	118		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	100	100	100	100		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0		180	
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	25	25	32		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	105	68	90		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	50	214	50	214		
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	21	90	21	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	34	26	26		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	17	17		
*	Malancha, Ctp,EPZ (United)	Gas	5x8.73+3x9.34			2	30	10	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	80	90	95		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	73	55	55		
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	20	100	20	100		
56	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	56	33	56	56		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108		
Chattogram Zone Total			2442	2382	774	1235	867	1223	0	555	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	31	41	39	39		
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	166	208	210	210		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	330	305	305	320		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	320	320	310	330	40	Gas Shortage
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	40	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	122	128	132		
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	38	32	40		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	137	129	142	142		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14+6x10.59+1x10.59	200	200	0	195	195	195		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	115	78	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	6	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	75	75	71	71		
**	Impport (Tripura)	India		160	160	150	160	143	166		
Cumilla Zone Total			3193	3169	1645	2086	1946	2183	227	0	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	81	100	102	102	102	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	20	20	20		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	106	49	79		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	154	48	180		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutarkhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0		
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	11	11		
Mymensingh Zone Total			622	614	242	386	282	392	102	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.08.22 (Yesterday)		07.08.22 (Today)		07.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	MW	MW				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	33	53	33	53					
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	56	61	61					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	221	220	220					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	8	16					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	330	275	290	290					
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	380	402	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection		
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	31	31	31		19	Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.5*5*2	50	50	30	48	30	49					
Sylhet Zone Total				2522	2477	1306	1387	1298	1417	39	942			
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	150	150	160	185		260	Gas Shortage		
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	15	32					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	60	70		37	Maintenance ongoing		
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	221	228	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	96	60	96					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	0	35					
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	88	105	105	105					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	44	0	100	0					
115	Khulna 115 MW PP (KPOL-2)	HFO (NENP)	7x17	115	115	16	32	16	16		83	Fuel Oil Shortage		
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8		32	Fuel Oil Shortage		
**	Bheramara (HVDC)	India		1000	1000	914	909	931	931					
Khulna Zone Total				2388	2384	1433	1691	1672	1703	375	37			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	64	64			Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	33	23	30					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	88	88	88		106	Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	940	800	600	600					
121	Potualkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	90	150			Line Overload		
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	187	225	220					
Barisal Zone Total				1958	1958	1282	1322	1090	1152	106	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	32	32	32		18	Turbocharger problem		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	172	170	172					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	40		46	Maintenance ongoing		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	80	80	86					
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32		18	Under maint.		
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	33	33		16	Under maint.		
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	178	170	188	190					
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	213	213	210	210		220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	146	143	162	167		77	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	290	286	350	350		128	Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	21					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52					
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	50	94	50	94					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total				2129	2129	1074	1460	1450	1627	596	98			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	240	250	250					
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	91	56	92					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Hajpara, Talia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	90	52	90					
Rangpur Zone Total				800	720	296	421	366	432	85	85			
Sub-total: Plants in operation				22058	21680	10149.0	13227	11730	13539	2738	2377			
(B) Plants under long term maintenance/ contract expired														
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020		
153	Ammara 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0					
Gross Total				22482	21680	10149	13227	11730	13539	2738	2377			
(C) Actual data of 07.08.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	14200 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13501 MW, at =	21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	13227 MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	:	10149 MW, at =	9:00 hrs	Dhaka	4992	4822	170	Mymensingh	1019	839	180		
05.	Day-peak Generation (Generation end)	:	10149 MW, at =	9:00 hrs	Chattogram	1296	1246	50	Sylhet	568	488	80		
06.	Evening-peak Generation (Generation end)	:	13227 MW, at =	21:00 hrs	Khulna	1640	1480	160	Barishal	402	402	0		
07.	Evening Peak Load-shed (Sub-station end)	:	897 MW, at =	21:00 hrs	Rajshahi	1371	1251	120	Rangpur	945	908	37		
08.	Minimum Generation Forecast up to 8.00 hrs.	:	11166 MW, at =	5:00 hrs	Cumilla	1268	1168	100						
09.	Generation shortfall at evening peak due to :	:				Total						13501	12604	897
a)	Gas limitation	:	2653 MW			Fuel cost :						(a) Gas = 144451350 Taka	(c) Coal = 231624653 Taka	
d)	Coal supply Limitation	:	85 MW			(b) Oil = 1216925561 Taka						Total = 1593001564 Taka		
b)	Low water level in Kaptai lake	:	0 MW			14. Maximum Temperature in Dhaka was :						35.4° C		
c)	Plants under shut down/ maintenance	:	2377 MW			15. Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	268.04 MKWh			At evening peak-hour						10149 MW, at	21:00 hrs	
	By Gas = 125.597 MKWh					By Coal = 27.823 MKWh						454 MW, at	5:00 hrs	
	By Oil = 1.561 MKWh					By Hydro = 2.797 MKWh						0 MW, at		
11.	Total Gas Supplied	:	969.50 MMCFD			Energy						0	MKWh	
(D) Forecast of 07.08.22 (Today) Sunday :														
01.	Maximum Demand	:	14200 MW	(Generation end)	04.	Maximum Load-shed						609.6206867 MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13539 MW	(Generation end)	05.	Total Generation						287.76	MKWh	
03.	Reserve / Shortage	:	-661 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :						35.7° C		

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation