

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour		Energy Generated	Remarks
				MW	MW	MW	KWH		
Unit No. X Capacity									
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1'260	260	0	0	0	Under maint.	
2	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	0	0	0	Under maint.	
3	Ghorasal TPP Unit-1	PDB	1'210	180	0	0	4284000	Machine problem	
4	Ghorasal 365 MW CAPP Unit-7	QRPP	1'243+1'122	365	300	0	7139018	Contract Expired	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	0	Engine problem	
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	81	0	2064772	Under maint.	
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	0	Gas shortage	
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	398	0	9775110	Gas shortage	
9	Haripur 308MW CAPP (HPL)	IPP	1'225+1'111	360	0	0	7904000	Gas shortage	
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	450	0	8905250	Fuel shortage	
11	Meghnaghat 100 MW(IEI)	NENP	1'28.9	100	47	0	439560	Gas shortage	
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	0	0	0	Under maint.	
13	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	0	Engine problem	
14	Madanganj-55 MW PP(Summit)	ORPP	3'17.08+1'113.0	55	30	0	740685	Contract Expired	
15	Karanganj 100 MW PP (Powerpac)	IPP	8'13.45	0	0	0	0	Under maint.	
16	Narsingdi 22 MW (Doreen)	SIPP, PDB	6'22	22	22	0	402120	Under maint.	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	0	Gas shortage	
18	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	95	0	3309000	Fuel shortage	
19	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	32	0	321600	Gas shortage	
20	Siddhirgonj 335 MW CAPP	EGCB	1'217+118	335	0	0	0	Gas shortage	
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	32	0	302688	Fuel shortage	
22	Katpali 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	0	Engine problem	
23	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	0	662400	Engine problem	
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	125	0	1052160	Under maint.	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	0	1325689	Under maint.	
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	0	773708	Engine problem	
27	Bosila 108MW PPI(IEI)	IPP	12'8.775+1'33.0	0	0	0	0	Engine problem	
28	Sunmit Power (Madhabdi-Ashulia)	SIPP, REB	3'3.67+4'8.73	80	50	0	106400	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	0	78760	Engine problem	
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	24	0	623400	Engine problem	
31	Gazipur 52 MW PP	RPCL	6'8.9	52	41	0	980640	#REF!	
32	Tongi 80 MW GTPP	PDB	1'105	105	0	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	296	0	3362181	Engine problem	
34	Keraniganj 300 MW PP (ARR)	IPP	2'587.14	300	301	0	2919141	Engine problem	
35	Bramhanganj 100 MW PP (Aggreko)	IPP	11'40.959	100	81	0	1508028	Engine problem	
36	Aurahat 100MW PP (Aggreko)	IPP	8'85'23+0.95'91	100	86	0	1572319	Engine problem	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	0	1621584	Engine problem	
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	0	2316000	Fuel shortage	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	34	0	404160	Engine problem	
40	Manikganj 162MW PPI(MPGL)	IPP	9'18	162	162	0	2329480	Engine problem	
41	Spectra Solar Plant Ltd	IPP	35	35	0	0	238880	Engine problem	
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	0	1251000	Engine problem	
Dhaka area Total				5847	3694	70380503			
43	Chattogram TPP-1	PDB	1'210	180	105	0	2500000	Machine problem	
44	Chattogram TPP-2	PDB	1'210	180	0	0	0	Gas shortage	
45	Raozan 25 MW PP	RPCL	3'9.9	25	25	0	532513	Engine problem	
46	Teknaf 20MW PP (Solartech)	IPP	20	20	0	0	105540	Engine problem	
47	Balenga 50MW PP (Baraka)	IPP	6'9.98	50	42	0	237600	Low water level	
48	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	150	0	3541731	HGPI for 30 days.	
49	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	0	Under maint.	
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	0	Engine problem	
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	51	0	725963	Fuel shortage	
52	Hathazari 100 MW peaking PP	PDB	11'8.9	98	26	0	602360	Fuel shortage	
53	Dhazari-Kalesh 100 MW Peaking	PDB	6'17	102	51	0	706931	Fuel shortage	
54	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	33	0	790320	Fuel shortage	
55	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	21	0	519360	Fuel shortage	
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	14	0	324192	Engine problem	
57	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	29	0	579360	Engine problem	
58	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	91	0	666240	Engine problem	
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	7	0	28080	Engine problem	
60	Amara 100 MW PP (United)	IPP	17'17+24	300	213	0	2806945	Engine problem	
61	Jodiac Power	IPP	3'18.55+1'3.6	54	36	0	854462	Engine problem	
62	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	55	0	1313922	Engine problem	
63	Juidah unit-2 (Acorn)	IPP	8'13.6	100	20	0	493440	Engine problem	
64	Anilma Energy Ltd.	IPP	6'21.2	116	107	0	2570564	Engine problem	
Mirshara 150 MW				BPDB-RPCL	18.5'9	0	0	0	On test
Chattogram area Total				2382	1089	19732523			
65	Ashuganj TPP Unit-1	APSCl	1'150	0	0	0	0	Contract Expired	
66	Ashuganj TPP Unit-2	APSCl	1'150	0	0	0	0	Contract Expired	
67	Ashuganj TPP Unit-3	APSCl	1'150	134	0	0	0	Gas shortage	
68	Ashuganj 225 MW CAPP	APSCl	1'142+1'175	221	206	0	5007000	#REF!	
69	Ashuganj 450 MW CAPP(North)	APSCl	1'360	360	330	0	8247900	Gas shortage	
70	Ashuganj 450 MW CAPP(South)	APSCl	1'360	360	310	0	7649000	FGMO	
71	Ashuganj 420 MW CAPP(East)	APSCl	284'1+136'1	284	0	0	0	On test.	
72	Ashuganj 50 MW PP	APSCl	14'3.968	45	40	0	852624	Engine problem	
73	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	55	0	1266240	Gas shortage	
74	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	26	0	418181	Engine problem	
75	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	0	1128102	Engine problem	
76	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	133	0	2898836	Engine problem	
77	Titas 50 MW Peaking PP	PDB	6'8.92	52	37	0	932664	Engine problem	
78	Chandpur 150 MW CAPP	PDB	11'06+1'57	163	142	0	1300970	Machine problem	
79	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	0	4163520	Engine problem	
80	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	0	475344	Engine problem	
81	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	0	193320	Engine problem	
82	Import (Tripura)	Imported power	0	160	168	0	2880000	Engine problem	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	0	670900	Engine problem	
84	Jangalia 52 MW PP (Kishore)	IPP	6'8.92	52	37	0	932664	Fuel shortage	
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	17	0	459620	Engine problem	
86	Daudkandi 200 MW PP (B.Trac)	IPP	15'4.14	200	200	0	3173952	Engine problem	
87	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	0	Fuel shortage	
88	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	58	0	611520	Fuel shortage	
89	Bhairab 54.5 MW	IPP	3'18.2	54	35	0	887040	35 KV feeder problem.	
90	Chandpur 115(Doreen)	IPP	4'18.3+2'22.5	115	95	0	2125440	Engine problem	
Cumilla Area Total				3169	2168	45342173			
91	RPCL 210MW CAPP	IPP	4'35+1'70	202	101	0	2787840	Gas shortage	
92	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	0	502848	Engine problem	
93	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	0	Under maint.	
94	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	0	13950	Engine problem	
95	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	180	0	2181600	Engine problem	
96	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	79	0	1537200	Engine problem	
97	Sulakhali 50 MW Solar PP	IPP	50	50	0	0	323550	Engine problem	
98	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	0	287280	Engine problem	
Mymensingh Area Total				614	394	7634268			
99	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	0	1022000	Machine problem	
100	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	30	0	686936	Machine problem	
101	Kushnara 163 MW CAPP (KP)	IPP	1'109+1'54	163	0	0	0	Gas shortage	
102	Shajshaj 330 MW CAPP	PDB	2'110	330	0	0	0	Under maint.	
103	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	5	0	129600	Gas shortage	
104	Fenchugonj 44MW (Energyprima)	NENP	12'3.3+5'2	50	5	0	143640	Gas shortage	
105	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	0	Engine problem	
106	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	63	0	1424736	Engine problem	
107	Shahjibazar 80MW PP (Shahjibazar)	RPP	32'2.90	86	81	0	777600	Engine problem	
108	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	0	Under maint.	
109	Sylhet 225 MW CAPP	PDB	1'142+1'189	231	221	0	5215200	Gas shortage	
110	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	0	Gas shortage	
111	Sylhet 50MW PP (EPL)	NENP	27'2	50	0	0	61340	Gas shortage	
112	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	0	0	74160	Gas shortage	
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	280	0	7228000	FGMO	
114	Bibiana-III 400 MW CAPP	PDB	400 MW	400	400	0	9544000	Engine problem	
115	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	0	224100	Engine problem	
116	Bibiana South 400 MW	PDB	400 MW	383	400	0	9451500	Engine problem	
Sylhet Area Total									