

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9544667, 9551095

Month August, 2022				Day : Wednesday				Date : 17.08.22			
Probable Maximum Demand :			14300 MW		Probable Maximum Generation :		13880 MW		Rule Curve = 94.12 ft		
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.95 ft		Today = 95.90 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.22 (Yesterday)		17.08.22 (Today)		16.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		
					Day	Evening	Day	Evening	MW	(MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	81	92	92		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	321	330	330		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	408	398	412	412		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	193	95	100	100	115	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	8	32	70	Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	22	22	22		
17	Summit Power, (Madhabdi+Ashula)	Gas (SIPP, REB)	6x8.07+1x8.73	80	80	44	50	50	50		
18	Maons 33 MW PP(Summit)	Gas (SIPP, REB)	6x8.73	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x8.73	33	33	25	24	25	24		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	125	16	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	296	95	285		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	149	35	149		
26	Keanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	103	301	100	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	92	81	60	96		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	94	86	86	100		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	34	17	34	70	Fuel Oil Shortage
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	47	55	55	55		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	32	8	32	68	Fuel Oil Shortage
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	47	8	50	53	Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	2923	3694	2813	3760	1046	660	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	147	150	145	145		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25		
42	Teknaf 20MW PP (Solar tech)	Solar (IPP)	1x20	20	20	17	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	42	6	42		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	213	123	210		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	21	21	21	79	Fuel Oil Shortage
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26	72	Fuel Oil Shortage
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	14	15	15		
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	29	7	30		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	91	12	95		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	0	0		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	20	20	100	80	Fuel Oil Shortage
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	33	33	33	67	Fuel Oil Shortage
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
Chattogram Zone Total			2442	2382	776	1069	740	1146	349	555	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	40	35	35		
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1775	221	221	205	206	205	210		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	325	310	310	320		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x360	360	360	335	330	330	330		
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	55	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	26	8	8	169	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	124	133	125	133		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	37	40	40		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	50	142	140	142		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0	52	Fuel Oil Shortage
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	17	20	21		
76	Daudkandi 200 MW PP (B. Trac)	HSD (IPP)	86x1.4+8x1.515+1x1.032	200	200	150	200	200	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0	114	Fuel Oil Shortage
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	58	9	57	55	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	95	96	100		
**	Impoort (Tripura)	India		160	160	134	168	143	168		
Cumilla Zone Total			3193	3169	1928	2168	2067	2168	390	0	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	131	101	130	100	101	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	79	68	79		
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	77	180	80	180		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Myensing Zone Total			622	614	366	394	364	393	101	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.22 (Yesterday)		17.08.22 (Today)		16.08.22 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance							
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation	Machines shut down	Description/ Remarks	Probable start-up date						
					Day	Evening	Day	Evening	MW	(MW)								
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.						
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.						
90	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	19x2.90	51	51	5	5	5	5									
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.						
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0									
93	Shahibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	62	64									
94	Shahibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.						
95	Shahibazar 86MW PP (Shahibazar)	Gas (RPP)	3x2.90	86	86	10	81	10	80									
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	193	221	220	220									
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10									
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0		25	Gas Shortage						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300									
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	402	400	400									
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400									
103	Shahibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work						
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0		50	Gas Shortage						
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5		45	Gas Shortage						
Sylhet Zone Total					2522	2477	1460	1540	1485	1557	140	680						
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0									
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	220	160	200	180		250	Gas Shortage						
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	36									
109	Gopatganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	31	65	35	65		44	Maintenance ongoing						
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	222	223	225	225									
111	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	10	93	90	90									
112	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	17	53	17	52		52	Fuel Oil Shortage						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	89	105	90	105									
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0									
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	66		99	Fuel Oil Shortage						
116	Noopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0		40	Fuel Oil Shortage						
**	Bheramara (HVDC)	India		1000	1000	884	884	924	924									
Khulna Zone Total					2388	2384	1580	1636	1697	1743	441	44						
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	32	110									
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	30	19	30									
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	150	149	151	151									
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	610	620	620									
121	Potua khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	15	150	150	150									
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0									
Barishal Zone Total					1958	1958	821	1049	972	1061	0	0						
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage						
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage						
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	30	32	32		18	Turbocharger problem						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	52	168	100	175									
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40									
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	39	78	50	80									
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	40		18	Under maint.						
129	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	42	50	42	50									
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	32	33	33		18	Under maint.						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	175	160	170	150		50	Gas Shortage						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	209	215	220	220		220	Running on HSD						
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	165	150	160	150		70	Gas Shortage						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	321	400	380		93	Gas Shortage						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	21	22									
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11									
137	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8									
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95									
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94									
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0									
Rajshahi Zone Total					2129	2129	1303	1503	1374	1580	604	54						
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80									
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling						
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250									
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	55	91	55	90									
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0									
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	17	52	0	52									
Rangpur Zone Total					800	720	407	473	393	472	0	85						
Sub-total: Plants in operation					22058	21680	11564.0	13526	11905	13880	3071	2078						
(B) Plants under long term maintenance/ contract expired																		
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0									
149	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0									
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0									
151	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	0	0	0	0	0									
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020						
153	Amnura 50 MW PP(Sinha)	HFO (ORPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022						
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0						
Gross Total					22482	21680	11564	13526	11905	13880	3071	2078						
(C) Actual data of 16.08.22 (Yesterday) Tuesday :																		
01.	Max. Demand at eve. peak (Generation end)	:	14100	MW	at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	13385	MW	at =	21:00	hrs	Zone	Demand	Supply	Load Shed							
03.	Highest Generation (Generation end)	:	13526	MW	at =	21:00	hrs		MW	MW	MW							
04.	Minimum Generation (Generation end)	:	10559	MW	at =	7:00	hrs	Dhaka	4847	4847	0	Mymensingh	1087	907	180			
05.	Day-peak Generation (Generation end)	:	11564	MW	at =	10:00	hrs	Chattogram	1307	1307	0	Sylhet	559	559	0			
06.	Evening-peak Generation (Generation end)	:	13526	MW	at =	21:00	hrs	Khulna	1613	1443	170	Barishal	398	398	0			
07.	Evening Peak Load-shed (Sub-station end)	:	529	MW	at =	21:00	hrs	Rajshahi	1386	1307	79	Rangpur	871	821	50			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11212	MW	at =	5:00	hrs	Cumilla	1317	1267	50							
09.	Generation shortfall at evening peak due to :	:										Total	13385	12856	529			
		a) Gas limitation	:	3071	MW													
		d) Coal supply Limitation	:	0	MW													
		b) Low water level in Kapitla lake	:	0	MW													
		c) Plants under shut down/ maintenance	:	2078	MW													
10.	Total Energy (Generation + India Import)	:	283.56	MkWh														
			By Gas =	143.908	MkWh	By Oil =	86.327	MkWh										
			By Coal =	23.614	MkWh	By Hydro =	3.542	MkWh										
			By Solar =	1.571	MkWh													
11.	Total Gas Supplied	:	1055.89	MMCFD														
(D) Forecast of 17.08.22 (Today) Wednesday :																		
01.	Maximum Demand	:	14300	MW	(Generation end)	04.	Maximum Load-shed	:	433	MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	13880	MW	(Generation end)	05.	Total Generation	:	299.79	MkWh								
03.	Reserve / Shortage	:	-420	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka	:	34.5° C									

* Active Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation