

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month August, 2022			Day : Sunday				Date : 21.08.22				
Probable Maximum Demand :			14200 MW		Probable Maximum Generation :				13638 MW		
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 95.55 ft		Today = 95.30 ft		Rule Curve = 95.40 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.08.22 (Yesterday)		21.08.22 (Today)		20.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	300	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	93	87	87		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	257	275	275		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	240	240		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	409	412	412		
11	Siddhirgonj 2'120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	35	0	0	175	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	185	93	200	200	242	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8	94	Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22		
17	Summit Power.(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	52	52	52	52		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	40	24	40		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	52	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	45	119	16	120		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	188	243	110	285		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	16	149		
26	Keranigonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	300	300	230	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.999	100	100	70	91	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.999	100	100	0	91	70	90		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17	87	Fuel Oil Shortage
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	50	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	7	8	8	93	Fuel Oil Shortage
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	8	8	8	92	Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2685</b>	<b>3335</b>	<b>2595</b>	<b>3375</b>	<b>1118</b>	<b>660</b>	
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	156	150	150		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	108	110	110	110		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	38	25	37		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	87	69	85		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	124	181	85	178		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	9	43	40	40	55	Fuel Oil Shortage
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11		
*	Malancha_Ctg.EPZ(United)	Gas	5x8.73+3x9.34			2	25	10	25		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	94	12	93		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54		
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	110	110	110		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90	Fuel Oil Shortage
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	108	108	108		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>724</b>	<b>1123</b>	<b>863</b>	<b>1107</b>	<b>376</b>	<b>555</b>	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	40	35	35		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	204	206	210	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	305	300	310		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	310	300	320		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	54	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	55	73	36	36	122	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	105	138	140	140		
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	47	37	45		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	143	144	145	145		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	100	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8	44	Fuel Oil Shortage
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	18	18		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+49x1.515+51x1.096	200	200	150	195	200	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	34	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	29	9	26	84	Fuel Oil Shortage
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	19	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	96	96	96		
**	Impoprt(Tripura)	India		160	160	152	156	143	165		
<b>Cumilla Zone Total</b>			<b>3193</b>	<b>3169</b>	<b>2004</b>	<b>2204</b>	<b>1991</b>	<b>2273</b>	<b>250</b>	<b>0</b>	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	113	127	85	100	75	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	68	48	68		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	77	106	80	180		
85	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutkhalhi 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0		
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>350</b>	<b>335</b>	<b>299</b>	<b>382</b>	<b>75</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.08.22 (Yesterday)		21.08.22 (Today)		20.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	20	30	30		70	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	5	0	5				
91	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	62	62	62				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	207	193	193	193				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0		17	Gas Shortage	
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	295	300	310				
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	402	405	400	400				
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	378	391	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0		50	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	5	0	5		45	Gas Shortage	
<b>Sylhet Zone Total</b>				<b>2522</b>	<b>2477</b>	<b>1438</b>	<b>1518</b>	<b>1448</b>	<b>1538</b>		<b>132</b>	<b>690</b>	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	155	155	155		255	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	20	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	40	50		45	Maintenance ongoing	
110	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	150	225	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	92	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	35	17	35		70	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	67	15	67				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	10	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0		40	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	907	905	904	904				
<b>Khulna Zone Total</b>				<b>2388</b>	<b>2384</b>	<b>1266</b>	<b>1599</b>	<b>1542</b>	<b>1590</b>		<b>464</b>	<b>45</b>	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	16	25				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	148	150	151	151				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	960	1160	1170	1170				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				
122	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0				
<b>Barishal Zone Total</b>				<b>1958</b>	<b>1958</b>	<b>1127</b>	<b>1370</b>	<b>1369</b>	<b>1411</b>		<b>0</b>	<b>0</b>	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	32	32		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	18	172	120	170				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	38	82	35	80				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
132	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	174	174	180	180		36	Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	196	220	220		220	Running on HSD	
134	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	148	148	150	150		72	Gas Shortage	
135	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	291	316	305	305		98	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	21	21				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	50	94	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2129</b>	<b>2129</b>	<b>935</b>	<b>1453</b>	<b>1193</b>	<b>1470</b>		<b>597</b>	<b>54</b>	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	81	80	80				
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	251	251	250	250				
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	91	55	90				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	72				
<b>Rangpur Zone Total</b>				<b>800</b>	<b>720</b>	<b>395</b>	<b>495</b>	<b>393</b>	<b>492</b>		<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>				<b>22058</b>	<b>21680</b>	<b>10924.0</b>	<b>13432</b>	<b>11693</b>	<b>13638</b>		<b>3012</b>	<b>2089</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katbotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniaganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>		<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>22482</b>	<b>21680</b>	<b>10924</b>	<b>13432</b>	<b>11693</b>	<b>13638</b>		<b>3012</b>	<b>2089</b>	
<b>(C) Actual data of 20.08.22 (Yesterday) Saturday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13950 MW, at = 20:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 13236 MW, at = 20:00 hrs		Zone		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 13478 MW, at = 22:00 hrs		Dhaka		4795	4735	60	Mymensingh	1174	874	300	
04.	Minimum Generation (Generation end)	: 10502 MW, at = 8:00 hrs		Chattogram		1234	1234	0	Sylhet	613	613	0	
05.	Day-peak Generation (Generation end)	: 10924 MW, at = 12:00 hrs		Khulna		1522	1522	0	Barishal	368	368	0	
06.	Evening-peak Generation (Generation end)	: 13432 MW, at = 20:00 hrs		Rajshahi		1349	1349	0	Rangpur	926	926	0	
07.	Evening Peak Load-shed (Sub-station end)	: 431 MW, at = 20:00 hrs		Cumilla		1255	1184	71					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10977 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	: 3012 MW		13.		Fuel cost :		(a) Gas = 149368899 Taka	(c) Coal = 295592113 Taka				
d)	Coal supply Limitation	: 0 MW						(b) Oil = 1148424829 Taka	Total = 1593385841 Taka				
b)	Low water level in Kapta lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2089 MW											
10.	Total Energy (Generation + India Import)	: 272.95 MKWh		14.		Maximum Temperature in Dhaka was :		34.3° C					
	By Gas = 130.956 MKWh	By Oil = 75.714 MKWh		15.		Export through East-West interconnections :							
	By Coal = 35.968 MKWh	By Hydro = 3.615 MKWh				At evening peak-hour		: 10924 MW, at 20:00 hrs					
	By Solar = 1.163 MKWh					Maximum		: 515 MW, at 21:00 hrs					
11.	Total Gas Supplied	: 1063.50 MMCFD				Energy		: 0 MKWh					
<b>(D) Forecast of 21.08.22 (Today) Sunday :</b>													
01.	Maximum Demand	: 14200 MW (Generation end)		04.		Maximum Load-shed		: 518 MW At evening peak (Sub-station end)					