

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|------------------------------|---|----------------|---------------------|-------------|------------------|----------------------|-----------------------|---------|
| | | | Unit No. X Capacity | MW | | | | |
| 1 | Ghorasal Repowered CAPP Unit-3 (GT) | PDB | 1'260 | 260 | 0 | 0 | Under maint. | |
| 2 | Ghorasal Repowered CAPP Unit-4 | PDB | 1'210 | 180 | 0 | 0 | Under maint. | |
| 3 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1'210 | 180 | 180 | 4284000 | | |
| 4 | Ghorasal 78.5 MW PPI(MAX) | ORPP | 1'243+1'122 | 365 | 300 | 7063636 | Machine problem | |
| 5 | Ghorasal 108MW PP (Regent) | IPP | 2'40 | 0 | 0 | 0 | Contract Expired | |
| 6 | Haripur GTPP | SBU, PDB | 34'3.35 | 108 | 91 | 2130636 | Engine problem | |
| 7 | Haripur 412 MW CAPP | EGCB | 2'32 | 20 | 0 | 0 | Under maint. | |
| 8 | Haripur 365 MW CAPP(HPL) | IPP | 1'273+1'139 | 412 | 391 | 9818110 | Gas shortage | |
| 9 | Meghnaghat 450 MW CAPP(MPL) | IPP | 1'235+1'125 | 365 | 363 | 7042000 | | |
| 10 | Meghnaghat 100 MW(EL) | NENP | 2'150+1'150 | 450 | 270 | 6457750 | Machine problem | |
| 11 | Meghnaghat CAPP(Summit) | IPP | 1'2'9 | 100 | 25 | 391680 | Fuel shortage | |
| 12 | Madanganj 102 PPI(Summit) | IPP | 2'110+1'110 | 335 | 0 | 0 | Gas shortage | |
| 13 | Madanganj 55 MW PPI(Summit) | NENP | 6'17 | 102 | 0 | 0 | Under maint. | |
| 14 | Keraniganj 100 MW PP (Powerpac) | IPP | 3'17.08+1'111.3 | 65 | 30 | 779305 | Engine problem | |
| 15 | Narsingdi 22 MW PP (Doreen) | GRPP | 8'13.45 | 0 | 0 | 0 | Contract Expired | |
| 16 | 210 MW Siddhirgonj TPP | SIPP, REB | 9'2.90 | 22 | 19 | 408304 | Engine problem | |
| 17 | Siddhirgonj 2'20 MW GTPP | PDB | 1'210 | 115 | 0 | 0 | Under maint. | |
| 18 | Siddhirgonj 100 PPI(Dutch Bangla) | EGCB | 2'105 | 210 | 0 | 0 | Gas shortage | |
| 19 | Siddhirgonj 335 MW CAPP | NENP | 1'2'9 | 100 | 32 | 250858 | Fuel shortage | |
| 20 | Gagnagar 102 MW PP (Digital Power) | EGCB | 1'217+118 | 335 | 140 | 4259184 | ST under shut down | |
| 21 | Katpott 52 MW PPI (Sinha) | IPP | 12'8.924 | 102 | 32 | 330048 | Fuel shortage | |
| 22 | Karnalghat 54 MW PPI(Banco Energy) | IPP | 717.9 | 0 | 0 | 0 | Fuel shortage | |
| 23 | Kodda 150MW PP | IPP | 3'19.3 | 54 | 54 | 794520 | | |
| 24 | Nababganj 55 MW PP (Northern) | BPDB-RPCL | 9'17.06 | 149 | 126 | 1267200 | Engine problem | |
| 25 | Nababganj 55 MW PP (Southern power) | IPP | 3'19.3 | 55 | 55 | 896216 | Engine problem | |
| 26 | Bosila 108MW PPI(CLO) | IPP | 3'19.3 | 55 | 35 | 893217 | Engine problem | |
| 27 | Summit Power (Madhabad-Ashulia) | IPP | 12'8.775+1'35.0 | 0 | 0 | 0 | | |
| 28 | Masona 33 MW PPI(Summit) | SIPP, REB | 33.67+4'8.73 | 80 | 50 | 1167380 | Engine problem | |
| 29 | Ruggan 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 0 | 723400 | Engine problem | |
| 30 | Gazipur 52 MW PP | RPCL | 6'8.9 | 52 | 39 | 348960 | #REF! | |
| 31 | Tongi 80 MW GTPP | PDB | 1'105 | 105 | 0 | 0 | Under maint. | |
| 32 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18'17.076 | 300 | 277 | 4496289 | Engine problem | |
| 33 | Keraniganj 300 MW PP (APR) | IPP | 250'1.4 | 300 | 204 | 4439617 | Engine problem | |
| 34 | Bramharanjan 100 MW PP (Aggroko) | IPP | 11'40.959 | 100 | 90 | 1444529 | Fuel shortage | |
| 35 | Aurahat 100MW PP (Aggroko) | IPP | 0.85'23+0.95'91 | 100 | 91 | 1357207 | Engine problem | |
| 36 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8'18.45+8.97 | 149 | 143 | 2707490 | | |
| 37 | Gazipur 100 MW PP | RPCL | 6'17.5 | 105 | 105 | 1044000 | | |
| 38 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5'6 | 104 | 54 | 567360 | Fuel shortage | |
| 39 | Manikganj 162MW PPI(MPL) | IPP | 9'18 | 162 | 162 | 1922400 | | |
| 40 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 0 | 205118 | |
| 41 | Kanchan Purbachal Power Generation Ltd. | IPP | 18.4'3 | 55 | 55 | 1319680 | | |
| Dhaka area Total | | | 5847 | 3432 | | 69536354 | | |
| 41 | Chattogram TPP-1 | PDB | 1'210 | 180 | 110 | 2600000 | Machine problem | |
| 42 | Chattogram TPP-2 | PDB | 1'210 | 180 | 0 | 0 | Gas shortage | |
| 43 | Raozan 25 MW PP | RPCL | 3'8.9 | 25 | 25 | 589631 | | |
| 44 | Teknaf 20MW PP (Solartech) | IPP | 2'0 | 20 | 0 | 97605 | | |
| 45 | Kaptai Hydro. Unit-1,2,3,4, 5 | IPP | 9'8.98 | 50 | 39 | 489120 | Engine problem | |
| 46 | Sikalbaha 225MW | PDB | 2'40+3'50 | 230 | 152 | 3552673 | Low water level | |
| 47 | Sikalbaha Peaking GT | PDB | 1'150+1'175 | 225 | 0 | 0 | HGPI for 30 days. | |
| 48 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6'17.5 | 105 | 87 | 1897709 | Engine problem | |
| 49 | Hathazari 100 MW peaking PP | PDB | 11'8.9 | 98 | 42 | 857312 | Fuel shortage | |
| 50 | Dahazari 100 MW Peaking | PDB | 8'17 | 102 | 51 | 589385 | Fuel shortage | |
| 51 | Juidah 100 MW Unit-1 (Acorn) | NENP | 8'13.45 | 100 | 10 | 257040 | Fuel shortage | |
| 52 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 8'13.5 | 100 | 10 | 247680 | Fuel shortage | |
| 53 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8'2.90 | 22 | 11 | 280080 | Engine problem | |
| 54 | Malancha, Ctg. EPZ (United) | IPP | 5'8.73+3'9.34 | 0 | 31 | 412320 | | |
| 55 | Chattogram 108 MW PP (ECPV) | IPP | 16'7 | 108 | 94 | 629760 | Engine problem | |
| 56 | Kaptai 7 MW Solar PP | PDB | 7.4 | 7 | 0 | 2569 | | |
| 57 | Anwara 300 MW PP (United) | IPP | 17'124 | 300 | 178 | 1894891 | Fuel shortage | |
| 58 | Jodac Power | IPP | 3'18.55+1'3.6 | 54 | 36 | 908373 | Engine problem | |
| 59 | Karnaphuli Power Ltd. | IPP | 18.415'6+6.5 | 110 | 110 | 2683879 | | |
| 60 | Juidah unit-2 (Acorn) | IPP | 8'13.6 | 100 | 10 | 250560 | Engine problem | |
| 61 | Anilma Energy Ltd. | IPP | 6'21.2 | 116 | 107 | 2595655 | Engine problem | |
| 62 | Mrshara 150 MW | BPDB-RPCL | 18.5'9 | 0 | 0 | 0 | On test. | |
| Chattogram area Total | | | 2382 | 1102 | | 20986882 | | |
| 61 | Ashuganj TPP Unit-3 | APSCCL | 1'150 | 0 | 0 | 0 | Contract Expired | |
| 62 | Ashuganj TPP Unit-4 | APSCCL | 1'150 | 0 | 0 | 0 | Contract Expired | |
| 63 | Ashuganj TPP Unit-5 | APSCCL | 1'150 | 134 | 0 | 0 | Gas shortage | |
| 64 | Ashuganj 225 MW CAPP | APSCCL | 1'142+1'175 | 221 | 209 | 4911000 | #REF! | |
| 65 | Ashuganj 450 MW CAPP(North) | APSCCL | 1'360 | 360 | 320 | 7713900 | Gas shortage | |
| 66 | Ashuganj 450 MW CAPP(South) | APSCCL | 1'360 | 360 | 305 | 7159000 | FGMO | |
| 67 | Ashuganj 420 MW CAPP(East) | APSCCL | 284'1+136'1 | 0 | 284 | 0 | On test. | |
| 68 | Ashuganj 50 MW PP | APSCCL | 14'3.968 | 45 | 39 | 858096 | Engine problem | |
| 69 | Ashuganj 55 MW PP (Precision) | ORPP | 15'4 | 55 | 56 | 1323840 | | |
| 70 | Ashuganj 195MW PP (APSCCL-United) | IPP | 20'9.73+1'16 | 195 | 8 | 217454 | Gas shortage | |
| 71 | Ashuganj 51 MW PP (Midland) | IPP | 6'9.34 | 51 | 51 | 1122928 | | |
| 72 | Ashuganj 150MW PP (Midland) | IPP | 23'7.015 | 150 | 138 | 3109600 | Engine problem | |
| 73 | Titas 50 MW Peaking PP | PDB | 6'8.92 | 52 | 42 | 96660 | Engine problem | |
| 74 | Chandpur 150 MW CAPP | PDB | 11'08+1'57 | 163 | 143 | 3435010 | Machine problem | |
| 75 | Chandpur 200MW (Desh energy) | IPP | 12'18.4 | 200 | 179 | 2760000 | Line O/L | |
| 76 | Feni 22MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 19 | 227556 | | |
| 77 | Feni 11 MW PP (Doreen) | SIPP, REB | 4'2.90 | 11 | 10 | 228240 | | |
| 78 | Imported (Tripura) | Imported power | 0 | 160 | 164 | 3631680 | | |
| 79 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4'8.73 | 33 | 25 | 679300 | Engine problem | |
| 80 | Jangalia 150 MW PP (Lakshmi) | IPP | 6'8.92 | 52 | 8 | 54883 | Engine problem | |
| 81 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3'3.67+2'6.97 | 25 | 18 | 484430 | Engine problem | |
| 82 | Daudkandi 200 MW PP (B.Trac) | IPP | 154'1.4 | 200 | 170 | 3685632 | | |
| 83 | Feni Lanka Power | IPP | 7'18.415+1'9.78 | 114 | 17 | 424080 | Fuel shortage | |
| 84 | Chowmuhani 113 MW | IPP | 12'9.78+2'3.1 | 113 | 58 | 903840 | Fuel shortage | |
| 85 | Bharab 54.5 MW | IPP | 3'18.2 | 54 | 35 | 869040 | 33 KV feeder problem. | |
| 86 | Chandpur 115 (Doreen) | IPP | 4'18.5+2'22.5 | 115 | 97 | 2333760 | Engine problem | |
| Cumilla Area Total | | | 3169 | 2111 | | 47030777 | | |
| 87 | RPCL 210MW CAPP | IPP | 4'35+1'70 | 202 | 107 | 214880 | Gas shortage | |
| 88 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 0 | 299808 | | |
| 89 | Jamalpur 95 MW PP(Powerpac) | IPP | 12'8.924 | 0 | 0 | 0 | Under maint. | |
| 90 | Sarishabari 3 MW Solar Plant | IPP | 1'3 | 3 | 0 | 11050 | | |
| 91 | Mymensingh 200 MW PP (United) | IPP | 9'78'21 | 200 | 125 | 2078400 | Fuel shortage | |
| 92 | Jamalpur 150 MW PP (United) | IPP | 9'78'12 | 115 | 99 | 1626000 | Engine problem | |
| 93 | Sutakhal 50 MW Solar PP | IPP | 50 | 50 | 0 | 332160 | | |
| 94 | Tangal Pali Power Gen 22 MW | IPP | 4'6.7 | 22 | 12 | 279120 | Engine problem | |
| Mymensingh Area Total | | | 614 | 343 | | 6775018 | | |
| 95 | Fenchugonj CAPP Phase-1 | PDB | 2'32+1'33 | 70 | 43 | 1019000 | Machine problem | |
| 96 | Fenchugonj CAPP Phase-2 | PDB | 2'35+1'35 | 90 | 30 | 693128 | Machine problem | |
| 97 | Kushnara 163 MW CAPP (KP) | IPP | 1'109+1'54 | 163 | 0 | 0 | Gas shortage | |
| 98 | Shajibazar 330 MW CAPP | PDB | 3'110 | 330 | 0 | 0 | Under maint. | |
| 99 | Fenchugonj 51 MW PP (Barakatullah) | RPP | 19'2.90 | 51 | 5 | 76200 | Gas shortage | |
| 100 | Fenchugonj 44MW (Energyptima) | NENP | 12'3.3+5'2 | 50 | 0 | 0 | Gas shortage | |
| 101 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4'2.90 | 11 | 0 | 0 | | |
| 102 | Shajibazar GTPP Unit - 8 & 9 | PDB | 2'35 | 66 | 60 | 1413312 | | |
| 103 | Shajibazar 98MW PP (Shajibazar) | RPP | 32'2.90 | 86 | 81 | 915840 | | |
| 104 | Shajibazar 100 MW GTPP | PDB | 1'100 | 100 | 0 | 0 | Under maint. | |
| 105 | Sylhet 225 MW CAPP | PDB | 1'142+1'189 | 231 | 193 | 4486330 | Machine problem | |
| 106 | Sylhet 20 MW GTPP | PDB | 1'20 | 20 | 0 | 0 | Gas shortage | |
| 107 | Sylhet 50MW PP (EPL) | NENP | 27'2 | 50 | 6 | 84760 | Gas shortage | |
| 108 | Shahjahanulla 25 MW PP | SIPP, REB | 3'9.34 | 25 | 8 | 44352 | Gas shortage | |
| 109 | Bibiana-II 341 MW CAPP (Summit) | IPP | 1'222+1'119 | 341 | 280 | 7206000 | FGMO | |
| 110 | Bibiana 400 MW CAPP | PDB | 400 | 400 | 401 | 9559000 | | |
| 111 | Sylhet 10MW PP (Desh) | RPP | 6'1.95 | 10 | 10 | 241380 | | |
| 112 | Bibiana South 400 MW | PDB | 400 MW | 383 | 401 | 9297800 | | |
| Sylhet Area Total | | | 2477 | 1518 | | 35037102 | | |
| 113 | Bheramara GTPP Unit-3 | PDB | 1'20 | 16 | 0 | 0 | Reserve. | |
| 114 | Bheramara (HVDC) | Imported power | 2'500 | 1000 | 893 | 21466181 | | |
| 115 | Khulna 115 PP MW (RPCL-2) | NENP | 7'17 | 115 | 16 | 103680 | Fuel shortage | |
| 116 | Fardpur 50 MW Peaking PP | PDB | 9'8.99 | 54 | 19 | 136680 | Engine problem | |
| 117 | Khulna 225 MW CAPP | NWPGCL | 1'150+1'175 | 230 | 228 | 5254080 | | |
| 118 | Gopalganj 100 MW Peaking PP | PDB | 16'6.98 | 109 | 70 | 492544 | Engine problem | |
| 119 | Bheramara 410 MW CAPP | NWPGCL | 1'278+1'132 | 410 | 245 | 4436352 | Gas shortage. | |
| 120 | Noapara 40 MW PP (Khanjahan Ali) | NENP | 5'8.5 | 40 | 0 | 0 | Fuel shortage | |
| 121 | Noapara 100 MW PP (Bangla Trac) | IPP | 70'1.4 | 100 | 70 | 1452480 | Engine problem | |
| 122 | Rupsha 108 MW PP (Orion rupsha) | IPP | 6'18.445 | 105 | 17 | 268320 | Fuel shortage | |
| 123 | Madhumati 100 MW PP | NWPGCL | 6'18 | 105 | 67 | 803520 | Fuel shortage | |
| 124 | Mongla Orion 100 MW Solar PP | IPP | 100 | 100 | 0 | 522720 | | |
| 125 | Khulna 330 MW CAPP (OIL) | BPDB | 1'220+1'110 | 0 | 0 | 0 | On test. | |
| 126 | Rampal 1320 MW (BIFPCL) | NTPC&BPDB | 0 | 0 | 0 | 0 | | |
| Khulna Area Total | | | 2384 | 1622 | | 34939557 | | |
| 127 | Barisal 110 MW PP (Summit) | IPP | 7'17.076 | 110 | 48 | 591936 | Line O/L | |
| 128 | Bhola 33 MW PP (Venture) | NENP | 1'34.50 | 40 | 26 | 977740 | Engine problem | |
| 129 | Bhola 225 MW CAPP | PDB | 2'63+1'69 | 194 | 152 | 3591435 | Gas shortage | |
| 130 | Bhola 95 MW PP (Aggroko) | ORPP | 96'11.00 | 0 | 0 | 0 | Contract Expired | |