

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022		Day : Wednesday				Date : 24.08.22						
Probable Maximum Demand :		14200 MW				Probable Maximum Generation : 14033 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday =		94.95 ft		Today =		95.15 ft		Rule Curve = 96.04 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.08.22 (Yesterday)		24.08.22 (Today)		23.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:												
Day Evening Day Evening												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	87	91	91	91			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	275	352	250	250			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	270	270	270			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	399	391	390	390			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	170	140	160	200			
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	8	32		70	Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	0	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	39	24	40			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	35	105			
22	Kodda 150MW PP	HFO (BRPger)	9x17.06	149	149	16	126	16	126			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	26	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	211	277	110	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	143	16	149			
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	204	225	225			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	90	50	90			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	91	80	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	54	17	54		50	Fuel Oil Shortage
32	Manikganj 162MW PPI(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	32	7	40		68	Fuel Oil Shortage
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	16	25	0	25		75	Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2830	3432	2583	3478	808	660		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	152	150	150			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	110	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	38	25	38			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	87	69	105			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	87	178	85	178			
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	10	10	10	10		90	Fuel Oil Shortage
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		51	Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	42	40	40		56	Fuel Oil Shortage
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			0	31	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	10	94	12	95			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	10	10	10	10		90	Fuel Oil Shortage
56	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10		90	Fuel Oil Shortage
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total			2442	2382	804	1102	862	1106	377	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	39	40	40			
60	Ashuganj 225 MW CAPP	Gas (AFSCL)	1x142+1*75	221	221	206	209	210	210			
61	Ashuganj 450 MW CAPP(South)	Gas (AFSCL)	1x360	360	360	270	305	300	305			
62	Ashuganj 450 MW CAPP(North)	Gas (AFSCL)	1x361	360	360	280	320	300	320			
63	Ashuganj 420 MW CAPP(East) GT	Gas (AFSCL)	1x284	284	284	0	0	0	0			On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8		187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	138	125	140			
68	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	42	42	42			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	143	143	143	143			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	179	100	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8		44	Fuel Oil Shortage
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	18	18	18			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14+6x11.019+1x11.086	200	200	185	170	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	58	28	110		55	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	97	96	96			
**	Impoport (Tripura)	India		160	160	154	164	143	165			
Cumilla Zone Total			3193	3169	1842	2111	1873	2314	286	0		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	80	107	100	105		95	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	0	0			
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	99	50	100			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	96	125	57	125			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	5	12	12	12			
Mymensingh Zone Total			622	614	313	343	271	342	95	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.08.22 (Yesterday)		24.08.22 (Today)		23.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut-down (MW)		Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	60	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	193	193	190	190				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8		17	Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	280	280				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	401	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	401	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6	6		44	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage	
Sylhet Zone Total					2522	2477	1442	1518	1442	1512	131	680	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	245	250	250		165	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	18	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	30	70		39	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	213	226	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	64	70	50	93				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17		88	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	67				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
115	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	16	16	16		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0		40	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	886	893	910	910				
Khulna Zone Total					2388	2384	1408	1622	1613	1698	392	39	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	32	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	26	20	30				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	151	152	100	151				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1070	1160	1170	1170				
121	Potuaikhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	5	8	0	0				
Barishal Zone Total					1958	1958	1261	1394	1322	1416	0	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	120	120	120	170		18	Turbocharger problem	
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	31	0	40				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	35	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	174	205	200	200				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	218	220	220	220		220	Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	191	190	190				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	293	414	410	410				
135	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2129	2129	1146	1667	1401	1713	391	54	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	82	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x.2'3	113	113	56	91	55	90				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Hajpara, Talia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	34	0	34				
Rangpur Zone Total					800	720	387	457	393	454	0	85	
Sub-total: Plants in operation					22058	21680	11433.0	13646	11760	14033	2480	2073	
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95		0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51		0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108		0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100		0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20		0	0	0	0			Contract Expired on 12/1/2020	
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50		0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22482	21680	11433	13646	11760	14033	2480	2073	
(C) Actual data of 23.08.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14200 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13605 MW, at =	21:00 hrs		Demand	Supply	Load Shed	Zone				
03.	Highest Generation (Generation end)	:	13646 MW, at =	21:00 hrs		MW	MW	MW	Demand	Supply	Load Shed		
04.	Minimum Generation (Generation end)	:	10759 MW, at =	8:00 hrs	Dhaka	4859	4774	85	Mymensingh	1242	876	366	
05.	Day-peak Generation (Generation end)	:	11433 MW, at =	12:00 hrs	Chattogram	1378	1378	0	Sylhet	485	485	0	
06.	Evening-peak Generation (Generation end)	:	13646 MW, at =	21:00 hrs	Khulna	1678	1684	0	Barishal	377	377	0	
07.	Evening Peak Load-shed (Sub-station end)	:	511 MW, at =	21:00 hrs	Rajshahi	1421	1421	0	Rangpur	844	844	0	
08.	Minimum Generation Forecast up to 8.00 hrs.	:	10752 MW, at =	5:00 hrs	Cumilla	1315	1255	60					
09.	Generation shortfall at evening peak due to :	:							Total	13605	13094	511	
a)	Gas limitation	:	2480 MW		13.	Fuel cost :			(a) Gas =	156765433 Taka	(c) Coal =	294209604 Taka	
d)	Coal supply Limitation	:	0 MW						(b) Oil =	1250321169 Taka		1701296206 Taka	
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :							
c)	Plants under shut down/ maintenance	:	2073 MW			33.9° C							
10.	Total Energy (Generation + India Import)	:	287.54 MKWh		15.	Export through East-West interconnections :							
	By Gas = 139.411 MKWh			82.331 MKWh		At evening peak-hour :							
	By Coal = 35.846 MKWh			3.553 MKWh		Maximum :							
	By Solar= 1.301 MKWh					Energy :							
11.	Total Gas Supplied	:	1075.00 MMCFD			: 0 MKWh							
(D) Forecast of 24.08.22 (Today) Wednesday :													
01.	Maximum Demand	:	14200 MW	(Generation end)	04.	Maximum Load-shed : 154 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	14033 MW	(Generation end)	05.	Total Generation : 299.21 MKWh							
03.	Reserve / Shortage	:	-167 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 33.2° C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation