

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW				
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	0	0	Under maint.	
3	Ghorasal 195 MW CCGP Unit-1	PDB	1'210	190	180	4284000		
4	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	300	7104382	Machine problem	
5	Ghorasal 78.5 MW PPI(MAX)	ORPP	2'40	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	95	2083591	Engine problem	
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.	
8	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	403	9787390		
9	Haripur 306 MW CCGP(HPL)	IPP	1'235+1'125	366	326	7810000	Machine problem	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	300	7071850	Dirty gas	
11	Meghnaghat 100 MW(IELE)	NENP	1'29.9	100	83	584640	Fuel shortage	
12	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage	
13	Madanganj 102 PPI(Summit)	NENP	6'17	102	0	0	Under maint.	
14	Madanganj 55 MW PPI(Summit)	IPP	3'17.08+1'111.3	55	55	1325740		
15	Karaniganj 100 MW PP (Powerpac)	ORPP	8'13.45	0	0	0	Contract Expired	
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	9'2.90	22	19	416200	Engine problem	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.	
18	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	93	1238000	Gas shortage	
19	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	1'29.9	100	92	623040	Engine problem	
20	Siddhirgonj 335 MW CCGP	EGCB	1'217+1'118	335	335	8037876		
21	Gagnagar 102 MW PP (Digital Power)	IPP	1'29.924	102	92	649152	Engine problem	
22	Katpott 52 MW PPI (Sinha)	IPP	1'71.9	0	0	0	Fuel shortage	
23	Karnalghat 54 MW PPI(Banco Energy)	IPP	3'18	54	54	763560		
24	Kodda 150MW PP	BPDB-RCPL	9'17.06	149	90	1558080	Engine problem	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	870592		
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	924754		
27	Bosila 108MW PPI(CLO)	IPP	12'8.775+1'3.5	0	0	0		
28	Summit Power (Madhabad-Ashulia)	SIPP, REB	33.67+4'8.73	80	51	1189140	Engine problem	
29	Maona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	750600		
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	30	683800		
31	Gazipur 52 MW PP	RCPL	6'8.9	52	40	371040	#REF!	
32	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	276	6428289	Engine problem	
34	Keraniganj 300 MW PP (APR)	IPP	2'50'1.4	300	101	2743891	Engine problem	
35	Brambaraganj 100 MW PP (Aggreko)	IPP	11'40.959	100	90	1506828	Engine problem	
36	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	1295478	Engine problem	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	3618576		
38	Gazipur 100 MW PP	RCPL	6'17.5	105	105	1132200		
39	Meghnaghat 104 MW PP (OPOL)	IPP	18.5'6	104	90	632640	Fuel shortage	
40	Manikganj 162MW PPI(MPL)	IPP	9'18	162	162	1967040		
41	Specia Solar Plant Ltd	IPP	35	35	0	256907		
42	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	1303200		
Dhaka area Total				5847	3859	79016406		
43	Chattogram TPP-1	PDB	1'210	180	110	2600000	Machine problem	
44	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
45	Raizant 25 MW PP	RCPL	3'8.9	25	25	617815		
46	Teknaf 20MW PPI (Solartech)	IPP	2'0	20	0	137970		
47	Kaptai 50 MW PP (Baraka)	IPP	8'9.98	50	39	681600	Engine problem	
48	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	150	3377290	Low water level	
49	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.	
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.	
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1983854		
52	Hathazari 100 MW peaking PP	PDB	11'9.9	98	34	756384	Fuel shortage	
53	Dahazari 100 MW Peaking	PDB	8'17	102	85	591580	Fuel shortage	
54	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	254400	Fuel shortage	
55	Juidah 100 MW Unit-3 (Acorn)	IPP	8'13.5	100	10	266880	Fuel shortage	
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	389520	Engine problem	
57	Malancha, Ctg. EPZ (United)	*	5'8.73+3'9.34	0	29	516480		
58	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	95	504000	Engine problem	
59	Kaptai 7 MW Solar PP	PDB	7.4	7	0	35841		
60	Aniwa 300 MW PP (United)	IPP	17'1+24	300	52	1289000	Fuel shortage	
61	Jodica Power	IPP	3'18.55+1'3.6	54	34	548408	Engine problem	
62	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	92	2496535	Engine problem	
63	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	251520	Engine problem	
64	Aniwa Energy Ltd.	IPP	6'21.2	116	107	2559273	Engine problem	
65	Mirsharai 150 MW	BPDB-RCPL	18.5'9	0	0	18400	On test.	
Chattogram area Total				2382	1003	19855160		
66	Ashuganj TPP Unit-3	APSCl	1'150	0	0	0	Contract Expired	
67	Ashuganj TPP Unit-4	APSCl	1'150	0	0	0	Contract Expired	
68	Ashuganj TPP Unit-5	APSCl	1'150	134	0	0	Gas shortage	
69	Ashuganj 225 MW CCGP	APSCl	1'142+1'175	221	207	4995000	#REF!	
70	Ashuganj 450 MW CCGP(North)	APSCl	1'360	360	310	8030000	Gas shortage	
71	Ashuganj 450 MW CCGP(South)	APSCl	1'360	360	305	7487000	FGMO	
72	Ashuganj 425 MW CCGP(East)	APSCl	2841+136'1	0	284	0	On test.	
73	Ashuganj 50 MW PP	APSCl	14'3.968	45	24	842616	Engine problem	
74	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	55	1295520		
75	Ashuganj 195MW PP (APSCl-United)	IPP	20'9.73+1'16	195	8	217454	Gas shortage	
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1194034		
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	140	3159781	Engine problem	
78	Titas 50 MW Peaking PP	PDB	6'9.82	52	38	993120	Engine problem	
79	Chandpur 150 MW CCGP	PDB	11'08+1'57	163	0	2601120	Tripped at 18:36	
80	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	160	2356800	Line O/L	
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	498600		
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	226440		
83	Impoport (Tripura)	Imported power	0	160	168	3418560		
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	604600	Engine problem	
85	Jangalia 15 MW PP (Lakshreev)	IPP	6'8.92	52	8	52906	Fuel shortage	
86	Camilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	18	402120	Engine problem	
87	Daudkandi 200 MW PP (B.Trac)	IPP	15'41.4	200	194	2882880	Engine problem	
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	79800	Fuel shortage	
89	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	111	1813560	Engine problem	
90	Bharadwaj 54.5 MW	IPP	3'18.2	54	35	888480	33 KV feeder problem.	
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	98	2085320	Engine problem	
Cumilla Area Total				3169	2002	46131511		
92	RCPL 210MW CCGP	IPP	4'35+1'70	202	107	2130240	Gas shortage	
93	Tangali 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage	
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.	
95	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14650		
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	97	2329000	Fuel shortage	
97	Jamalpur 15 MW PP (United)	IPP	9'78'12	115	108	2554800	Engine problem	
98	Sutarkhal 50 MW Solar PP	IPP	50	50	0	359550		
99	Tangali Pali Power Gen 22 MW	IPP	4'6.7	22	12	282480	Engine problem	
Mymensingh Area Total				614	324	7670120		
100	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	43	1022000	Machine problem	
101	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	42	947570	Machine problem	
102	Kushnara 163 MW CCGP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage	
103	Shajibazar 330 MW CCGP	PDB	3'110	330	0	0	Under maint.	
104	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	5	130200	Gas shortage	
105	Fenchugonj 44MW (Energyptima)	NENP	12'3.3+5'2	50	0	0	Gas shortage	
106	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	Engine problem	
107	Shahibazar GTPP Unit-8 & 9	PDB	2'35	66	61	1397664		
108	Shahibazar 98MW PP (Shahibazar)	RPP	32'2.90	86	81	781440		
109	Shahibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.	
110	Sylhet 225 MW CCGP	PDB	1'142+1'189	231	194	4586220	Machine problem	
111	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage	
112	Sylhet 50MW PP (EPL)	NENP	27'2	50	6	166020	Gas shortage	
113	Shahajanulla 25 MW PP	SIPP, REB	3'9.34	25	8	110880	Gas shortage	
114	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	270	7085000	FGMO	
115	Bibiana-I 400 MW CCGP	PDB	400	400	403	8696000		
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	244440		
117	Bibiana South 400 MW	PDB	400 MW	383	401	9474300		
Sylhet Area Total				2477	1524	35551734		
118	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.	
119	Bheramara (HVDC)	Imported power	2'500	1000	892	21449454		
120	Khulna 115 MW PP (RCPL-2)	NENP	7'17	115	16	102720	Fuel shortage	
121	Fariapur 50 MW Peaking PP	PDB	9'8.99	54	32	151200	Engine problem	
122	Khulna 225 MW CCGP	NWVGCL	1'150+1'175	230	224	4776000		
123	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	58	619520	Engine problem	
124	Bheramara 410 MW CCGP	NWVGCL	1'278+1'132	410	255	6471936	Gas shortage.	
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	70	491520	Engine problem	
127	Rushda 116 MW PP (Orion rushda)	IPP	6'18.445	105	17	151920	Fuel shortage	
128	Madhumati 100 MW PP	NWVGCL	6'18	105	50	593280	Fuel shortage	
129	Mongla Orion 100 MW Solar PP	IPP	100	100	0	699840		
130	Khulna 330 MW CCGP (OIL)	BPDB	1'220+1'110	0	0	0	On test.	
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0		
Khulna Area Total				2384	1614	35513390		
132	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	48	486528	Line O/L	
133	Bhola 33 MW PP (Venture)	NENP	1'34.90	40	29	486758		