

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022		Day : Sunday				Date : 04.09.22							
Probable Maximum Demand :		13900 MW				Probable Maximum Generation :				14301 MW			
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 96.22 ft				Today = 96.19 ft				Rule Curve = 99.69 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.09.22 (Yesterday)		04.09.22 (Today)		03.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation MW	(Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)	Evening	Probable Peak Generation (MW)	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	200	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	66	87	90	90	21	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	293	223	200	200	137	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	402	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	337	310	300	300				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	130	120	120	205	Gas Shortage		
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	50	92				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	0	19	20	20				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIIP, REB)	6x6.77+7x8.73	80	80	45	49	51	51				
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	15	14	21	21				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	41	16	41				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	100	34	100				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	81	95	17	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	193	230	260	270				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	149	90	130				
26	Kerangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	52	50	220	220				
27	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	65	93	55	93				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	35	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	18	18	18	18	37	Fuel Oil Shortage		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	62	90	62	90				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	49	83	50	85				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847		3226	3564	3191	3775	835	670		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	150	150	150		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	25	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	69	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52	248	Fuel Oil Shortage		
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	32	90	10	90				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	13	47	17	47	55	Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	26	26	26				
51	Barakunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	22	10	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	88	11	86				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	100	30	100				
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	78	30	80				
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	102	107	107	107				
Chattogram Zone Total			2442	2382		843	1196	859	1199	303	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	48	43	50				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	183	205	180	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	305	270	305				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	320	285	320				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	55	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	37	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	140	130	140				
68	Titras 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	25	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	30	90	80	90				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	200	17	200				
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	19	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	25	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44	Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	14	20	20	20				
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+6x1.515+15x1.088	200	200	60	50	100	190				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0	114	Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	101	116	105	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	96	55	96				
**	Impoport (Tripura)	India		160	160	144	150	143	165				
Cumilla Zone Total			3193	3169		1450	1967	1649	2128	345	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	104	80	100	98	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	113	105	78	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	76	97	87	95				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total			622	614		312	318	309	322	120	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.09.22 (Yesterday)		04.09.22 (Today)		03.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41			49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	26	0	20	40					
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	0	11	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	60	64					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	78	78	50	81					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	186	186	0	0					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	0	20	20					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	0	23	23	23			2	Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	300	300					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	402	290	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	399	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	0	25	25			50	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	48	0	20	40			50	Gas Shortage	
Sylhet Zone Total				2522	2477	1325	1567	1313	1498	102	669			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	215	210	210	210			200	Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	50	0	50					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	60					
110	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	138	221	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	20	94					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	75	35	75					
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	15	15	15	15					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	100	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			115	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	0			40	Fuel Oil Shortage	
**	Bheramara (HVDC) India			1000	1000	895	896	915	915					
Khulna Zone Total				2388	2384	1416	1537	1520	1644	355	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	31	20	30					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	84	85	85			110	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1020	1000	1170					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				Line Overload	
122	Bhola 220MW CCPP (Nutan Bidytj BD Ltd)	Gas/HSD	2x75+1x70	220	220	216	223	220	220					
Barishal Zone Total				1958	1958	1194	1390	1357	1554	110	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage	
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	30	60	165					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	25					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	84	0	80					
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24			26	Under maint.	
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	205	206	190	206					
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	166	217	220	220			220	Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	201	196	190	200					
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	419	355	414					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	22	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	8	8	8					
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52					
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	47	94	50	94					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total				2129	2129	1109	1536	1164	1669	391	62			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80					
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250					
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	50	90	55	92					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	0	90					
Intraco Solar 30 MW						33	0	12	0					
Rangpur Zone Total				800	720	417	509	405	512	0	85			
Sub-total: Plants in operation				22058	21680	11292.0	13584	11767	14301	2561	2041			
(B) Plants under long term maintenance/ contract expired														
148	Jamrapur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0					
Gross Total				22482	21680	11292	13584	11767	14301	2561	2041			
(C) Actual data of 03.09.22 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	13762 MW.	at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13262 MW.	at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13584 MW.	at =	19:30 hrs	Dhaka	4938	4864	74	Mymensingh	1031	941	90	
04.	Minimum Generation (Generation end)	:	10129 MW.	at =	8:00 hrs	Chattogram	1245	1245	0	Sylhet	509	509	0	
05.	Day-peak Generation (Generation end)	:	11292 MW.	at =	12:00 hrs	Khulna	1667	1667	0	Barishal	401	401	0	
06.	Evening-peak Generation (Generation end)	:	13584 MW.	at =	19:30 hrs	Rajshahi	1386	1386	0	Rangpur	815	815	0	
07.	Evening Peak Load-shed (Sub-station end)	:	164 MW.	at =	19:30 hrs	Cumilla	1270	1270	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10301 MW.	at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:								Total	13262	13098	164	
	a) Gas limitation	:	2561 MW			13.	Fuel cost :	(a) Gas = 163241908 Taka	(c) Coal = 269905187 Taka					
	d) Coal supply Limitation	:	0 MW				(b) Oil = 1104481203 Taka	Total = 1537628297 Taka						
	b) Low water level in Kapali lake	:	0 MW											
	c) Plants under shut down/ maintenance	:	2041 MW			14.	Maximum Temperature in Dhaka was :	33.8° C						
10.	Total Energy (Generation + India Import)	:	283.86 MKWh			15.	Export through East-West interconnections :							
	By Gas =	143.431 MKWh	By Oil =	77.615 MKWh			At evening peak-hour	: 11292 MW.	at	19:30 hrs				
	By Coal =	33.148 MKWh	By Hydro =	3.664 MKWh			Maximum	: 960 MW.	at	19:30 hrs				
	By Solar =	1.104 MKWh					Energy	: 0 MKWh						
11.	Total Gas Supplied	:	1073.20 MMCFD											
(D) Forecast of 04.09.22 (Today) Sunday :														
01.	Maximum Demand	:	13900 MW	(Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14301 MW	(Generation end)		05.	Total Generation	:	290.46 MKWh					
03.	Reserve / Shortage	:	401 MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		33.2° C					

* Captive Power ** Incoined Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation