

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022			Day : Sunday				Date : 11.09.22							
Probable Maximum Demand :			13800 MW				Probable Maximum Generation :				14127 MW			
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 96.00 ft				Today = 95.98 ft				Rule Curve = 101.30 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.09.22 (Yesterday)		11.09.22 (Today)		10.09.22 Gen. shortfall for : Gas/Coal/Water Limitation MW	(Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks Probable start-up date			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	200	200	200	200	190	Under maint.			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	260	260	260					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	82	82	85	85	26	Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	222	162	200	200	198	Gas Shortage			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	366	380	380					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	283	244	250	250	91	Gas Shortage			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	128	130	130	207	Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	65	64	65					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	22	22	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIIP, REB)	6x3.67+7x3.73	80	80	47	49	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	7	6	8	8					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	43	40	43					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	77	64	65	65					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	97	16	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	269	275	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	146	149	149					
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	220	225	150	225					
27	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90					
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	55	17	55					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0	55	Fuel Oil Shortage			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	64	24	64					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	24	56	24	56					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	3116	3422	3031	3531	1012	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	149	148	150	150		Unit 1 under rehabilitation			
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	105	105	105	105	180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	38	0	38					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	70	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing			
47	Anwara 300 MW PP (Unitec)	HFO (IPP)	17x17.076+3x8.04	300	300	214	214	214	214	86	Fuel Oil Shortage			
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	32	90	33	90					
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	11	51	51	Fuel Oil Shortage			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	20	23	24	24					
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	10	13	13	13					
*	Malancha, Ctg EPZ (Unitec)	Gas	5x8.73+3x9.34			10	18	7	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	5	5	5	5	103	Fuel Oil Shortage			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105					
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	100	38	100					
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	95	33	95					
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
Chattogram Zone Total			2442	2382	922	1278	1001	1283	240	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	45	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	204	204	205	205	206				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	335	345	320	330					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	200	200	360	Under maint.			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	140	150	40	40	45	Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	137	135	135					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	35	35	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	31	82	82					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	85	17	85					
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	0	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	25	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	21	9	21	21					
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.286	200	200	170	50	150	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17	97	Fuel Oil Shortage			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	97	115	105	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	104	35	115					
**	Impoport (Tripura)	India		160	160	136	150	143	166					
Cumilla Zone Total			3193	3169	1512	1691	1746	2011	142	360				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	73	100	80	100	102	Gas Shortage			
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage			
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	99	98	99	99					
84	Myensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	86	107	87	107					
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Myensingh Zone Total			622	614	320	317	330	318	124	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.09.22 (Yesterday)		11.09.22 (Today)		10.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	MW	MW				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41			49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0						
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	62	62						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	50	80	81	81						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	220	220	220						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	17	18	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	310	320						
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400						
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	396	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0			50	Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0			50	Gas Shortage		
Sylhet Zone Total				2522	2477	1513	1569	1585	1595			100	669		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	240	290	280	280			120	Gas Shortage		
108	Fairidpur 80 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	50						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	68						
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	226	225	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	90	90						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	35	70						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0						
115	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	0	0	0			115	Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0			40	Fuel Oil Shortage		
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	903	902	906	906						
Khulna Zone Total				2388	2384	1389	1637	1651	1739			275	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	48						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	29	22	31						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	86	85	85			108	Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	1040	1110	1110						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	219	225	220	220						
Barisal Zone Total				1958	1958	1159	1412	1469	1511			108	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24			18	Turbocharger problem		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	30	60	164						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	81						
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32			18	Under maint.		
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42			24	Fuel Oil Shortage		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26			24	Under maint.		
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	160	205	190	205						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	190	218	220	220			220	Running on HSD		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	160	185	190	190						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	418	414	414						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8			44	Fuel Oil Shortage		
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	95	55	95						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	50	94						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0						
Rajshahi Zone Total				2129	2129	1034	1487	1280	1624			459	60		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	78	81	83						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	249	250	250						
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	90	55	92						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0						
147	Thakurganj 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	90	0	90						
	Intraco Solar 30 MW	Solar (IPP)				21	0	12	0						
Rangpur Zone Total				800	720	386	507	406	515			0	85		
Sub-total: Plants in operation				22058	21680	11351.0	13320	12499	14127			2460	2399		
(B) Plants under long term maintenance/ contract expired															
148	Jalmalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
149	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
150	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0						
Gross Total				22482	21680	11351	13320	12499	14127			2460	2399		
(C) Actual data of 10.09.22 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	13560	MW, at =	20:00 hrs	12	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13021	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	13320	MW, at =	20:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	:	10634	MW, at =	8:00 hrs	Dhaka	4778	4702	76	Mymensingh	1130	985	145		
05.	Day-peak Generation (Generation end)	:	11351	MW, at =	11:00 hrs	Chattogram	1188	1188	0	Sylhet	440	440	0		
06.	Evening-peak Generation (Generation end)	:	13320	MW, at =	20:00 hrs	Khulna	1605	1605	0	Barisal	369	369	0		
07.	Evening Peak Load-shed (Sub-station end)	:	221	MW, at =	20:00 hrs	Rajshahi	1395	1395	0	Rangpur	898	898	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10443	MW, at =	5:00 hrs	Cumilla	1219	1219	0						
09.	Generation shortfall at evening peak due to :	:								Total	13021	12800	221		
a)	Gas limitation	:	2460	MW						(e) Gas =	160569244	Taka	(c) Coal =	267293523	Taka
d)	Coal supply Limitation	:	0	MW						(b) Oil =	1219098679	Taka	Total =	1646961446	Taka
b)	Low water level in Kapli lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	2399	MW						14.	Maximum Temperature in Dhaka was :	34.9° C			
10.	Total Energy (Generation + India Import)	:	288.25	MKWh						15.	Export through East-West interconnections :				
	By Gas =	141.476	MKWh	By Oil =	83.581	MKWh				At evening peak-hour	:	11351			