

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month September, 2022		Day: Monday				Date: 12.09.22						
Probable Maximum Demand :		13300 MW				Probable Maximum Generation : 14257 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 95.98 ft				Today = 96.08 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.09.22 (Yesterday)		12.09.22 (Today)		Rule Curve = 101.30 ft	11.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)			Gen. shortfall for :		
					Day	Evening	Day	Evening		Gas/Coal/Water Limitation	Machines shut down	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	210	200	200			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	240	250	250			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	79	74	75	75	34		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	188	153	200	200	207		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	190	225	225	260		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	372	347	335	350	65		Gas Shortage
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	244	236	250	250	99		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	114	110	135	135	225		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	65	8	65			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIIP, REB)	6x8.97+7x8.73	80	80	48	42	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	8	6	8	8			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	50	40	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	45	84	85	85			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	17	128	16	130			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	243	258	275	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	224	150	150	225			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	70	80	90			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	55	17	55			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	21	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0	55		Fuel Oil Shortage
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	7	64	8	64			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	57	7	56			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2907	3245	2924	3513	1155	670		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	148	150	150			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	100	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	21	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	38	25	38			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	70	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI Ongoing
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	213	214	214	214	86		Fuel Oil Shortage
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	34	90	33	90			
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	11	51	51		Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	24	24	24			
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			13	5	12	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	5	5	5	5	103		Fuel Oil Shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105			
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	100	38	100			
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	85	33	85			
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total			2442	2382	1005	1251	1036	1278	240	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	46	45	45			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	203	197	205	205			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	280	280	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	235	130	30	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	54	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	78	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	130	135	135			
68	Titias 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	30	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	82	83	82	82			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	70	17	85			
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	19	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	8	30	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	18	21	21	21			
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+6x1.515+15x1.388	200	200	155	115	150	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	52	17	114	62		Fuel Oil Shortage
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	97	116	97	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115			
**	Impoport (Tripura)	India		160	160	132	156	143	166			
Cumilla Zone Total			3193	3169	1764	1773	1496	2176	249	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	103	80	100	99		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	98	99	99			
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	107	87	107			
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Myensingh Zone Total			622	614	338	320	330	318	121	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.09.22 (Yesterday)		12.09.22 (Today)		11.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	MW	MW				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41			49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0						
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	50	80	81	81						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0						
100	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	310	320						
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	399	401	400	400						
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0			50	Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	0	0	0	0			50	Gas Shortage		
Sylhet Zone Total				2522	2477	1530	1564	1585	1595	100	669				
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	265	250	260	260			160	Gas Shortage		
108	Fairpur 80 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	50						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	68						
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	130	228	130	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	90	90						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	35	70						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	17	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			115	Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0			40	Fuel Oil Shortage		
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	889	889	914	914						
Khulna Zone Total				2388	2384	1333	1571	1544	1727	315	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	48						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	24	22	31						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	85			108	Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	990	1110	1110						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				Line Overload		
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	224	221	220	220						
Barishal Zone Total				1958	1958	1148	1353	1469	1511	108	0				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24			18	Turbocharger problem		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	60	164						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	74	0	81						
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32			18	Under maint.		
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	26			18	Under maint.		
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	196	189	190	205						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	190	210	220	220			220	Running on HSD		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	183	175	190	190						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			44	Fuel Oil Shortage		
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	2	95	55	95						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	94	50	94						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0						
Rajshahi Zone Total				2129	2129	1019	1418	1280	1624	435	54				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	78	81	83						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250						
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	92	55	92						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	72	0	90						
	Intraco Solar 30 MW	Solar (IPP)				32	0	12	0						
Rangpur Zone Total				800	720	425	492	406	515	0	85				
Sub-total: Plants in operation				22058	21680	11469.0	12987	12070	14257	2723	2033				
(B) Plants under long term maintenance/ contract expired															
148	Jalmalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
149	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
150	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0	0	0				
Gross Total				22482	21680	11469	12987	12070	14257	2723	2033				
(C) Actual data of 11.09.22 (Yesterday) Sunday :															
01.	Max. Demand at eve. peak (Generation end)	:	13264	MW, at =	20:00 hrs	12	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12734	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	12987	MW, at =	20:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	10443	MW, at =	8:00 hrs	Dhaka	4619	4619	0	Mymensingh	1152	897	255		
05.	Day-peak Generation (Generation end)	:	11469	MW, at =	12:00 hrs	Chattogram	1298	1298	0	Sylhet	546	546	0		
06.	Evening-peak Generation (Generation end)	:	12987	MW, at =	20:00 hrs	Khulna	1402	1402	0	Barishal	341	341	0		
07.	Evening Peak Load-shed (Sub-station end)	:	255	MW, at =	20:00 hrs	Rajshahi	1304	1304	0	Rangpur	857	857	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9578	MW, at =	5:00 hrs	Cumilla	1215	1215	0						
09.	Generation shortfall at evening peak due to :	:								Total	12734	12479	255		
	a) Gas limitation	:	2723	MW						(e) Gas =	158411598	Taka	(c) Coal =	253627516	Taka
	d) Coal supply Limitation	:	0	MW						(b) Oil =	1173920530	Taka	Total =	158959644	Taka
	b) Low water level in Kaptai lake	:	0	MW											
	c) Plants under shut down/ maintenance	:	2033	MW						14.	Maximum Temperature in Dhaka was : 32.5° C				
10.	Total Energy (Generation + India Import)	:	281.14	MKWh						15.	Export through East-West interconnections :				
	By Gas =	139.858	MKWh	By Oil =	80.660	MKWh				At evening peak-hour	11469	MW, at	20:00 hrs		
	By														