

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Friday				Date : 16.09.22							
Probable Maximum Demand : 12400 MW				Probable Maximum Generation : 14283 MW											
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.43 ft				Today = 96.57 ft				Rule Curve = 102.45 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.09.22 (Yesterday)		16.09.22 (Today)		15.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation (MW)	16.09.22 (Today) Gen. shortfall for : Gas/Coal/Water Limitation (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date		
					Actual Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	200	200	200						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	250	300	300						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	62	62	40	76	46		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	175	140	200	200	220		Gas Shortage			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	175	200	200	275		Gas Shortage			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	365	326	340	350						
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	220	0	0	115		Gas Shortage			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	120	103	135	135	232		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	9	16	90						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	22	22	22	22						
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIIP, REB)	6x8.97+7x8.73	80	80	45	45	45	45						
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	25	33	33	33						
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	6	6	8	8						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	49	25	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	87	105	105	105						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	115	17	115						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	165	255	260	285						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	121	149	149	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	54	21	150	225						
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	25	50	90						
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	25	75	75						
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	45	35	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	17	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	38	93	50	90						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162						
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0						
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	60	8	60						
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	41	7	40						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0						
Dhaka Zone Total				6004	5847	2613	3038	2661	3379	1098	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	148	149	146	149			Unit 1 under rehabilitation			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	0	110	110						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	43	25	44						
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	87	17	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI Ongoing			
47	Anwara 300 MW PP (Unitec)	HFO (IPP)	17x17.076+3x8.04	300	300	268	300	200	300						
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	34	76	34	76						
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	24	0	25						
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	17	15	15	15						
*	Malancha, Ctg EPZ (Unitec)	Gas	5x8.73+3x9.34			9	23	10	30						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel Oil Shortage			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36						
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	82	105	105	105						
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	90	38	90						
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	78	10	78						
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	88	106	107	107						
Chattogram Zone Total				2442	2382	1019	1208	920	1346	108	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0						
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	44	44	44						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	191	206	175	200						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	250	280	300	300						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	360	330	300	330						
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284		Gas Shortage			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	55	55	55						
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	143	100	143						
68	Titias 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	30	0	30						
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	82	83	83						
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	158	200	100	200						
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	19	19	19	19						
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	8	8	10	10						
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	8	25	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	6	42	8	42						
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	16	21	21	21						
76	Dauckandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.6+40x1.55+15x1.596	200	200	30	20	150	190						
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	66	99	17	114						
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	108	115	97	113						
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	115	35	115						
**	Impoport (Tripura)	India		160	160	120	146	143	165						
Cumilla Zone Total				3193	3169	1727	2039	1766	2283	471	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	73	70	70	129		Gas Shortage			
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage			
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	107	107	100	100						
84	Myensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	142	142	80	140						
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0						
86	Sutiali 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0						
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	12	12	12	12						
Myensingh Zone Total				622	614	365	334	314	322	151	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.09.22 (Yesterday)		16.09.22 (Today)		15.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance						
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date					
					Day	Evening	Day	Evening	MW	(MW)							
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	1x9.2.90	51	51	5	5	5	5	46		Gas Shortage					
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	63	63	63								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	30	81	10	81								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220								
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	8	8	25		Gas Shortage					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	280	300								
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	401	400	400								
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400								
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6	6	44		Gas Shortage					
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	5	5	5	5	45		Gas Shortage					
Sylhet Zone Total					2522	2477	1485	1574	1510	1601	171	669					
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
107	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	240	240	200	200	170		Gas Shortage					
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	43								
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60								
110	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	120	227	130	225								
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	96								
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	17	56								
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	32	50	15	50								
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	41	0	100	0								
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	18	32	16	32	83		Fuel Oil Shortage					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage					
	Rampal 1320 MW	Coal (BIFFCL)				0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	900	902	920	920								
Khulna Zone Total					2388	2384	1368	1550	1448	1682	293	0					
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	26	20	25								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	87	87	87	107		Gas Shortage					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	670	750	1110	1110								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	223	220	220								
Barishal Zone Total					1958	1958	969	1118	1453	1491	107	0					
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	25	18		Turbocharger problem					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.8	200	200	0	0	0	160								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	84	0	84								
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	32	16	32	18		Under maint.					
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	0	42								
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33	17		Under maint.					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	195	189	170	190								
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	130	130	130	220	220		Running on HSD					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	172	160	170	170	60		Gas Shortage					
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	360	414	414	54		Gas Shortage					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18								
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43								
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	60	95	55	95								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	37	113	50	113								
141	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	4	0	6	0								
Rajshahi Zone Total					2129	2129	1063	1290	1087	1647	505	53					
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	75	72	75								
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under overhauling					
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250								
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	55	113								
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
148	Maipon, Taluka 8 MW Solar PP (Gympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0								
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	34	94	0	94			Contract Expired on 12/11/2020					
150	Lalmohanali 30 MW Solar (Itraco)	Solar (IPP)	1'30	30	30	6	0	12	0			Contract Expired on 11/01/2022					
Rangpur Zone Total					830	750	294	532	397	532	0	85					
Sub-total: Plants in operation					22088	21710	10903.0	12683	11556	14283	2904	2032					
(B) Plants under long term maintenance/ contract expired																	
151	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
152	Katpilit 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
153	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
154	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
155	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0								
156	Amshura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0					
Gross Total					22512	21710	10903	12683	11556	14283	2904	2032					
(C) Actual data of 15.09.22 (Yesterday) Thursday :																	
01.	Max. Demand at eve. peak (Generation end)	:	12683	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12252	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	12683	MW,	at =	19:30	hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	8864	MW,	at =	6:00	hrs	Dhaka	4733	4733	0	Mymensingh	926	926	0		
05.	Day-peak Generation (Generation end)	:	10903	MW,	at =	12:00	hrs	Chattogram	1281	1281	0	Sylhet	525	525	0		
06.	Evening-peak Generation (Generation end)	:	12683	MW,	at =	19:30	hrs	Khulna	1359	1359	0	Barishal	334	334	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Rajshahi	1155	1155	0	Rangpur	777	777	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9123	MW,	at =	5:00	hrs	Cumilla	1162	1162	0						
09.	Generation shortfall at evening peak due to :	:										Total	12252	12252	0		
a)	Gas limitation	:	2904	MW								(a) Gas =	158001095	Taka	(c) Coal =	199174528	Taka
d)	Coal supply Limitation	:	0	MW								(b) Oil =	929270526	Taka	Total =	1286446148	Taka
b)	Low water level in Kaplai lake	:	0	MW													
c)	Plants under shut down/ maintenance	:	2032	MW													
10.	Total Energy (Generation + India Import)	:	261.85	MKWh													
	By Gas =	140.039	MKWh		By Oil =	67.872	MKWh										
	By Coal =	24.742	MKWh		By Hydro =	3.551	MKWh										
	By Solar =	0.969	MKWh														
11.	Total Gas Supplied	:	1055.03	MKWh													
(D) Forecast of 16.09.22 (Today) Friday :																	
01.	Maximum Demand	:	12400	MW	(Generation end)												
02.	Maximum Generation	:	14283	MW	(Generation end)												
03.	Reserve / Shortage	:	1883	MW	(Generation end)												
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)												
05.	Total Generation	:	256.01	MKWh													
06.	Probable Max. Temperature in Dhaka :	:	32.1 ° C														

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation