

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month September, 2022		Day : Saturday				Date : 17.09.22						
Probable Maximum Demand :		13400 MW				Probable Maximum Generation : 14561 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 96.57 ft				Today = 96.68 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.09.22 (Yesterday)		17.09.22 (Today)		Rule Curve = 16.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation (MW)	102.68 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	200	200	230	230	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	32	32	32	32	76	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	310	222	300	330	138	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	200	225	225	250	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	402	350	412			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	132	133	135	135	202	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	90			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIIP, REB)	6x3.67+7x3.73	80	80	41	52	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	25	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	7	7	8	8			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	45	35	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	17	115	17	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	122	273	260	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	52	132	149	149			
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	150	225			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	90			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	75	75			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	1	17	50	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	60	8	60			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	41	7	40			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2293	2911	2897	3589	1211	670		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	148	150	150	150		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	110	110	110	110	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	25	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	38	105	17	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing	
47	Anwara 300 MW PP (Unitec)	HFO (IPP)	17x17.076+3x8.04	300	300	231	266	200	300			
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	33	90	34	76			
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	23	0	25			
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	15	16	15	15			
*	Malancha, Ctg EPZ (Unitec)	Gas	5x8.73+3x9.34			13	39	10	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel Oil Shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	25	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	39	105	105	105			
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	90	38	90			
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	80	33	80			
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	106	107	107	107			
Chattogram Zone Total			2442	2382	896	1312	947	1349	108	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	44	44	44			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	184	205	205	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	275	300	310			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	270	300	330			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1*54	55	55	51	54	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	26	26	169	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	45	142	100	143			
68	Titias 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	21	0	30			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	84	83	83			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	19	155	100	200			
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	19	19	19	19			
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	10	11	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	16	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	42	44	Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daukandi 200 MW PP (B.Tec)	HSD (IPP)	86x1.4+40x1.515+15x1.596	200	200	0	0	150	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	12	17	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	90	115	97	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115			
**	Impoport (Tripura)	India		160	160	112	136	143	165			
Cumilla Zone Total			3193	3169	1466	1819	1814	2311	497	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	40	100	70	100	102	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	86	106	100	100			
84	Myensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	121	152	85	152			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	30	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Myensingh Zone Total			622	614	291	370	319	364	124	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.09.22 (Yesterday)		17.09.22 (Today)		16.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening							
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage			
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	68	66	68						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	1	81	10	81						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	8	8	25		Gas Shortage			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	280	300						
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400						
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	6	6	50		Gas Shortage			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	0	0	0	0	50		Gas Shortage			
Sylhet Zone Total					2522	2477	1491	1551	1503	1596	187	669			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	260	280	260	280	130		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	43						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	53	0	60						
110	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	120	120	130	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	96						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	56	17	56						
113	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	32	15	50						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	16	49	66		Fuel Oil Shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage			
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	904	905	916	916						
Khulna Zone Total					2388	2384	1372	1539	1504	1775	236	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	32						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	20	25						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	87	87	87	107		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	880	1110	1110						
121	Potuaikali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	17			Line overload			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	184	224	220	220						
Barishal Zone Total					1958	1958	966	1247	1470	1491	107	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	25	18		Turbocharger problem			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	160						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	84						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32	18		Under maint.			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	0	42						
131	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	33	18		Under maint.			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	200	205	200	205						
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	130	130	130	130	220		Running on HSD			
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	172	175	180	185	45		Gas Shortage			
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	356	414	414	58		Gas Shortage			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18						
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	15	35	55	95						
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	6	113	50	113						
141	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	4	0	6	0						
Rajshahi Zone Total					2129	2129	978	1225	1129	1554	494	54			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	74	72	75						
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250						
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	15	113	55	113						
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
147	Maipon, Taluka 8 MW Solar PP (Gympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	34	91	0	94			Contract Expired on 12/11/2020			
149	Lalmohona 30 MW Solar (Itraco)	Solar (IPP)	1'30	30	30	24	0	12	0			Contract Expired on 11/01/2022			
Rangpur Zone Total					830	750	403	528	397	532	0	85			
Sub-total: Plants in operation					22088	21710	10156.0	12502	11980	14561	2964	2033			
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpilit 52 MW PP (Simha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3-5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
154	Aminura 30 MW PP (Simha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0			
Gross Total					22512	21710	10156	12502	11980	14561	2964	2033			
(C) Actual data of 16.09.22 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	12558	MW,	at =	20:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12112	MW,	at =	20:00	hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12515	MW,	at =	22:00	hrs	Dhaka	4306	4306	0	Mymensingh	1083	1045	38
04.	Minimum Generation (Generation end)	:	9123	MW,	at =	7:00	hrs	Chattogram	1241	1241	0	Sylhet	510	510	0
05.	Day-peak Generation (Generation end)	:	10156	MW,	at =	12:00	hrs	Khulna	1443	1443	0	Barishal	321	321	0
06.	Evening-peak Generation (Generation end)	:	12502	MW,	at =	20:00	hrs	Rajshahi	1235	1235	0	Rangpur	835	825	10
07.	Evening Peak Load-shed (Sub-station end)	:	52	MW,	at =	20:00	hrs	Cumilla	1138	1134	4				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9700	MW,	at =	5:00	hrs	Total							
09.	Generation shortfall at evening peak due to :	:										12112	12060	52	
a)	Gas limitation	:	2964	MW											
d)	Coal supply Limitation	:	0	MW											
b)	Low water level in Kaplai lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	2033	MW											
10.	Total Energy (Generation + India Import)	:	261.51	MKWh											
	By Gas =	139.879	MKWh		By Oil =	63.255	MKWh	13. Fuel cost : (a) Gas = 157927103 Taka (c) Coal = 232374168 Taka							
	By Coal =	28.919	MKWh		By Hydro =	3.381	MKWh	(b) Oil = 859463676 Taka Total = 1249764947 Taka							
	By Solar =	1.380	MKWh					14. Maximum Temperature in Dhaka was : 31.7 °C							
11.	Total Gas Supplied	:	1041.13	MKCFD				15. Export through East-West interconnections :							
								At evening peak-hour : 10156 MW, at 20:00 hrs							