

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month September, 2022				Day : Tuesday				Date : 20.09.22			
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 13785 MW				Rule Curve = 103.37 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.72 ft				Today = 96.99 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.22 (Yesterday)		20.09.22 (Today)		19.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	MW	(MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	200	230	230	230	190	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	100	90	100		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contact Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	273	252	250	250	108	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	210	225	225	240	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	406	407	390	400		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	145	140	140	190	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	92		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x1.73	80	80	46	45	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	14	24	24		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	48	32	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
22	Kodda 150MW PP	HFO (BRPger)	9x17.06	149	149	16	78	16	130		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	273	273	275	275		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	149	149	149		
26	Keeranigonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	223	183	120	180		
27	Bramhanigonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	75	90		
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	75	90		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	94	50	90		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	144	72	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	88	45	90		
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	41	80	40	80		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2769</b>	<b>3223</b>	<b>2717</b>	<b>3327</b>	<b>748</b>	<b>1370</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	151	151	151		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	110	110	110	110	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	39	40	40		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	102	105	105	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	248	275	250	275		
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	33	90	33	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	31	20	25		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			10	28	5	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel Oil Shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	27	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	84	105	88	105		
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	90	38	100		
56	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	33	78	33	80		
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1068</b>	<b>1336</b>	<b>1098</b>	<b>1335</b>	<b>108</b>	<b>555</b>	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	42	40	40		
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	200	191	180	185		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	250	250	250	250	110	Gas Shortage
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	300	280	280	280	80	Gas Shortage
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	30	20	30		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	132	140	135	140		
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	27	29	29		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	83	83	83	83		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	120	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	7	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	32	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14+6x11.019+1x11.066	200	200	188	190	150	190		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	17	34		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	115	97	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	115	35	115		
**	Impoport (Tripura)	India		160	160	72	126	143	165		
<b>Cumilla Zone Total</b>			<b>3193</b>	<b>3169</b>	<b>1776</b>	<b>2021</b>	<b>1746</b>	<b>2056</b>	<b>661</b>	<b>0</b>	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	65	99	70	100	103	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	13	14	14	9	Gas Shortage
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	87	96	97	105		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	141	151	150	150		
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>367</b>	<b>371</b>	<b>395</b>	<b>381</b>	<b>112</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.22 (Yesterday)		20.09.22 (Today)		19.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	63	60	60				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	78	78				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	17		Gas Shortage	
100	Bibiyan-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	265	280				
101	Bibiyan-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	405	402	400	400				
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	384	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
<b>Sylhet Zone Total</b>						<b>2522</b>	<b>2477</b>	<b>1473</b>	<b>1563</b>	<b>1467</b>	<b>1550</b>	<b>179</b>	<b>669</b>
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	225	230	230	185		Gas Shortage	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	35				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	40				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	180	227	150	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	10	94	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	55	17	55				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	60				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	97	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	16	32	83		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
**	Bheramara (HVDC) India			1000	1000	885	891	918	918				
<b>Khulna Zone Total</b>						<b>2388</b>	<b>2384</b>	<b>1435</b>	<b>1663</b>	<b>1496</b>	<b>1690</b>	<b>308</b>	<b>0</b>
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	0	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	16	25				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	83	86	85	85	108		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	890	1080	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	214	224	220	220				
<b>Barishal Zone Total</b>						<b>1958</b>	<b>1958</b>	<b>1222</b>	<b>1450</b>	<b>1448</b>	<b>1489</b>	<b>108</b>	<b>0</b>
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	20	90	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	81				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	42				
130	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.	
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	187	180	180	180				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	165	216	150	210	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	158	154	150	150	66		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	334	260	300	80		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	76	95	50	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	108	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
<b>Raishahi Zone Total</b>						<b>2129</b>	<b>2129</b>	<b>1074</b>	<b>1423</b>	<b>1096</b>	<b>1468</b>	<b>581</b>	<b>60</b>
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	78	78	78				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	73	71	50	71				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talasia 8 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energyac)	HFO (IPP)	6*20	115	115	94	94	70	90				
148	lalmonirhat 30 MW Solar (Intrao)	Solar (IPP)	1*30	30	30	0	0	12	0				
<b>Rangpur Zone Total</b>						<b>830</b>	<b>750</b>	<b>528</b>	<b>493</b>	<b>468</b>	<b>489</b>	<b>0</b>	<b>85</b>
<b>Sub-total: Plants in operation</b>						<b>22088</b>	<b>21710</b>	<b>11712.0</b>	<b>13543</b>	<b>11931</b>	<b>13785</b>	<b>2805</b>	<b>2739</b>
<b>(B) Plants under long term maintenance/ contract expired</b>													
149	Jamalganj 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpuchi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
154	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
<b>Sub-total: Plants under long term maintenance/ contract expired</b>						<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Gross Total</b>						<b>22512</b>	<b>21710</b>	<b>11712</b>	<b>13543</b>	<b>11931</b>	<b>13785</b>	<b>2805</b>	<b>2739</b>
<b>(C) Actual data of 19.09.22 (Yesterday) Monday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13964 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):									
02.	Max. Demand at eve. peak (Sub-station end)	: 13437 MW, at = 21:00 hrs		Zone Demand Supply Load Shed Zone Demand Supply Load Shed									
03.	Highest Generation (Generation end)	: 13543 MW, at = 21:00 hrs		Dhaka 4829 4800 29 Mymensingh 1136 923 213									
04.	Minimum Generation (Generation end)	: 10447 MW, at = 7:00 hrs		Chattogram 1266 1266 0 Sylhet 634 539 95									
05.	Day-peak Generation (Generation end)	: 11712 MW, at = 12:00 hrs		Khulna 1595 1595 0 Barishal 368 368 0									
06.	Evening-peak Generation (Generation end)	: 13543 MW, at = 21:00 hrs		Rajshahi 1387 1387 0 Rangpur 903 903 0									
07.	Evening Peak Load-shed (Sub-station end)	: 388 MW, at = 21:00 hrs		Cumilla 1319 1268 51									
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10459 MW, at = 5:00 hrs		Total 13437 13049 388									
09.	Generation shortfall at evening peak due to :	a) Gas limitation : 2805 MW											
	d) Coal supply Limitation	: 0 MW											
	b) Low water level in Kaptai lake	: 0 MW											
	c) Plants under shut down/ maintenance	: 2739 MW											
10.	Total Energy (Generation + India Import)	: 290.34 MKWh											
	By Gas = 129.781 MKWh	By Oil = 98.762 MKWh											
	By Coal = 32.578 MKWh	By Hydro = 3.657 MKWh											
	By Solar = 1.404 MKWh												
11.	Total Gas Supplied	: 1009.47 MMCFD											
<b>(D) Forecast of 20.09.22 (Today) Tuesday :</b>													
01.	Maximum Demand	: 14000 MW (Generation end)		04. Maximum Load-shed : 198 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 13785 MW (Generation end)		05. Total Generation : 300.14 MKWh									
03.	Reserve / Shortage	: -215 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 33.8 °C									

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation