

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month September, 2022		Day : Friday				Date : 23.09.22							
Probable Maximum Demand :		13700 MW				Probable Maximum Generation : 13273 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 96.96 ft				Today = 96.87 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.09.22 (Yesterday)		23.09.22 (Today)		Rule Curve = 104.80 ft	22.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation (MW)	23.09.22 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	200	220	220	220				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	41	41	40	40				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	234	159	200	200		201	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	195	185	225	225		265	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	373	325	350	350		87	Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	138	95	120	120		240	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	75	40	75				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIP, REB)	8x2.90	22	22	19	22	19	22				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIP, REB)	6x3.67+7x3.73	80	80	50	50	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIIP, REB)	4x8.73	33	33	18	14	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	48	32	49				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	90				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	263	260	260	260				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	115	133	115	133				
26	Kerangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	211	226	200	225				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	85	70	85				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	73	50	70				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	37	0	35				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	87	45	90				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	41	90	40	80				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847	2777	3010	2718	3162	1338	845			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	152	117	117			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		180	Under maint.	
41	Raizan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	47	47	47				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	154	145	150	150				
47	Anwara 300 MW PP (Unitec)	HFO (IPP)	17x17.076+3x8.04	300	300	282	300	282	300				
48	Jaldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	33	33	33	33				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	0	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	22	20	30				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIP, PDB)	8x2.90	22	22	15	15	15	15				
*	Malancha, Ctg EPZ (Unitec)	Gas	5x8.73+3x9.34			6	28	10	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel Oil Shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	88	105	105	105				
55	Jaldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	38	38	38	38				
56	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33				
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total			2442	2382	1146	1260	1146	1240	288	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	42	40	44				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	201	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	340	310	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	12	14	14	14	270		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	54	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	63	157	78	78	38		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	132	138	130	130				
68	Titias 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	30	30	30				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	82	80	80				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	0	0	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIP, REB)	4x2.90	11	11	7	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIP, PDB)	4x8.73	33	33	0	32	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIIP, REB)	3x3.67+2x6.97	25	25	18	21	21	21				
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.6+40x1.515+15x1.596	200	200	178	186	150	190				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	101	60	90				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	107	35	115				
**	Impoport (Tripura)	India		160	160	144	154	143	166				
Cumilla Zone Total			3193	3169	1654	1962	1706	1903	668	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	110	70	100	92		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIIP, PDB)	8x2.90	22	22	14	14	14	14	8		Gas Shortage	
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	96	108	100	100				
84	Myensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	149	171	150	170				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutialkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0				
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.09.22 (Yesterday)		23.09.22 (Today)		22.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	0	0		60	GT-1 Under maint.	
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	5	5	10	10	46		Gas Shortage	
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobigara 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	15	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	310	280	310				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	404	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	399	390	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	5	5	11	11	45		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	5	5	10	10	45		Gas Shortage	
Sylhet Zone Total					2522	2477	1456	1570	1459	1563	164	680	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	220	210	220	220	200		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	63	0	60				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	221	150	210				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	30	95	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	93	75	93				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	906	904	916	916				
Khulna Zone Total					2388	2384	1445	1652	1542	1660	339	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	28	16	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	84	85	85	110		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1110	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	224	222	220	220				
Barishal Zone Total					1958	1958	1198	1476	1447	1472	110	0	
123	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	16	0	24		18	Turbocharger problem	
125	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	15	174	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	0	75				
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhalhi 50 MW PP (Northern)	HFO (GRPP)	6x8.9	50	50	34	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	188	171	150	170				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	213	143	130	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	157	124	130	130	96		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	313	310	310	101		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanke)	HFO (IPP)	6x8.92	52	52	0	8	8	24	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	95	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	90				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2129	2129	1123	1322	1028	1407	632	54	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	82	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	249	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	71	71	71	71				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
147	Thakurgaon 115MW PP (Energyprac)	HFO (IPP)	6*20	115	115	0	75	34	75				
148	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	13	0	12	0				
Rangpur Zone Total					830	750	418	477	455	476	0	85	
Sub-total: Plants in operation					22088	21710	11587.0	13138	11893	13273	3639	1994	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (GRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Arinchara 30 MW PP(Sintra)	HFO (GRPP)	7x7.75	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	11587	13138	11893	13273	3639	1994	
(C) Actual data of 22.09.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 14234	MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 13627	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 13177	MW, at = 22:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	: 10903	MW, at = 8:00 hrs	Dhaka	4836	4673	163	Mymensingh	1114	967	147		
05.	Day-peak Generation (Generation end)	: 11587	MW, at = 10:00 hrs	Chattogram	1310	1310	0	Sylhet	639	527	112		
06.	Evening-peak Generation (Generation end)	: 13138	MW, at = 21:00 hrs	Khulna	1682	1483	199	Barishal	391	391	0		
07.	Evening Peak Load-shed (Sub-station end)	: 1010	MW, at = 21:00 hrs	Rajshahi	1424	1281	143	Rangpur	904	780	124		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10677	MW, at = 5:00 hrs	Cumilla	1327	1205	122						
09.	Generation shortfall at evening peak due to :							Total	13627	12617	1010		
a)	Gas limitation	: 3639	MW	13.	Fuel cost :	(a) Gas = 144387828	Taka	(c) Coal = 271764189	Taka				
d)	Coal supply Limitation	: 0	MW			(b) Oil = 1440009699	Taka	Total = 1856161985	Taka				
b)	Low water level in Kaptai lake	: 0	MW										
c)	Plants under shut down/ maintenance	: 1994	MW	14.	Maximum Temperature in Dhaka was :	34.6° C							
10.	Total Energy (Generation + India Import)	: 291.45	MkWh	15.	Export through East-West interconnections :								
	By Gas = 128.978	MkWh	By Oil = 98.574		At evening peak-hour	: 11587	MW, at 21:00 hrs						
	By Coal = 33.356	MkWh	By Hydro = 6.336		Maximum	: 1025	MW, at 4:00 hrs						
	By Solar = 1.391	MkWh			Energy	: 0	MkWh						
11.	Total Gas Supplied	: 997.58	MMCFD										
(D) Forecast of 23.09.22 (Today) Friday :													
01.	Maximum Demand	:											