

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW				
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1*260	260	0	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	220	5263000		
3	Ghorasal 365 MW CAPP Unit-7	PDB	1*210	190	160	4032000		
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	0	Under maint.
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	66	1668545		Contract Expired
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	0	Gas shortage
7	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	409	8742910		Under maint.
8	Haripur 360 MW CAPP(HPL)	IPP	1*236	360	278	5616000		Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	225	4655000		GT-2 SD due to dirty gas
10	Meghnaghat 100 MW(EL)	NENP	12*8.9	100	91	1248000		Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	335	136	3126662		Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	1299321		
14	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	9*2.90	22	22	462492		
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	0	Gas shortage
18	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12*8.9	100	88	1332480		Fuel shortage
19	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	0	0	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	75	1135872		Engine problem
21	Katpott 52 MW PP (Sinha)	IPP	17*3.0	52	0	0	0	Fuel shortage
22	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	654840		
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	119	1149120		Fuel shortage
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	926172		
25	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	896497		
26	Bosila 108MW PPI(CCLC)	IPP	12*8.75+1*3.5	0	0	0	0	
27	Summit Power (Madhabdi-Ashulia)	SIPP, REB	33.67+4*8.73	80	51	1172780		Engine problem
28	Macona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	591100		Engine problem
29	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	15	472300		Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	41	1110720		#REF!
31	Tongi 80 MW GTPP	PDB	1*105	105	0	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	268	6247636		Engine problem
33	Karaniganj 300 MW PP (ARR)	IPP	25*11.4	300	222	2662371		Engine problem
34	Bramhataganj 100 MW PP (Aggreko)	IPP	114*0.959	100	90	1272305		Engine problem
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	839238		Fuel shortage
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	109	2736430		Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2504400		
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	74	1372800		Engine problem
39	Manikganj 162MW PPI(MPL)	IPP	9*18	162	147	1697680		Engine problem
40	Spectra Solar Plant Ltd.	IPP	35	35	35	193531		
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	37	257040		Fuel shortage
<b>Dhaka area Total</b>				<b>5847</b>	<b>3362</b>	<b>65330722</b>		
41	Chattogram TPP-1	PDB	1*210	180	0	0	0	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	25	596621		
44	Teknaf 200MW PP (Solartech)	IPP	20	20	0	135675		
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	151	3492395		Low water level
46	Sikalbaha 225MW	PDB	1*150+1*175	225	140	3339985		ST under shutdown
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	2427127		
49	Hafazari 100 MW peaking PP	PDB	11*9.9	98	27	424944		Fuel shortage
50	Hafazari 100 MW Peaking	PDB	8*17	102	51	619039		Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	33	783480		Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	33	804480		Fuel shortage
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	15	349200		Engine problem
54	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	37	814080		
55	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	0	Fuel shortage
56	Kaptai 7 MW Solar PP	PDB	7.4	7	0	18634		
57	Anwara 200 MW PP (Uniled)	IPP	17*12.4	300	280	6749455		Engine problem
58	Jodis Power	IPP	3*18.55+1*3.6	54	54	696285		
59	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	105	2298327		Fuel shortage
60	Juidah unit-2 (Acorn)	IPP	8*13.6	100	33	827520		Engine problem
61	Anlima Energy Ltd.	IPP	6*21.2	116	107	2534182		Engine problem
62	Mirshara 150 MW	BPDB-RPCL	18.5*9	0	0	0	0	On test.
<b>Chattogram area Total</b>				<b>2382</b>	<b>1236</b>	<b>27932109</b>		
61	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCCL	1*142+1*75	221	206	4708000		#REF!
65	Ashuganj 450 MW CAPP(North)	APSCCL	1*360	360	0	0	0	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCCL	1*360	360	305	7860000		FGMO
67	Ashuganj 450 MW CAPP(East)	APSCCL	284*1.96*11	284	13	471700		On test.
68	Ashuganj 50 MW PP	APSCCL	14*3.968	45	43	1025064		Engine problem
69	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	55	1324800		
70	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	82	1973818		Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1176960		
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	132	3121309		Engine problem
73	Titas 50 MW Peaking PP	PDB	6*8.9	52	29	631816		Engine problem
74	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	80	1953770		Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	4467840		
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	188928		
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	197820		
78	Import (Tripura)	Imported power	0	160	158	3133440		
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	692200		
80	Jangalia 40 MW PP (Lakshmi)	IPP	6*8.92	52	43	326558		Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	486660		Engine problem
82	Daudkandi 200 MW PP (B.Trac)	IPP	15*14.4	200	182	2340480		Engine problem
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	414960		Fuel shortage
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	96	1689240		Engine problem
85	Bhairab 54.5 MW	IPP	3*18.2	54	7	565520		33 KV feeder problem.
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1424640		
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1898</b>	<b>40195233</b>		
87	RPCL 210MW CAPP	IPP	4*35+1*70	202	102	1922880		Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	14	323388		Gas shortage
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12550		
91	Mymensingh 200 MW PP (Uniled)	IPP	9*78*21	200	174	3813600		Fuel shortage
92	Jamalpur 15 MW PP (Uniled)	IPP	9*78*12	115	95	2385200		Engine problem
93	Sulatkhal 50 MW Solar PP	IPP	50	50	0	263660		
94	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	6	144960		Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>391</b>	<b>8846238</b>		
95	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	43	1024000		Machine problem
96	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	0	200232		Machine problem
97	Kushnara 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	0	Gas shortage
98	Shahbazar 33 MW CAPP	PDB	3*30	33	0	0	0	Under maint.
99	Fenchugonj 51 MW PP (Barakattullah)	RPP	19*2.90	51	16	322800		Gas shortage
100	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	15	340128		Gas shortage
101	Hobiganj 11MW PP Cofidence-E	SIPP, REB	4*2.90	11	0	0	0	Gas shortage
102	Shahbazar GTPP Unit- 8 & 9	PDB	2*35	66	61	1416672		
103	Shahbazar 80MW PP (Shahbazar)	RPP	3*2.90	86	81	772800		
104	Shahbazar 100 MW GTPP	PDB	1*100	100	0	0	0	Under maint.
105	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	220	5237210		
106	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	0	Gas shortage
107	Sylhet 50MW PP (EPL)	NENP	27*2	50	16	287420		Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	43922		Gas shortage
109	Bibiyan-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	310	7322000		FGMO
110	Bibiyan 400 MW CAPP	PDB	400	400	398	9469000		Gas shortage
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	237600		
112	Bibiyan South 400 MW	PDB	400	383	397	9214800		
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1575</b>	<b>35888584</b>		
113	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	0	
114	Bheramara (HVDC)	Imported power	2*500	1000	899	21782545		
115	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	32	323520		Fuel shortage
116	Fardpur 100 MW Peaking PP	PDB	8*8.99	80	54	0	0	
117	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	223	3814080		
118	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	70	535040		Engine problem
119	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	235	5706432		Gas shortage
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	0	Fuel shortage
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	50	975360		
122	Rupsha 118 MW PP (Orion rupsha)	IPP	6*18.445	105	94	1441920		Engine problem
123	Madhumati 100 MW PP	NWPGCL	6*18	105	50	826256		Fuel shortage