

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022		Day : Wednesday				Date : 28.09.22							
Probable Maximum Demand :		14300 MW				Probable Maximum Generation : 13264 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday =		97.10 ft		Today =		97.18 ft		Rule Curve = 105.28 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.09.22 (Yesterday)		28.09.22 (Today)		27.09.22 Gen. shortfall for : Gas/Coal/oil/Water Limitation	(Yesterday) Gen. shortfall for : Machines shut down	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	110	110	110				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	93	95	95				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	345	225	250	250	135			Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x110	450	450	225	225	225	225	225			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	332	275	300	275	60			Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	148	140	140	140	195			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	84	40	92				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	51	51	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	28	28				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	48	48				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	130	16	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	261	281	250	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	40	86	130	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	225	225	225				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	100	75	100				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	55	55	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	22	53	54	54				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	89	45	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	82	42	82				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847	2691	3181	2835	3284	1237	845			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	157	157	156	156				Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	47	47	40	47				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	88	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	150	150	150				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	196	300	300	300				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	11	11	11	11				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	28	29	20	30				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	16	16				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	21	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	89	105	105	105				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	10	10				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total			2442	2382	982	1181	1138	1179	180	330			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	38	41	44	44				
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	205	168	200	200				
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	310	320	310	320				
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360			Gas Shortage
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCCL)	1x284	284	284	53	72	40	40	212			Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	54	55	55				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187			Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	129	135	140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	35	35				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	81	81	82	82				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	183	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Deukandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+6x1.015+1x1.068	200	200	180	185	150	185				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	99	114	105	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115				
**	Impoport (Tripura)	India		160	160	148	100	143	166				
Cumilla Zone Total			3193	3169	1701	1749	1721	1882	759	0			
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	69	100	70	100	102			Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	17	11	17				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	106	100	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	143	100	150				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.09.22 (Yesterday)		28.09.22 (Today)		27.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for r Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					MW
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	16	16	51		Gas Shortage	
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	5	5	5	6		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	62	62	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	10	78				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	280	300				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400				
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	394	399	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	0	0	15	15	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1458	1548	1491	1587	194	680	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	180	185	185	185	225		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	38				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	30	64				
110	Khulna 225 MW CAPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	120	224	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	94	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	93	55	90				
113	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	15	67	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	16	32				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0				
	Rampal 1320 MW	Coal (BHP/CL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				100	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	890	800	918	918				
Khulna Zone Total					2388	2384	1453	1596	1589	1692	225	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	25	18	25				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	82	84	85	85	110		Gas Shortage	
120	Payra 1320 MW TUPP	Coal (BCPCL)	2x622	1244	1244	870	1080	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x8.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	218	220	220	220				
Barishal Zone Total					1958	1958	1190	1441	1449	1472	110	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	167	171	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	0	75				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	165	161	170	170	49		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	139	219	210	210	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	126	126	130	130	94		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	238	231	250	250	183		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total					2129	2129	1027	1317	1082	1331	717	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	79	79	79				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	71	56	56	56				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tahila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	55	76	50	75				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	33	0	12	0				
Rangpur Zone Total					830	750	494	461	455	460	0	85	
Sub-total: Plants in operation					22088	21710	11311.0	12847	12103	13264	3524	1940	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bagura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Triflulia 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	11311	12847	12103	13264	3524	1940	
(C) Actual data of 27.09.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 14200 MW, at = 20:00 hrs					12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	: 13635 MW, at = 20:00 hrs					Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	: 12921 MW, at = 22:00 hrs						MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	: 10614 MW, at = 7:00 hrs					Dhaka	4927	4718	209	Mymensingh	1091	883
05.	Day-peak Generation (Generation end)	: 11311 MW, at = 12:00 hrs					Chattogram	1388	1388	0	Sylhet	623	516
06.	Evening-peak Generation (Generation end)	: 12847 MW, at = 20:00 hrs					Khulna	1629	1382	247	Barishal	396	396
07.	Evening Peak Load-shed (Sub-station end)	: 1247 MW, at = 20:00 hrs					Rajshahi	1423	1265	158	Rangpur	856	708
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10994 MW, at = 5:00 hrs					Cumilla	1302	1132	170			
09.	Generation shortfall at evening peak due to :										Total	13635	12388
	a) Gas limitation	: 3524 MW									(c) Coal =	275214271	Taka
	d) Coal supply Limitation	: 0 MW					13. Fuel cost :	(a) Gas = 137809384	Taka		Total =	182283798	Taka
	b) Low water level in Kaptai lake	: 0 MW						(b) Oil = 1409815143	Taka				
	c) Plants under shut down/ maintenance	: 1940 MW					14. Maximum Temperature in Dhaka was :	33.3 °C					
10.	Total Energy (Generation + India Import)	: 283.05 MKWh					15. Export through East-West interconnections :						
	By Gas = 124.593 MKWh	By Oil = 95.336 MKWh					At evening peak-hour	: 11311 MW, at	20:00 hrs				
	By Coal = 33.705 MKWh	By Hydro = 3.821 MKWh					Maximum	: 615 MW, at	12:00 hrs				
	By Solar= 1.343 MKWh						Energy	: 0 MKWh					
11.	Total Gas Supplied	: 966.12 MMCFD											
(D) Forecast of 28.09.22 (Today) Wednesday :													
01.	Maximum Demand	: 14300 MW (Generation end)					04.	Maximum Load-shed	: 995 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	: 13264 MW (Generation end)					05.	Total Generation	: 313.26 MKWh				
03.	Reserve / Shortage	: -1036 MW (Generation end)					06.	Probable Max. Temperature in Dhaka :	33.2 °C				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation