

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Thursday						Date : 29.09.22			
Probable Maximum Demand : 14400 MW				Probable Maximum Generation : 13143 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.18 ft		Today = 97.17 ft		Rule Curve = 105.52 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.09.22 (Yesterday)		29.09.22 (Today)		28.09.22 Gen. shortfall for : Gas/Coal/Water Limitation (MW)	(Yesterday) Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	220	200	200	200				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	165	160	160				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	87	90	90				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	317	198	200	200	162			Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	320	153	200	200				
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	145	140	140	190			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	40	40	40				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	19				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	43	52	51	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	16	28	28				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	48	48	48				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	90	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	128	16	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	100	292	100	290				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	149	149	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	215	220	200	220				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	95	100	50	100				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	51	95	50	95				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	65	69	55	55				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	88	45	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	33	84	42	82				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2816	3173	2521	3209	1199	845		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	157	155	155				Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	0	0	0				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	147	150	150	150				
47	Amwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	196	300	300	300				
48	Juldah 100 MW PP Unit 3 (Acorn)	HFO (IPP)	8x13.45	100	100	11	11	11	11				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	30	20	30				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	16	16				
*	Malancha, City EPZ (United)	Gas	5x8.73+3x9.34			2	22	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	45	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	10	10				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total				2442	2382	1007	1145	1115	1149	180	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	37	35	35				
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	197	198	200	200				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	325	335	335	335				
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360			Gas Shortage
63	Ashuganj 420 MW CCGP(East) GT	Gas (APSCCL)	1x284	284	284	88	0	0	0	284			Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	47	51	55	55				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	26	26	26	169			Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	35	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	115	135	140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	82	81	82	82				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	25	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Deukandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+6x1.015+19x1.068	200	200	105	115	100	150				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	115	105	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	30	115	35	115				
**	Impoport (Tripura)	India		160	160	120	158	143	166				
Cumilla Zone Total				3193	3169	1576	1724	1639	1813	813	0		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	45	107	70	100	95			Gas Shortage
82	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	95	96	100	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	160	100	150				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0				
86	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	29	0	50	0	50				
87	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total				622	614	269	394	356	384	95	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.09.22 (Yesterday)		29.09.22 (Today)		28.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down (MW)			
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	41	41	41		49	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5	6		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	57	60	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	75	10	75				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	213	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	320	280	320				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	410	400	400				
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	386	381	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1470	1563	1469	1584	194	669	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	195	215	215	215		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	32				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	48	30	64				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	215	225	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	70	91	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	94	55	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	56	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0				
	Rampal 1320 MW	Coal (BHPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				100	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	901	905	925	925				
Khulna Zone Total					2388	2384	1583	1656	1626	1711	215	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	18	25				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	79	85	85	85	109		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	960	1090	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x8.78	150	150	0	17	0	0			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220				
Barishal Zone Total					1958	1958	1297	1475	1449	1472	109	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	151	171	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	76	0	75				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25				
131	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	167	162	175	175				
132	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	209	211	210	210	220		Running on HSD	
133	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	123	127	130	130	93		Gas Shortage	
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	213	240	250	250	174		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	18	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	94	113	50	113				
140	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total					2129	2129	1099	1331	1087	1354	658	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	80	85	85				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	56	56	56				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tahula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	57	50	76				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	28	0	12	0				
Rangpur Zone Total					830	750	417	443	461	467	0	85	
Sub-total: Plants in operation					22088	21710	11534.0	12904	11723	13143	3463	1929	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Pinfullia 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	11534	12904	11723	13143	3463	1929	

(C) Actual data of 28.09.22 (Yesterday) Wednesday :																	
01. Max. Demand at eve. peak (Generation end) : 14500 MW, at = 21:00 hrs					12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
02. Max. Demand at eve. peak (Sub-station end) : 13713 MW, at = 21:00 hrs					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
03. Highest Generation (Generation end) : 12904 MW, at = 21:00 hrs					Dhaka	4890	4545	345	Mymensingh	1131	954	177					
04. Minimum Generation (Generation end) : 10994 MW, at = 8:00 hrs						Chattogram	1484	1294		190	Sylhet	609	491	118			
05. Day-peak Generation (Generation end) : 11534 MW, at = 12:00 hrs							Khulna	1654		1424		230	Barishal	406	406	0	
06. Evening-peak Generation (Generation end) : 12904 MW, at = 21:00 hrs						Rajshahi	1366	1222		144	Rangpur	876	707	169			
07. Evening Peak Load-shed (Sub-station end) : 1471 MW, at = 21:00 hrs						Cumilla	1297	1199		98							
08. Minimum Generation Forecast up to 8:00 hrs. : 10599 MW, at = 5:00 hrs													Total	13713	12242	1471	
09. Generation shortfall at evening peak due to :						13. Fuel cost :		(a) Gas = 137707652 Taka		(c) Coal = 276472454 Taka							
a) Gas limitation : 3463 MW								(b) Oil = 1428677659 Taka		Total = 1842857765 Taka							
c) Plants under shut down/ maintenance : 1929 MW																	
10. Total Energy (Generation + India Import) : 284.59 MMWh					14. Maximum Temperature in Dhaka was : 32.2° C												
By Gas = 123.493 MKWH					15. Export through East-West interconnections :					At evening peak-hour : 11534 MW, at 21:00 hrs							
By Coal = 33.860 MKWH					Maximum : 615 MW, at 12:00 hrs												
By Solar= 1.476 MKWH					By Oil = 96.914 MKWH												
By Hydro = 3.735 MKWH					By Solar = 0 MKWH												
11. Total Gas Supplied : 972.75 MMCFD																	
(D) Forecast of 29.09.22 (Today) Thursday :																	
01. Maximum Demand : 14400 MW (Generation end)					04. Maximum Load-shed : 1158 MW At evening peak (Sub-station end)												
02. Maximum Generation : 13143 MW (Generation end)					05. Total Generation : 317.59 MKWh												
03. Reserve / Shortage : -1257 MW (Generation end)					06. Probable Max. Temperature in Dhaka : 34.4° C												

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation