

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022		Day : Friday				Date : 30.09.22					
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :				13501 MW			
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 97.17 ft		Today = 97.06 ft				Rule Curve = 105.76 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.09.22 (Yesterday)		30.09.22 (Today)		29.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210 1 x 210	210 210	180 190	230 160	210 160	230 180	230 180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	84	90	90		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	262	201	320	320	159	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	340	250	320	320		
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	140	140	185	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	55	55	55	55		
15	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	92		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	51	51	51		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	21	21		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	48	49	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	90	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	128	16	130		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	275	95	290		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	145	133	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	170	223	200	220		
27	Birampuriganj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	0	0	0		
28	Aurahati 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	95	50	95		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	56	17	55		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	30	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	53	54	54	54		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	88	45	90		
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	33	67	42	92		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2626	3128	2704	3431	1191	845
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	151	114	114		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210 1 x 210	210 210	180 210	0 0	0 0	0 0	0 0	180	Gas Shortage Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	18	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	0	0		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	150	150	25	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	196	300	195	300		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	11	11	11	11		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	7	23	23	23		
51	Barebkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	16	16		
52	Malancha, Ctg. EPZ (United)	Gas	5x8.73+3x9.34			3	18	20	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	36	18	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	10	10		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	10	10		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			1	0	0	0		
Chattogram Zone Total				2442	2382	988	1119	826	1153	180	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	37	35	35		
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+17x5	221	221	198	191	190	190		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	330	260	310	320		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	300	300	340	330		
63	Ashuganj 420 MW CCGP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	20	20	20		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	0	8	8	195	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	107	125	130	135		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	81	81	80	80		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	164	179	180	180		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	25	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	100	102	100	100		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	17	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	97	115	108	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	32	114	35	115		
**	limpoot (Tripura)	India		160	160	154	160	143	166		
Cumilla Zone Total				3193	3169	1636	1878	1867	1988	479	0
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	102	70	100	100	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	96	100	100		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	151	86	150		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
86	Sutahkali 50 MW Solar PP	Solar (IPP)	1x50	50	50	23	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	276	383	342	384	100	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.09.22 (Yesterday)		30.09.22 (Today)		29.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for r Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening					MW	MW	
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.			
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	5	5	5	46		Gas Shortage			
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	0	0	0	11		Gas Shortage			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	62	60	62			Under maint.			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	75						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	213	220	220	220						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0	17		Gas Shortage			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	290	320						
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	397	400	400						
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	370	395	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage			
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage			
Sylhet Zone Total					2522	2477	1442	1532	1479	1576	194	669			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	190	190	200	200	220		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	31	6	40						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	45	60						
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	195	221	220	220						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	50	50	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	94	55	94						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	24	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16						
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	0	0	0						
	Rampal 1320 MW	Coal (BHPCL)				0	0	0	0						
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	909	909	927	927						
Khulna Zone Total					2388	2384	1387	1619	1634	1657	220	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	31	20	25						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	82	84	85	85	110		Gas Shortage			
120	Payra 1320 MW TAPP	Coal (BCPCL)	2x622	1244	1244	920	1130	1110	1110						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x8.78	150	150	0	0	0	0			Line Overload			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	222	220	220						
Barishal Zone Total					1958	1958	1259	1499	1451	1472	110	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	1	171	100	170						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	2	84	0	75						
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32						
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25						
131	Sirajganj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	173	161	175	175						
132	Sirajganj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	155	215	210	210	220		Running on HSD			
133	Sirajganj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	128	127	130	130	93		Gas Shortage			
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	255	262	270	270	152		Gas Shortage			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	18	18						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8						
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	113	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	92	113	113	113						
140	Sirajganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0						
Rajshahi Zone Total					2129	2129	928	1364	1170	1374	636	0			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	80	85	85						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250						
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	56	56	56						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tahulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	5	75	50	75						
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	12	0						
Rangpur Zone Total					830	750	424	461	461	466	0	85			
Sub-total: Plants in operation					22088	21710	10966.0	12983	11934	13501	3110	1929			
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Bagura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
154	Khulna 30 MW PP(SIPPA)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0			
Gross Total					22512	21710	10966	12983	11934	13501	3110	1929			
(C) Actual data of 29.09.22 (Yesterday) Thursday :															
01.	Max. Demand at eve. peak (Generation end)					14429	MW, at =	21:00 hrs							
02.	Max. Demand at eve. peak (Sub-station end)					13758	MW, at =	21:00 hrs							
03.	Highest Generation (Generation end)					12993	MW, at =	22:00 hrs							
04.	Minimum Generation (Generation end)					10599	MW, at =	8:00 hrs							
05.	Day-peak Generation (Generation end)					10966	MW, at =	12:00 hrs							
06.	Evening-peak Generation (Generation end)					12983	MW, at =	21:00 hrs							
07.	Evening Peak Load-shed (Sub-station end)					1333	MW, at =	21:00 hrs							
08.	Minimum Generation Forecast up to 8:00 hrs.					10467	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :														
	a) Gas limitation					3110	MW								
	d) Coal supply Limitation					0	MW								
	b) Low water level in Kaptai lake					0	MW								
	c) Plants under shut down/ maintenance					1929	MW								
10.	Total Energy (Generation + India Import)					279.68	MKWh								
	By Gas =	125.851	MKWh	By Oil =	89.161	MKWh									
	By Coal =	34.057	MKWh	By Hydro =	3.614	MKWh									
	By Solar=	1.418	MKWh												
11.	Total Gas Supplied					982.74	MMCFD								
(D) Forecast of 30.09.22 (Today) Friday :															
01.	Maximum Demand					13500	MW	(Generation end)							
02.	Maximum Generation					13501	MW	(Generation end)							
03.	Reserve / Shortage					1	MW	(Generation end)							
04.	Maximum Load-shed					0	MW	At evening peak (Sub-station end)							
05.	Total Generation					290.59	MKWh								
06.	Probable Max. Temperature in Dhaka :					35.6	°C								

*Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation