

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month October, 2022				Day : Wednesday				Date : 12.10.22			
Probable Maximum Demand : 14200 MW				Probable Maximum Generation : 12637 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.53 ft		Today = 98.58 ft		Rule Curve = 107.00 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.10.22 (Yesterday)		12.10.22 (Today)		11.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	100	100	100		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	61	62	62	62		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	305	323	300	300		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	398	400	400		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	208	222	200	200		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16	86	Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	48	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	0	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	10	12	15	15		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	40	40	40		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	64	130		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	296	250	295		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	90	90	90	90		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	130	0	130		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	0	50		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	74	17	74		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	90	162	90	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0		
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	8	0	8		
36	Meghnaghat 100 MW (WIEL)	HFO (NENP)	12x8.9	100	100	16	71	8	70		
37	Madanganj 102 PP (Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
<b>Dhaka Zone Total</b>				<b>6004</b>	<b>5847</b>	<b>2428</b>	<b>2957</b>	<b>2323</b>	<b>2895</b>	<b>521</b>	<b>1180</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	154	154	154		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	8	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	44	25	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	105	105	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	229	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	195	267	195	280		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	14	22	22		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	2	17	5	15		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	35	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	80	105	105	105		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	63	90	50	90		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	66	80	66	80		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>1244</b>	<b>1440</b>	<b>1250</b>	<b>1463</b>	<b>288</b>	<b>330</b>
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	35	50	38	38		
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	169	213	180	180		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	220	265	265	265	95	Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	275	270	270	270	90	Gas Shortage
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	105	103	115	137		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	47	0	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	82	82	82		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	44	51	17	50		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	0	100	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	112	0	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9	104	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115		
**	Import (Tajura)	India		160	160	152	156	143	166		
<b>Cumilla Zone Total</b>				<b>3193</b>	<b>3169</b>	<b>1428</b>	<b>1811</b>	<b>1338</b>	<b>1808</b>	<b>944</b>	<b>0</b>
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	62	42	100	140	Gas Shortage
82	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	103	90	100		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	104	112	100	140	88	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	25	0	50	0		
87	Tangal 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>				<b>622</b>	<b>614</b>	<b>295</b>	<b>302</b>	<b>309</b>	<b>365</b>	<b>228</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.10.22 (Yesterday)		12.10.22 (Today)		11.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	MW	MW			
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	G1- Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5	46		Gas Shortage	
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.30	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	62	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	0	10	80				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140		91	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	270	270				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	405	406	370	400				
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5	45		Gas Shortage	
<b>Sylhet Zone Total</b>													
2522 2477 1409 1370 1344 1444 306 663													
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	210	220	210	210	190		Gas Shortage	
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	27	40	27	Fuel oil shortage	
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	69	0	60	40		Fuel oil shortage	
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	170	120	180				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0	50			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	94	35	90				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	9	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	85	16	16				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC ) India		1000	1000	917	918	935	935					
<b>Khulna Zone Total</b>													
2388 2384 1304 1668 1431 1631 297 0													
117	Barisal 110 MW PP (Summit )	HFO (IPP)	7 x 17.076	110	110	0	16	16	16		94	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	29	16	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	88	86	86	106		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	890	1000	1050				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	6x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	174	220	222	222				
<b>Barishal Zone Total</b>													
1958 1958 959 1243 1340 1394 106 244													
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	82				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	25				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	185	180	170	170				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	180	130	200	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	155	154	150	150	66		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	332	348	320	320	66		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	21	21				
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	34	0	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	70	113	113	113				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	89	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
<b>Rajshahi Zone Total</b>													
2129 2129 1002 1327 1034 1369 573 71													
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	81	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	113	56	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Haopara, Taulia 5MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 119MW PP (Energygas)	HFO (IPP)	6*20	115	115	0	76	0	75				
148	lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	21	0	12	0				
<b>Rangpur Zone Total</b>													
830 750 164 270 156 268 0 359													
<b>Sub-total: Plants in operation</b>													
22088 21710 10233.0 12388 10525 12637 3263 2847													
<b>(B) Plants under long term maintenance/ contract expired</b>													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammhura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>													
424 0 0 0 0 0 0 0													
<b>Gross Total</b>													
22512 21710 10233 12388 10525 12637 3263 2847													
<b>(C) Actual data of 11.10.22 (Yesterday) Tuesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13003 MW, at = 20:00 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 12490 MW, at = 20:00 hrs				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 12388 MW, at = 20:00 hrs				Dhaka	4690	4476	214	Mymensingh	966	844	122
04.	Minimum Generation (Generation end)	: 9961 MW, at = 8:00 hrs				Chattogram	1225	1225	0	Sylhet	402	402	0
05.	Day-peak Generation (Generation end)	: 10233 MW, at = 12:00 hrs				Khulna	1536	1536	0	Barishal	350	350	0
06.	Evening-peak Generation (Generation end)	: 12388 MW, at = 20:00 hrs				Rajshahi	1214	1214	0	Rangpur	743	743	0
07.	Evening Peak Load-shed (Sub-station end)	: 567 MW, at = 20:00 hrs				Cumilla	1364	1133	231				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9719 MW, at = 5:00 hrs				Total 12490 11923 567							
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 3263 MW				13. Fuel cost : (a) Gas = 147899040 Taka (c) Coal = 213706577 Taka							
d)	Coal supply Limitation	: 0 MW				(b) Oil = 1018831525 Taka Total = 1380437143 Taka							
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2847 MW				14. Maximum Temperature in Dhaka was : 34.1° C							
10.	Total Energy (Generation + India Import)	: 263.21 MKWh				15. Export through East-West interconnections : At evening peak-hour : 10233 MW, at 20:00 hrs							
	By Gas = 133.654 MKWh	By Oil = 74.419 MKWh		Maximum : 640 MW, at 18:00 hrs									
	By Coal = 24.400 MKWh	By Hydro = 3.753 MKWh		Energy : 0 MKWh									
	By Solar = 1.118 MKWh												
11.	Total Gas Supplied	: 1031.54 MMCFD											
<b>(D) Forecast of 12.10.22 (Today) Wednesday :</b>													
01.	Maximum Demand	: 14200 MW (Generation end)				04. Maximum Load-shed : 1440 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12637 MW (Generation end)				05. Total Generation : 301.71 MKWh							
03.	Reserve / Shortage	: -1563 MW (Generation end)				06. Probable Max. Temperature in Dhaka : 30.5° C							

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation