

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 15-Oct-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW			
			MW	MW	KWH		
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	100	2399000	Line O/L
3	Ghorasal 365 MW CAPP Unit-7	PDB	1*210	190	0	0	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Under maint.
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	84	1916318	Engine problem
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	385	9701380	Gas shortage
8	Haripur 380 MW CAPP(HPL)	IPP	1*230	242	242	6978000	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	225	5116600	Gas shortage
10	Meghnaghat 100 MW(LEL)	NENP	12*8.9	100	83	1866720	Fuel shortage
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	46	1120361	Engine problem
14	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	412704	Engine problem
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12*8.9	100	89	1726080	Fuel shortage
19	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	160	4692838	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	82	1622736	Fuel shortage
21	Katpott 52 MW PP (Sinha)	IPP	17*3.0	52	0	0	Fuel shortage
22	Karnalghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	489240	Engine problem
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	1005120	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	895522	
25	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	597522	
26	Bosila 108MW PPI(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Machhadin-Ashulia)	SIPP, REB	33.67+4*8.73	80	50	1227120	Engine problem
28	Macona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	797000	
29	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	14	380000	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	40	1021920	#REF!
31	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	276	4355780	Engine problem
33	Karaniganj 300 MW PP (ARR)	IPP	25*11.4	300	28	237656	Fuel shortage
34	Bramhataganj 100 MW PP (Aggreko)	IPP	114*0.959	100	50	282821	Fuel shortage
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	292295	Fuel conservation
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	126	2093184	Fuel shortage
37	Gazipur 100 MW PP	RPCL	6*17.5	105	88	2109600	Fuel shortage
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	94	1685760	Engine problem
39	Manikganj 162MW PPI(MPL)	IPP	9*18	162	162	2098000	
40	Spectra Solar Plant Ltd.	IPP	35	35	0	203695	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	54	1255680	
Dhaka area Total				5847	2876	5840262	
41	Chattogram TPP-1	PDB	1*210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Razzan 25 MW PP	RPCL	3*8.9	25	25	530820	
44	Teknaf 20MW PP (Solartech)	IPP	20	20	0	130950	
45	Palenga 50MW PP (Banco)	IPP	8*6.98	50	44	1039200	Engine problem
46	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	156	3752884	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	217	5279160	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	2340981	
50	Hathazari 100 MW peaking PP	PDB	11*9.9	98	21	460416	Fuel shortage
51	Hathazari 100 MW Peaking	PDB	8*17	102	51	613870	Fuel shortage
52	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	86	1819800	Fuel shortage
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	1963200	Fuel shortage
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	12	274176	Engine problem
55	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	9	457920	
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	12	82560	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4	7	0	28075	
58	Anwara 300 MW PP (Uniled)	IPP	17*17.24	300	302	4816727	
59	Jodis Power	IPP	3*18.55+1*3.6	54	54	1353663	
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	105	2565916	
61	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2297280	Engine problem
62	Anlima Energy Ltd.	IPP	6*21.2	116	107	2524145	Engine problem
Mirshara 150 MW			BPDB-RPCL	18.5*9	0	10036	On test.
Chattogram area Total				2382	1496	3213262	
61	Ashuganj TPP Unit-3	APSCl	1*150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCl	1*150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCl	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCl	1*142+1*75	221	189	4338000	#REF!
65	Ashuganj 450 MW CAPP(North)	APSCl	1*360	360	300	7225300	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCl	1*360	360	280	6504000	Gas shortage
67	Ashuganj 420 MW CAPP(East)	APSCl	284*1.56*11	420	0	2333400	On test
68	Ashuganj 50 MW PP	APSCl	14*3.968	45	5	211752	Gas shortage
69	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	5	136800	Gas shortage
70	Ashuganj 195MW PP (APSCl-Uniled)	IPP	20*9.73+1*16	195	8	184000	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1136394	
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	62	1147490	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	6*8.9	52	42	1018552	Engine problem
74	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	82	1956870	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	100	1616160	Fuel shortage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	486144	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	221220	
78	Import (Tripura)	Imported power	0	160	166	3457920	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	609800	Engine problem
80	Jangalia 40 MW PP (Lakshmi)	IPP	6*8.92	52	52	686678	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	511690	Engine problem
82	Daudkandi 200 MW PP (B.Trac)	IPP	15*14.4	200	100	286656	Fuel shortage
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	83	1047660	Fuel shortage
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	8	204960	Fuel shortage
85	Bhairab 54.5 MW	IPP	3*18.2	54	35	863640	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1788400	
Cumilla Area Total				3169	1762	37951488	
87	RPCL 210MW CAPP	IPP	4*35+1*70	202	53	1698240	Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	13	315612	Engine problem
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14700	
91	Mymensingh 200 MW PP (Uniled)	IPP	9*78*21	200	117	1716000	Fuel shortage
92	Jamalpur 115 MW PP (Uniled)	IPP	9*78*12	115	115	2652000	
93	Sulakhali 50 MW Solar PP	IPP	50	50	0	38950	
94	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	12	293280	Engine problem
Mymensingh Area Total				614	310	7078782	
95	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	30	716000	Machine problem
96	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	30	660000	Machine problem
97	Kushnara 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	Gas shortage
98	Shahbazar 333 MW CAPP	PDB	3*110	330	0	0	Under maint.
99	Fenchugonj 51 MW PP (Barakattullah)	RPP	19*2.90	51	0	38400	Gas shortage
100	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	0	0	Gas shortage
101	Hobiganj 11MW PP Cofidence-E	SIPP, REB	4*2.90	11	0	0	Engine problem
102	Shahbazar GTPP Unit-8 & 9	PDB	2*35	66	60	1451904	
103	Shahbazar 90MW PP (Shahbazar)	RPP	3*2.90	86	81	548160	
104	Shahbazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.
105	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	140	3360400	ST under maint
106	Sylhet 20 MW GTPP	PDB	1*20	20	18	427000	
107	Sylhet 50MW PP (EPL)	NENP	27*2	50	0	0	Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage
109	Bibianna-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	315	7144500	FGMO
110	Bibianna 225 MW CAPP	PDB	400 MW	400	403	9705000	Gas shortage
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241560	
112	Bibianna South 400 MW	PDB	400 MW	383	396	9282000	
Sylhet Area Total				2477	1483	33574924	
113	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Fuel shortage
114	Bheramara (HVDC)	Imported power	2*500	1000	925	22330181	
115	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	66	399360	Fuel shortage
116	Fandpur 100 MW Peaking PP	PDB	8*6.98	54	44	173760	Engine problem
117	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	160	3158400	Fuel shortage
118	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	55	303360	Engine problem
119	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	200	5388768	Gas shortage
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	64500	Fuel shortage
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	30	120000	Fuel conservation
122	Rupsha 118 MW PP (Orion rupsha)	IPP	6*18.445	105	93	987360	Engine problem
123	Madhumati 100 MW PP	NWPGCL	6*18	105	85	597168	Fuel shortage
124	Mongla Orion 100 MW Solar PP	IPP	100	100	0	581040	
125	Khulna 330 MW CAPP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
126	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	1186100	On test.
Khulna Area Total				2384	1666	35289997	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	192384	Line O/L
128	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	21	531549	Engine problem
129	Bhola 225 MW CAPP	PDB	2*63+1*98	194			