

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2022				Day : Sunday				Date : 16.10.22				
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 12688 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.54 ft		Today = 98.48 ft		Rule Curve = 107.40 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.22 (Yesterday)		16.10.22 (Today)		15.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	100	100	100	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	84	80	84			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	296	242	270	250	118	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	385	400	390			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	205	160	160	160		STG Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	46	46	46	46			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	65	82	74	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.7+7x8.73	80	80	54	50	50	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	14	16	16			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	40	40	40			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	32	132			
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	242	276	245	280			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	68	126	70	127			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	28	0	150			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	94	17	93			
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	90	162	90	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	17	54			
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	89	70	90			
36	Meghnaghat 100 MW (EEL)	HFO (NENP)	12x8.9	100	100	58	83	60	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2451	2876	2319	3039	553	1370	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	156	154	154		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0	180	Under maint.	
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	17	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	44	44	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	88	105	105	105			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	217	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	220	302	200	285			
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	76	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	7	21	21	21			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
52	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	2	9	5	15			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.0	108	108	0	12	0	12	96	Fuel oil shortage	
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	90	100			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	66	86	66	75			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
59	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			4	0	0	0			
Chattogram Zone Total				2442	2382	1305	1496	1323	1480	276	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	10	5	5	5	40	Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	162	189	170	190			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	260	280	270	290			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	280	300	280	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	288	0	0	0	284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	43	62	43	43			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	46	42	37	44			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	81	82	80	81			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	51	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	0	100	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	83	17	100			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	8	9	105		Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	41	115	41	115			
**	Import (Tijura)	India		160	160	138	166	143	166			
Cumilla Zone Total				3193	3169	1589	1762	1332	1764	800	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	53	65	80	149	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
83	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	98	115	90	115			
84	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	68	117	70	127	83	Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	279	310	302	347	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.22 (Yesterday)		16.10.22 (Today)		15.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30		60	G1-4 Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140		91	ST Under maint.
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	315	300	320			
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	408	403	400	400			
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	396	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0			Gas Shortage
105	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total				2522	2477	1386	1483	1388	1489	296	675	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	200	200	215	210		Gas Shortage
108	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	44			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	55			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	160	120	120			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	30	0	30		50	
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	93	35	90			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	85	15	85			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0			
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	16	66			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8	32		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0			
**	Bheramara (HVDC) India			1000	1000	923	925	939	939			
Khulna Zone Total				2388	2384	1364	1666	1425	1672	242	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16		94	Line Overload
118	Bhola 33 MW (Venture)	Gas (NENP)	1x34.50	40	40	19	21	16	28			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	88	85	85	106		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	1040	1000	1050			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	6x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	223	222	222			
Barishal Zone Total				1958	1958	847	1388	1323	1401	106	244	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	70	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	85			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	159	175	170	180			
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	145	147	150	154	73		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	393	304	320	330	110		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	17	22			
136	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	34	0	34			
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	113	113			
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	8	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total				2129	2129	738	1160	900	1230	624	71	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	83	80	81			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	38	52	44	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Haopara, Taulia 5MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 119MW PP (Energygas)	HFO (IPP)	6*20	115	115	0	72	0	72			
148	lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	12	0			
Rangpur Zone Total				830	750	160	207	144	266	0	359	
Sub-total: Plants in operation				22088	21710	10119.0	12348	10456	12688	3129	3049	
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0			
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprime)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Ammhura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0	0	0	
Gross Total				22512	21710	10119	12348	10456	12688	3129	3049	
(C) Actual data of 15.10.22 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	: 13354 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12665 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 12348 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 9512 MW, at = 9:00 hrs										
05.	Day-peak Generation (Generation end)	: 10119 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12348 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 927 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9442 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 3129 MW										
d)	Coal supply Limitation	: 0 MW										
b)	Low water level in Kaptai lake	: 0 MW										
c)	Plants under shut down/ maintenance	: 3049 MW										
10.	Total Energy (Generation + India Import)	: 259.17 MCKWh										
	By Gas = 130.835 MCKWh	By Oil = 73.048 MCKWh										
	By Coal = 24.075 MCKWh	By Hydro = 3.753 MCKWh										
	By Solar = 1.670 MCKWh											
11.	Total Gas Supplied	: 988.55 MCKWh										
				12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
					Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
					Dhaka	4783	4409	374	Mymensingh	1058	847	211
					Chattogram	1252	1252	0	Sylhet	570	468	102
					Khulna	1542	1542	0	Barishal	362	362	0
					Rajshahi	1287	1287	0	Rangpur	579	528	51
					Cumilla	1232	1043	189				
					Total				12665		11738	
					Total				20027991		Taka	
					Total				977690208		Taka	
				13.	Fuel cost :							
					(a) Gas = 140750973 Taka		(c) Coal = 200027991 Taka					
					(b) Oil = 977690208 Taka		Total = 1318469172 Taka					
				14.	Maximum Temperature in Dhaka was :				33.7° C			