

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2022				Day: Monday				Date: 17.10.22			
Probable Maximum Demand : 13700 MW				Probable Maximum Generation : 12480 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.48 ft		Today = 98.19 ft		Rule Curve = 107.50 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.22 (Yesterday)		17.10.22 (Today)		16.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	220	100	100		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	84	80	84		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	241	232	250	250	128	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	200	200	200	250	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	393	370	370	370		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	155	150	160	150		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	46	55	50	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	92	74	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	52	50	52		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	12	16	18		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	43	40	43		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	132	32	132		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	205	281	245	280		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	72	126	70	126		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	105	154	0	150		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	92	50	0	50		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	50	0	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	93	17	93		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	90	162	90	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	17	54		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	90	70	90		
36	Meghnaghat 100 MW (EEL)	HFO (NENP)	12x8.9	100	100	67	84	60	84		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2561	3090	2248	2989	588	1370
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	155	155	154	155		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	20	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	44	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	102	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	229	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	200	268	200	280		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	76	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	21	21	21	21		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	12	14		
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	2	16	5	15		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.0	108	108	0	12	0	12	96	Fuel oil shortage
54	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	53	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	90	100		
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	76	68	66	68		
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
59	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			11	0	0	0		
Chattogram Zone Total				2442	2382	1317	1464	1331	1471	276	330
58	Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	50	45	10	10	5	10	35	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	188	208	170	210		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	305	270	305		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	310	280	310		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	2	2	5	5	53	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	42	61	43	61		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	44	37	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	83	80	83		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	51	51	51		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	100	95	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	70	17	70		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	9	9	9	104	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	69	115	41	115		
**	Import (Tripura)	India		160	160	144	162	143	166		
Cumilla Zone Total				3193	3169	1571	1747	1332	1764	797	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	82	65	82	120	Gas Shortage
82	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	115	90	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	117	70	117	83	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
87	Tangal 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	277	339	302	339	203	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.22 (Yesterday)		17.10.22 (Today)		16.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30		60	G1- Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	60	62			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	135	140	140		96	ST Under maint.
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	409	409	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	388	400	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.4'5'2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total												
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	215	200	215	195		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	38	0	40			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	0	50			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	120	120			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	0	50			
112	Rupsha 105 MW PP (Orion upsha)	HFO (IPP)	6x18.445	105	105	62	75	35	75			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	43	85	15	85			
114	Mongla Orion 100 MW PP	Solar (IPP)		100	100	90	0	100	0			
115	Khulna 115 MW PP (KPC-2)	HFO (NENP)	7x17	115	115	16	16	16	16	99		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFD)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	914	914	939	939			
Khulna Zone Total												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16		94	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	25	16	25			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	88	85	88	106		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	950	1000	1000			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total												
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	76	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	168	181	170	180			
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	151	150	155	69		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	345	330	320	330	84		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	17	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	26	25	0	25			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	90	113	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	65	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Raishahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	83	80	83	594	71	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	53	113	44	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	72	0	72			
148	Almonihat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	34	0	12	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
22088 21710 10481.0 12309 10391 12480 3186 3054												
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amirua 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
Sub-Total: Plants under long term maintenance/ contract expired												
424 0 0 0 0 0 0 0 0 0 0 0												
Gross Total												
22512 21710 10481 12309 10391 12480 3186 3054												
(C) Actual data of 16.10.22 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	: 13177 MW, at = 20:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12678 MW, at = 20:00 hrs										
03.	Highest Generation (Generation end)	: 12309 MW, at = 20:00 hrs										
04.	Minimum Generation (Generation end)	: 9442 MW, at = 8:00 hrs										
05.	Day-peak Generation (Generation end)	: 10481 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12309 MW, at = 20:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 800 MW, at = 20:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9601 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 3186 MW										
d)	Coal supply Limitation	: 0 MW										
b)	Low water level in Kaptai lake	: 0 MW										
c)	Plants under shut down/ maintenance	: 3054 MW										
10.	Total Energy (Generation + India Import)	: 258.57 MKWh										
	By Gas = 127.840 MKWh	By Oil = 76.288 MKWh										
	By Coal = 23.345 MKWh	By Hydro = 3.758 MKWh										
	By Solar = 1.708 MKWh											
11.	Total Gas Supplied	: 975.40 MMCFD										
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
			Dhaka	4682	4338	344	Mymensingh	1060	900	160		
			Chattogram	1311	1311	0	Sylhet	548	444	104		
			Khulna	1482	1482	0	Barishal	349	349	0		
			Rajshahi	1250	1250	0	Rangpur	743	721	22		
			Cumilla	1253	1083	170						
			Total							12678	11878	800
			13. Fuel cost :		(a) Gas = 140180996 Taka	(c) Coal = 204007591 Taka						
					(b) Oil = 1033850647 Taka	Total = 1378039234 Taka						
			14. Maximum Temperature in Dhaka was : 34.1° C									
			15. Export through East-West interconnections :									
			At evening peak-hour			: 10481 MW, at 20:00 hrs						
			Maximum			: 406 MW, at 18:00 hrs						
			Energy			: 0 MKWh						
(D) Forecast of 17.10.22 (Today) Monday :												
01.	Maximum Demand	: 13700 MW (Generation end)										
02.	Maximum Generation	: 12480 MW (Generation end)										
03.	Reserve / Shortage	: -1220 MW (Generation end)										
			04. Maximum Load-shed			: 1124 MW At evening peak (Sub-station end)						
			05. Total Generation			: 287.79 MKWh						
			06. Probable Max. Temperature in Dhaka :			33.3° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation