

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9364667, 9551095

Month October, 2022				Day : Friday				Date : 21.10.22			
Probable Maximum Demand : 12700 MW				Probable Maximum Generation : 12516 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.81 ft		Today = 97.61 ft		Rule Curve = 107.80 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.10.22 (Yesterday)		21.10.22 (Today)		20.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	120	100	100		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	79	80	84		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	214	222	250	230	138	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	195	190	200	200	260	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	361	369	400	380	43	Gas Shortage
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	145	145	150	150		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	92	74	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	48	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	11	7	12	12		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	40	41	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	16	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	225	295	160	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	140	147		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	285	105	0	150		
27	Bramhangaan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	0	50		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	0	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	93	74	92		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	54	54	54		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	72	89	63	88		
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	55	92	67	90		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2833	3117	2453	3196	651	1180
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	156	156	156		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	18	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	32	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	51	105	51	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	150	150	150		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	141	300	140	300		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	90	25	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	38	38	38		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	3	28	30	30		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12	96	Fuel oil shortage
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	105	71	105		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	100	25	100		
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	33	68	33	70		
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
59	Mirsharal 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		
Chattogram Zone Total				2442	2382	792	1449	995	1453	276	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	49	48	48		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	167	187	150	150		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	250	260	250		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	324	288	400	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	10	5	5	45	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	70	71	70	70		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	42		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	44	48	50	50		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	50		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	6	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	20	60	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	111	17	110		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	115	53	115		
**	Import (Tijura)	India		160	160	146	160	143	166		
Cumilla Zone Total				3193	3169	1448	1635	1394	1691	479	360
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	45	30	100	157	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	108	90	108		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	108	48	120	92	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	253	292	251	359	249	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.10.22 (Yesterday)		21.10.22 (Today)		20.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1- Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	G1- Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	24	24	0	0	27		Gas Shortage
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5		6	Gas Shortage
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	65	60	60			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	20	30	140	140		201	ST Under maint.
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0	17		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	270	300	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	407	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	387	390	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	16	24	0	0	26		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	20	0	0	30		Gas Shortage
Sylhet Zone Total				2522	2477	1331	1423	1404	1485	215	774	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	205	200	190	190	210		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	45	0	33			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	68	0	40			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	225	225	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	50	0	50			
112	Rupsha 105 MW PP (Orion nupsha)	HFO (IPP)	6x18.445	105	105	35	94	50	94			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	30	105	67	105			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	100	0			
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	0	32	83		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	16	0	8	24		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFPCL)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	922	921	934	934			
Khulna Zone Total				2388	2384	1281	1531	1341	1486	317	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16		94	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	27	16	27			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	85	81	85	86	113		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	800	980	1000	1000			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	223	220	220			
Barishal Zone Total				1958	1958	1127	1327	1321	1349	113	244	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	50	16	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	32			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	176	170	170	170			
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	141	136	140	140	84		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	295	275	290	290	139		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	20	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	35	0	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	113	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	98	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Raishahi Zone Total				2129	2129	788	1206	879	1191	614	71	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	81			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	113	113	90	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	112	70	112			
148	Almonihat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	33	0	12	0			
Rangpur Zone Total				830	750	269	306	260	306	0	359	
Sub-total: Plants in operation				22088	21710	10122.0	12286	10298	12516	2914	3318	
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amnira 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0	0	0	
Gross Total				22512	21710	10122	12286	10298	12516	2914	3318	
(C) Actual data of 20.10.22 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	: 13150 MW, at = 20:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 12583 MW, at = 20:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 12286 MW, at = 20:00 hrs		Dhaka	4687	4357	330	Mymensingh	1025	855	170	
04.	Minimum Generation (Generation end)	: 9346 MW, at = 7:00 hrs		Chattogram	1376	1376	0	Sylhet	553	449	104	
05.	Day-peak Generation (Generation end)	: 10122 MW, at = 12:00 hrs		Khulna	1459	1459	0	Barishal	359	359	0	
06.	Evening-peak Generation (Generation end)	: 12286 MW, at = 20:00 hrs		Rajshahi	1234	1234	0	Rangpur	690	690	0	
07.	Evening Peak Load-shed (Sub-station end)	: 796 MW, at = 20:00 hrs		Cumilla	1201	1009	192					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9072 MW, at = 5:00 hrs						Total	12583	11787	796	
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :	(a) Gas = 132475964 Taka	(c) Coal = 209585148 Taka					
	a) Gas/LF limitation	: 2914 MW				(b) Oil = 963785135 Taka	Total = 1305846247 Taka					
	d) Coal supply Limitation	: 0 MW		14.	Maximum Temperature in Dhaka was :	34.4° C						
	b) Low water level in Kaptai lake	: 0 MW		15.	Export through East-West interconnections :							
	c) Plants under shut down/ maintenance	: 3318 MW		At evening peak-hour	: 10122 MW, at 20:00 hrs							
10.	Total Energy (Generation + India Import)	: 251.98 MKWh		Maximum	: 910 MW, at 12:00 hrs							
	By Gas = 126.108 MKWh	By Oil = 70.874 MKWh										
	By Coal = 23.946 MKWh	By Hydro = 3.708 MKWh										
	By Solar= 1.621 MKWh											
11.	Total Gas Supplied	: 970.28 MMCFD		Energy	: 0 MKWh							
(D) Forecast of 21.10.22 (Today) Friday :												
01.	Maximum Demand	: 12700 MW (Generation end)		04.	Maximum Load-shed	: 170 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 12516 MW (Generation end)		05.	Total Generation	: 260.47 MKWh						
03.	Reserve / Shortage	: -184 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	33.0° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation