

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9364667, 9551095

Month October, 2022				Day : Sunday				Date : 23.10.22			
Probable Maximum Demand : 13500 MW				Probable Maximum Generation : 12380 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.41 ft		Today = 97.21 ft		Rule Curve = 108.00 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.10.22 (Yesterday)		23.10.22 (Today)		22.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	170	100	100		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	79	80	80	80		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	294	257	250	250	103	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	417	411	400	412		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	161	170	160	170		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	75	92	74	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	42	39	40	45		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	13	12	13		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	16	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	163	260	160	260		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	126	144	80	118		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	106	0	150		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50		
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	84	74	84		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54		
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	87	63	87		
36	Meghnaghat 100 MW (EEL)	HFO (NENP)	12x8.9	100	100	67	83	67	83		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2480	3190	2423	3157	538	1180
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	155	155	155		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	32	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	51	105	51	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	150	150		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	141	300	140	300		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	76	25	76		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	36	30	36		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	2	30	10	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	105	61	105		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	100	25	100		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	33	56	33	56		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		
Chattogram Zone Total				2442	2382	924	1411	956	1400	288	330
58	Ashuganj TPP Unit-5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	10	50	48	50		
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	148	47	120	135		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	200	305	260	305		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360	Under maint.
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	432	318	300	318		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	47	5	47		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	8	73	8	8	12	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	71	73	70	73		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	44	44	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	51		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	8	34		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	12	12	15		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	0	100	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	111	17	111		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	115	53	115		
**	Import (Tripura)	India		160	160	162	158	143	166		
Cumilla Zone Total				3193	3169	1361	1732	1299	1766	377	360
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	74	70	80	128	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	97	90	97		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	88	48	88	112	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	250	289	290	295	240	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.10.22 (Yesterday)		23.10.22 (Today)		22.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1-Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	G1-Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	60	61			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140		91	ST Under maint.
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	341	300	341			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	409	408	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	396	380	380	380			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.4'5'2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total												
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	225	190	225	185		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	28	0	30			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	65			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0			
112	Rupsha 105 MW PP (Orion nupsha)	HFO (IPP)	6x18.445	105	105	28	75	50	75			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	67	105			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0			
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	304	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	919	917	937	937			
Khulna Zone Total												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	32		78	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	31	16	31			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	62	50	60	66	144		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	810	810	1000	1000			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	212	205	200	205			
Barishal Zone Total												
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	50	50	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0		71	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	16	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	171	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	143	140	143	77		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	280	374	320	374	40		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	20	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	90	113	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	69	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Raishahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	81	80	81	718	71	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	52	113	90	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Sypsa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	113	70	113			
148	Almohitha 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	35	0	12	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amirua 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
Sub-Total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 22.10.22 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	: 12952 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12373 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 12318 MW, at = 21:00 hrs										
04.	Minimum Generation (Generation end)	: 9281 MW, at = 9:00 hrs										
05.	Day-peak Generation (Generation end)	: 9750 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12318 MW, at = 21:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 584 MW, at = 21:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9259 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 2917 MW										
d)	Coal supply Limitation	: 0 MW										
b)	Low water level in Kaptai lake	: 0 MW										
c)	Plants under shut down/ maintenance	: 3192 MW										
10.	Total Energy (Generation + India Import)	: 250.64 MKWh										
	By Gas = 128.079 MKWh	By Oil = 66.274 MKWh										
	By Coal = 25.087 MKWh	By Hydro = 3.739 MKWh										
	By Solar = 1.678 MKWh											
11.	Total Gas Supplied	: 973.92 MMCFD										
(D) Forecast of 23.10.22 (Today) Sunday :												
01.	Maximum Demand	: 13500 MW (Generation end)										
02.	Maximum Generation	: 12380 MW (Generation end)										
03.	Reserve / Shortage	: -1120 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	4666	4506	160	Mymensingh	1005	805	200				
	Chattogram	1214	1214	0	Sylhet	522	419	103				
	Khulna	1481	1481	0	Barishal	379	379	0				
	Rajshahi	1213	1213	0	Rangpur	645	645	0				
	Cumilla	1249	1128	121	Total	12373	11789	584				
13.	Fuel cost :											
	(a) Gas = 134111225 Taka	(c) Coal = 201935663 Taka										
	(b) Oil = 893521635 Taka	Total = 1229568523 Taka										
14.	Maximum Temperature in Dhaka was :	34.8° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	: 9750 MW, at 21:00 hrs										
	Maximum Energy	: 496 MW, at 18:00 hrs										
		: 0 MKWh										
04.	Maximum Load-shed	: 1032 MW At evening peak (Sub-station end)										
05.	Total Generation	: 274.69 MKWh										
06.	Probable Max. Temperature in Dhaka :	31.8° C										

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation