

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	100	2840000	
3	Ghorasal 365 MW CAPP Unit-7	PDB	1*210	190	180	4347000	
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Under maint.
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	84	1921545	Engine problem
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	373	9283580	Gas shortage
8	Haripur 386 MW CAPP(HPL)	IPP	1*236	360	228	6010000	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	215	5054600	Gas shortage
10	Meghnaghat 100 MW(LEL)	NENP	12*8.9	100	83	1496640	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	139435	
14	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW RR (Doreen)	SIPP, REB	8*2.90	22	19	434520	Engine problem
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12*8.9	100	89	1674240	Engine problem
19	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	154	4137911	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	92	1725264	Engine problem
21	Katpott 52 MW PP (Sinha)	IPP	17*3.0	0	0	0	Fuel shortage
22	Karnalghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	654120	
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	1152960	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	904075	Fuel shortage
25	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	897038	
26	Bosila 108MW PPI(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Mahadevi-Ashulia)	SIPP, REB	33.67+4*8.73	80	48	1095320	Engine problem
28	Mazna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	833000	
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	15	349800	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	1032960	Engine problem
31	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	258	3709090	Fuel shortage
33	Karaniganj 300 MW PP (ARR)	IPP	258*1.4	300	232	1896967	Fuel conservation
34	Brambaraganj 100 MW PP (Aggreko)	IPP	114*0.959	100	90	894258	Engine problem
35	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	90	821571	Engine problem
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	134	2416032	Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	88	2118000	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	92	1765440	Engine problem
39	Manikganj 162MW PPI(MPL)	IPP	9*18	162	162	1926720	
40	Spectra Solar Plant Ltd.	IPP	35	35	0	67913	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	54	1270080	
Dhaka area Total				5847	3293	64061838	
41	Chattogram TPP-1	PDB	1*210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	25	550843	
44	Teknaf 20MW PP (Solartech)	IPP	20	20	0	24840	
45	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	44	768960	Engine problem
46	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	156	3477576	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	151	2247952	ST Under maint
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	1775599	
50	Hathazari 100 MW peaking PP	PDB	11*8.9	98	25	642576	Fuel shortage
51	Dohazari 100 MW Peaking	PDB	8*17	102	51	624284	Fuel shortage
52	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	80	1045560	Fuel shortage
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	928320	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
55	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	15	412800	
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4	7	0	621	
58	Anwara 300 MW PP (Uniled)	IPP	17*17.24	300	195	3319527	Fuel shortage
59	Jodac Power	IPP	3*18.55+1*3.6	54	54	1367115	
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	105	1775592	
61	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	1055040	Engine problem
62	Anlima Energy Ltd.	IPP	6*21.2	116	107	2517873	Engine problem
Mirshara 150 MW			BPDB-RPCL	18.5*9	0	33454	On test.
Chattogram area Total				2382	1393	22574032	
61	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCCL	1*142+1*75	221	140	2934000	Gas shortage
65	Ashuganj 450 MW CAPP(North)	APSCCL	1*360	360	0	0	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCCL	1*360	360	355	6960000	Gas shortage
67	Ashuganj 450 MW CAPP(East)	APSCCL	284*1+136*1	284	120	6347500	On test
68	Ashuganj 50 MW PP	APSCCL	14*3.968	45	10	802872	Gas shortage
69	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	5	150240	Gas shortage
70	Ashuganj 195MW PP (APSCCL-Uniled)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	48	1299709	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	6*8.92	50	43	1017376	Fuel shortage
74	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	50	1189880	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	1183200	
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	508968	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	2464200	
78	Import (Tripura)	Imported power	0	160	154	3665280	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	439900	Engine problem
80	Jangalia 40 MW PP (Lakshmi)	IPP	6*8.92	52	34	663283	Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	20	353230	Engine problem
82	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	122	1103808	Fuel conservation
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	111	1349760	
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	29400	Fuel shortage
85	Bhairab 54.5 MW	IPP	3*18.2	54	35	885240	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1673280	
Cumilla Area Total				3169	1627	35250580	
87	RPCL 210MW CAPP	IPP	4*35+1*70	202	103	1534080	Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	441720	Gas shortage
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10650	
91	Mymensingh 200 MW PP (Uniled)	IPP	9*78*21	200	88	1363200	Fuel shortage
92	Jamalpur 115 MW PP (Uniled)	IPP	9*78*12	115	97	1408400	Engine problem
93	Sulakhali 50 MW Solar PP	IPP	50	50	0	135970	
94	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	12	298080	Engine problem
Mymensingh Area Total				614	319	5190100	
95	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	30	716000	Machine problem
96	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	41	925320	Machine problem
97	Kushnara 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	Gas shortage
98	Shahbazar 33 MW CAPP	PDB	3*11.0	33	0	0	Under maint.
99	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	0	145800	Gas shortage
100	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	0	185832	Gas shortage
101	Hobiganj 11MW PP Cfidence-E	SIPP, REB	4*2.90	11	0	0	Engine problem
102	Shahbazar GTPP Unit-8 & 9	PDB	2*35	66	58	1407168	
103	Shahbazar 80MW PP (Shahbazar)	RPP	3*2.90	86	81	671040	
104	Shahbazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.
105	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	107	2468960	ST Under maint
106	Sylhet 20 MW GTPP	PDB	1*20	20	18	431000	
107	Sylhet 50MW PP (EPL)	NENP	27*2	50	0	131060	Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage
109	Bibiyan-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	250	7218000	FGMO
110	Bibiyan 400 MW CAPP	PDB	400	400	407	9790900	
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241560	
112	Bibiyan South 400 MW	PDB	400	383	394	9407900	
Sylhet Area Total				2477	1396	33658640	
113	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Fuel shortage
114	Bheramara (HVDC)	Imported power	2*500	1000	918	22181818	
115	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	16	144000	Fuel shortage
116	Fairpur MW Peaking PP	PDB	8*6.98	54	32	176160	Engine problem
117	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Fuel shortage
118	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	76	769408	Engine problem
119	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	200	5188656	Gas shortage
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	52500	Fuel shortage
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	50	251200	Fuel conservation
122	Rupsha 118 MW PP (Orion rupsha)	IPP	6*18.445	105	75	1702560	Engine problem
123	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
124	Mongla Orion 100 MW Solar PP	IPP	100	100	0	112320	
125	Khulna 330 MW CAPP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
126	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	337	7965800	On test.
Khulna Area Total				2384	1712	38514742	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	218496	Line O/L
128	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	27	540589	Engine problem
129	Bhola 225 MW CAPP	PDB	2*63+1*98	194	60	1528000	Gas shortage
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	0	0	0	Contract Expired
131	Payra 1320 MW	BCPCL	2*622	1244	660	16836200	Line O/L
132	Bhola Nutan Biddut BD LTD	IPP	220	220	220	5048291	
133	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				1958	983	24171576	
134	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage
136	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	32	208320	Engine problem
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	31479	Under maint.
138	Amnura 50 MW PP(Sinha)	ORPP	7*7.9	0	0	0	Contract Expired
139	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	42	896297	Engine problem
140	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	32	186034	Fuel shortage
141	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	230	0	0	Gas shortage
142	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	
143	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	148	3799064	Gas shortage
144	Sirajgonj 400 MW CAPP Unit-4	NWPGCL	1*282+1*132	414	296	7595018	Gas shortage
145	Santahar 50 MW Peaking PP	PDB	6*8.7	50	25	230700	Engine problem
146	Bogra 22 MW PP (SBB)	RPP	6*4	22	22	474960	
147	Bogra 20 MW PP (Energyprima)						