

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	1561000	Low Demand due to bad we
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*210	180	0	4063500	
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Under maint.
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	62	1345500	Low Demand due to bad we
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	303	8151040	Low Demand due to bad we
8	Haripur 365 MW CCPP(HPL)	IPP	1*230	365	219	5888000	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	150	4756100	Low Demand due to bad we
10	Meghnaghat 100 MW(IEI)	NENP	1*21.9	100	7	563860	Low Demand due to bad we
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	15	719288	Low Demand due to bad we
14	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	9*2.90	22	0	10908	Engine problem
16	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirganj 100 PP(Dutch Bangla)	NENP	12*8.9	100	8	623040	Low Demand due to bad we
19	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	0	2859947	Low Demand due to bad we
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	8	549792	Low Demand due to bad we
21	Katpodi 52 MW PP (Sinha)	IPP	17*3.0	52	0	0	Fuel shortage
22	Karnalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	329400	Low Demand due to bad we
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	727200	Low Demand due to bad we
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	591023	Low Demand due to bad we
25	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	0	309091	Low Demand due to bad we
26	Bosila 108MW PP(CLC)	IPP	12*9.775+1*3.5	0	0	0	
27	Summit Power (Madhabdi-Ashulia)	SIPP, REB	33.67+4*8.73	80	31	865000	Low Demand due to bad we
28	Mazna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	461400	Low Demand due to bad we
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	16	343000	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	0	388800	Low Demand due to bad we
31	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	15	1053818	Low Demand due to bad we
33	Karaniganj 350 MW PP (ARR)	IPP	25*14	350	0	52967	Low Demand due to bad we
34	Bramhataganj 100 MW PP (Aggreko)	IPP	11*40.959	100	0	6357	Low Demand due to bad we
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	7734	Low Demand due to bad we
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	0	633024	Low Demand due to bad we
37	Gazipur 100 MW PP	RPCL	6*17.5	105	17	1081200	Low Demand due to bad we
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	17	736240	Low Demand due to bad we
39	Manikganj 162MW PP(MPL)	IPP	9*18	162	35	665280	Low Demand due to bad we
40	Spectra Solar Plant Ltd	IPP	35	35	0	11517	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	15	820090	Low Demand due to bad we
Dhaka area Total				5847	1132	40206926	
41	Chattogram TPP-1	PDB	1*210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	0	379112	Low Demand due to bad we
44	Teknaf 20MW PP (Solartech)	IPP	20	20	0	560	
45	Palena 50MW PP (Baraka)	IPP	9*6.98	50	0	201120	Low Demand due to bad we
46	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	152	3348432	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	150	3197799	ST Under maint
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	17	1092290	Low Demand due to bad we
50	Hathazari 100 MW peaking PP	PDB	11*9.9	98	0	227040	Low Demand due to bad we
51	Dahazari 100 MW Peaking	IPP	8*17	102	17	314986	Low Demand due to bad we
52	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	11	526680	Low Demand due to bad we
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	30	452160	Low Demand due to bad we
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
55	Malancha, Ctg. EPZ (Uniled)		5*8.73+3*9.34	0	0	309600	
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4	7	0	8121	
58	Anwara 300 MW PP (Uniled)	IPP	17*17.24	300	101	1073891	Low Demand due to bad we
59	Jodis Power	IPP	3*18.55+1*3.6	54	17	826159	Low Demand due to bad we
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	17	1144140	Low Demand due to bad we
61	Juidah unit-2 (Acorn)	IPP	8*13.6	100	10	406080	Low Demand due to bad we
62	Anilma Energy Ltd.	IPP	6*21.2	116	0	933382	Low Demand due to bad we
Mirshara 150 MW			BPDB-RPCL	18.5*9	0	23418	On test.
Chattogram area Total				2382	522	14466390	
61	Ashuganj TPP Unit-3	APSCCL	11*50	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCCL	11*50	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCCL	11*50	134	0	0	Gas shortage
64	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	177	3156000	Low Demand due to bad we
65	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	80	1106600	Low Demand due to bad we
66	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	275	6608000	Low Demand due to bad we
67	Ashuganj 50 MW PP (East)	APSCCL	28*1.86+1*1.1	28	72	3736400	On test
68	Ashuganj 50 MW PP	APSCCL	14*3.968	45	5	560736	Low Demand due to bad we
69	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	5	356160	Low Demand due to bad we
70	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+1*16	195	8	334545	Low Demand due to bad we
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	592145	Low Demand due to bad we
73	Titas 50 MW Peaking PP	PDB	6*8.62	50	0	412756	Low Demand due to bad we
74	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	50	1002690	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	17	345120	Low Demand due to bad we
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	331488	
77	Feni 11 MW PP (Doreen)	SIPP, PDB	4*2.90	11	0	107802	
78	Imported (Tripura)	Imported power	0	160	48	1696320	Low Demand due to bad we
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	8	252400	Low Demand due to bad we
80	Jangalia 10 MW PP (Lakshmi)	IPP	6*8.92	52	0	299557	Low Demand due to bad we
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	0	126180	Low Demand due to bad we
82	Daudkandi 200 MW PP (B.Trac)	IPP	15*41.4	200	0	3840	Low Demand due to bad we
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	34	685140	Low Demand due to bad we
84	Chowmahani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Fuel shortage
85	Bhairab 54.5 MW	IPP	3*18.2	54	0	483120	Low Demand due to bad we
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	28	777600	Low Demand due to bad we
Cumilla Area Total				3169	815	22974979	
87	RPCL 210MW CCPP	IPP	4*35+1*70	202	35	1381440	Low Demand due to bad we
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	324281	
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	1800	
91	Mymensingh 200 MW PP (Uniled)	IPP	9*78.21	200	8	823200	Low Demand due to bad we
92	Jamalpur 115 MW PP (Uniled)	IPP	9*78.12	115	8	732000	Low Demand due to bad we
93	Sulatkhal 50 MW Solar PP	IPP	50	50	0	37890	
94	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	0	186240	Low Demand due to bad we
Mymensingh Area Total				614	69	3496851	
95	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	595000	Machine problem
96	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	816600	Machine problem
97	Kushnara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Gas shortage
98	Shahbazar 330 MW CCPP	PDB	3*110	0	0	0	Under maint.
99	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	0	0	Gas shortage
100	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	0	0	Gas shortage
101	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	0	0	Engine problem
102	Shahibazar GTPP Unit-8 & 9	PDB	2*35	66	65	1188960	
103	Shahibazar 80MW PP (Shahibazar)	RPP	3*2.90	86	30	146880	Low Demand due to bad we
104	Shahibazar 100 MW GTPP	PDB	0	100	0	0	Under maint.
105	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	178	3542100	
106	Sylhet 20 MW GTPP	PDB	1*20	20	18	352000	
107	Sylhet 50MW PP (EPL)	NENP	27*2	50	0	0	Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage
109	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	280	6453000	
110	Bibiyana-190 MW CCPP	IPP	400 MW	400	347	8378000	Low Demand due to bad we
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	182880	
112	Bibiyana South 400 MW	PDB	400 MW	383	350	8020600	Low Demand due to bad we
Sylhet Area Total				2477	1349	29676020	
113	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Fuel shortage
114	Bheramara (HVDC)	Imported power	2*500	1000	632	17660363	
115	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	0	0	Low Demand due to bad we
116	Fairpur 225 MW Peaking PP	PDB	8*6.98	54	0	5760	Low Demand due to bad we
117	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Fuel shortage
118	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	104704	Low Demand due to bad we
119	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	130	4080984	Low Demand due to bad we
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	Low Demand due to bad we
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Low Demand due to bad we
122	Rupsha 118 MW PP (Orion rupsha)	IPP	6*18.415	105	0	269280	Low Demand due to bad we
123	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
124	Mongla Orion 100 MW Solar PP	IPP	100	100	0	9360	
125	Khulna 330 MW CCPP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
126	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	3323850	On test.
Khulna Area Total				2384	762	25454301	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Low Demand due to bad we
128	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	1	86100	Low Demand due to bad we
129	Bhola 225 MW CCPP	PDB	2*63+1*98	194	0	482000	Low Demand due to bad we
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	0	0	0	Contract Expired
131	Payra 1320 MW	BCPCL	2*622	1244	500	13565600	Low Demand due to bad we
132	Bhola Nutan Biddut BD LTD	IPP	220	220	90	2818336	Low Demand due to bad we
133	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				1958	591	16952036	
134	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	
136	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Low Demand due to bad we
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Under maint.
138	Ammura 50 MW PP(Sinha)	ORPP	7*7.79	0	0	0	Contract Expired
139	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	0	209564	Low Demand due to bad we
140	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	93306	Low Demand due to bad we
141	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
142	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	
143	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	130	3139918	Low Demand due to bad we
144	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1*282+1*132	414	202		