

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9364667, 9551095

Month October, 2022				Day : Thursday				Date : 27.10.22			
Probable Maximum Demand : 13200 MW				Probable Maximum Generation : 12531 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.78 ft		Today = 96.78 ft		Rule Curve = 108.50 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.10.22 (Yesterday)		27.10.22 (Today)		26.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	81	80	84		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	281	272	300		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	372	400	400		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	120	120	125	135	215	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	67	92	74	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	23	51	51	53		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	10	25	32	32		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	28	41	41	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	97	110	116	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	225	242	225	260		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	111	133	80	134		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	80	0	0	150		
27	Bramhangaan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	0	50		
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	0	100		
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	0	17	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	74	74	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	32	54	54	54		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	90	63	90		
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	67	85	70	94		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
<b>Dhaka Zone Total</b>				<b>6004</b>	<b>5847</b>	<b>2623</b>	<b>2729</b>	<b>2411</b>	<b>3227</b>	<b>650</b>	<b>845</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	151	152	152		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	44	32	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	51	105	70	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150	74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	123	283	140	283		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	90	38	90		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	21	24	24	25		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Clq EPZ (Unite)	Gas	5x8.73+3x9.34	22	22	2	6	13	15		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	59	105	61	105		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	38	100	25	100		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	33	58	33	80		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5	150	150	18	0	0	0		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>924</b>	<b>1303</b>	<b>966</b>	<b>1386</b>	<b>310</b>	<b>404</b>
58	Ashuganj TPP Unit-5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	50	45	10	5	5	5	40	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	157	188	160	200		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	270	270	270	300		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x360	360	360	270	270	270	270		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	0	0		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	46	103	70	103		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	10	44	40	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	29	52	100	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	29	32	32		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	9	15	20	16	Gas Shortage
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	50	0	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	90	114	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	93	53	115		
**	Impoport (Tripura)	India		160	160	106	116	143	166		
<b>Cumilla Zone Total</b>				<b>3193</b>	<b>3169</b>	<b>1170</b>	<b>1414</b>	<b>1361</b>	<b>1793</b>	<b>541</b>	<b>0</b>
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	53	108	110	149	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	18	19		
83	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	49	97	90	97		
84	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	48	88	45	88	112	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>				<b>622</b>	<b>614</b>	<b>213</b>	<b>266</b>	<b>325</b>	<b>326</b>	<b>261</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.10.22 (Yesterday)		27.10.22 (Today)		26.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	42	42	42		48	GT-4 Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	11	11	11	11	40		Gas Shortage
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	70	60	70			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	78	72	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	165	178	165	178			
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	260	320	320			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	405	407	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	350	400	400			
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	8	11	11	11	39		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	10	10	10	10	40		Gas Shortage
<b>Sylhet Zone Total</b>												
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	130	210	200	250	200		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	38	0	38			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	76			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	225	225	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50			
112	Rupsha 105 MW PP (Orion upsha)	HFO (IPP)	6x18.445	105	105	21	75	75	75			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.445	105	105	0	0	0	0			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0			
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	32	0	16	83		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	8	40		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFPCL)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	752	890	916	916			
<b>Khulna Zone Total</b>												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	10	14	16	27			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	20	86	87	86	108		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	760	1000	1000			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	190	217	165	220			
<b>Barishal Zone Total</b>												
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	19	0	20		52	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	27			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	199	149	150	220	71		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	372	283	300	330	131		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	20	22			
136	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11	11		Gas Shortage
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	90	113	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
<b>Raishahi Zone Total</b>												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	82	80	82	814	52	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	82	112	100	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	115	70	75			
148	Almonihat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	29	0	12	0			
<b>Rangpur Zone Total</b>												
<b>Sub-total: Plants in operation</b>												
<b>(B) Plants under long term maintenance/ contract expired</b>												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amirua 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>												
<b>Gross Total</b>												
<b>(C) Actual data of 26.10.22 (Yesterday) Wednesday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 10800 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 10419 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 10833 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 6593 MW, at = 5:00 hrs										
05.	Day-peak Generation (Generation end)	: 9263 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 10800 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7595 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	: 3252 MW										
d)	Coal supply Limitation	: 0 MW										
b)	Low water level in Kaptai lake	: 0 MW										
c)	Plants under shut down/ maintenance	: 2492 MW										
10.	Total Energy (Generation + India Import)	: 212.04 MKWh										
	By Gas = 118.316 MKWh	By Oil = 50.259 MKWh										
	By Coal = 18.961 MKWh	By Hydro = 3.168 MKWh										
	By Solar = 1.423 MKWh											
11.	Total Gas Supplied	: 879.53 MMCFD										
<b>(D) Forecast of 27.10.22 (Today) Thursday :</b>												
01.	Maximum Demand	: 13200 MW (Generation end)										
02.	Maximum Generation	: 12531 MW (Generation end)										
03.	Reserve / Shortage	: -669 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	4143	4143	0	Mymensingh	826	826	0				
	Chattogram	1133	1133	0	Sylhet	381	381	0				
	Khulna	1138	1138	0	Barishal	209	209	0				
	Rajshahi	1145	1145	0	Rangpur	638	638	0				
	Cumilla	807	807	0								
					Total	10419	10419	0				
13.	Fuel cost :											
	(a) Gas = 129725703 Taka	(c) Coal = 164577640 Taka										
	(b) Oil = 666278619 Taka	Total = 960581962 Taka										
14.	Maximum Temperature in Dhaka was :	32.1° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	: 9263 MW, at 19:30 hrs										
	Maximum Energy	: 296 MW, at 7:00 hrs										
		: 0 MKWh										
04.	Maximum Load-shed	: 623 MW At evening peak (Sub-station end)										
05.	Total Generation	: 258.37 MKWh										
06.	Probable Max. Temperature in Dhaka :	29.8° C										

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation